



TYPICAL AIR CONDITIONING UNIT

HVAC NOTES

1. CONCEALED DUCTWORK TO BE UL-181, CLASS I, FIBERGLASS DUCTBOARD. DUCTS SHALL BE SIZED TO LIMIT MAIN DUCTS TO 1000 CFM & SECONDARY DUCTS TO 600 CFM. TO BE INSTALLED PER SMACNA STANDARDS.
2. EXPOSED DUCTWORK TO BE GALVANIZED SHEET METAL PER SMACNA STANDARDS. LINE WITH NEOPRENE COATED 1.0", 1.5 POUNDS PER CUBIC FOOT DUCT INSULATION.
3. ROUND FLEXIBLE DUCT TO BE UL-181, CLASS I, AIR DUCT MATERIALS.
4. DUCT SIZES SHOWN ARE CLEAR INSIDE DIMENSIONS.
5. PROVIDE U.L. LISTED 125 F FIRESTAT IN RETURN AIR OF EACH SYSTEM UNDER 2000 CFM TO SHUT DOWN FAN IN THE EVENT OF FIRE.
6. PROVIDE U.L. RATED FIRE DAMPERS WHERE REQUIRED AT ALL DUCT PENETRATIONS OF FIRE-RATED ASSEMBLIES AND WHERE REQUIRED BY CODE, INCLUDING OUTSIDE AIR INTAKES.
7. CONDENSATE DRAINS TO BE PVC PIPE RUN TO PLUMBERS P-TRAP WITHIN FIVE FEET OF AIR HANDLING UNITS.
8. ALL AIR HANDLING SYSTEMS TO BE BALANCED TO ASSURE PROPER AIR FLOWS PER PLANS.
9. DRYER DISCHARGE GRILL PER MFG'S REQUIREMENTS BACK DRAFT DAMPER MUST BE WEATHER AND INSECT PROOF.
10. EXHAUST FAN EQUAL TO BROAN MODEL NO. 100 CF. OR EQUAL. FAN SHALL BE CONTROLLED BY SWITCH ON WALL AT LIGHT SWITCH. PROVIDE BACK DRAFT DAMPER. PROVIDE AND INSTALL WATER PROOF GRILLE VENT ON ROOF FOR TOILET EXHAUST.
11. ALL SUPPLY AIR VENTS SHALL BE EQUIPPED WITH AIR CONTROL DAMPERS.
12. LOCATION OF OUTDOOR UNITS SHALL BE AS SHOWN ON PLAN. MECHANICAL CONTRACTOR SHALL PROVIDE A 4" CONCRETE REINFORCED PAD FOR EACH CONDENSING UNIT.
13. REFRIGERANT LINES SHALL BE SIZED BY UNIT MANUFACTURER AND INSTALLED ACCORDING TO MANUFACTURER'S INSTRUCTIONS.
14. ALL ELECTRICAL, MECHANICAL & PLUMBING PENETRATING FIRE WALLS SHALL BE FIRE CALKED. (PENETRATIONS THROUGH RATED CONSTRUCTION SHALL BE SEALED WITH A MATERIAL CAPABLE OF PREVENTING THE PASSAGE OF FLAMES AND HOT GASES WHEN TESTED IN ACCORDANCE WITH ASTM-E814.)
15. DRYER EXHAUST SHALL NOT EXCEED 25 FEET IN LENGTH.
16. THIS DRAWING SHOWN FOR ILLUSTRATION PURPOSES ONLY AND EQUIPMENT SHALL BE INSTALLED TO MEET FIELD REQUIREMENTS.
- 17.

* AHU= AIR HANDLING UNIT

NO.	TOTAL BTU	CFM	O.A.	HEAT *(KW)	ELECTRICAL		COMMENTS
					VOLTAGE	MCA CKT BKR	
1	60,000	2,000	300	75	208V, 3Ø	17	-
2	60,000	2,000	300	75	208V, 3Ø	17	-
3	60,000	2,000	300	100	208V, 3Ø	26.5	-
4	60,000	2,000	300	100	208V, 3Ø	26.5	-
5	120,000	4,000	800	125	208V, 3Ø	53.1	-
6	120,000	4,000	800	125	208V, 3Ø	53.1	-
7	36,000	1,200	300	75	208V, 3Ø	17	-
8	96,000	3,200	300	75	208V, 3Ø	26.2	-
9	48,000	1,600	300	75	208V, 3Ø	17	-
10	12,000	400	300	6	208V, 3Ø	17	-

* USE 3 STAGE HEAT

LOC.	CFM	VOLTAGE	TYPE	MANF.
TLTS	100	120	VENT	BROAN

	AHU #1 #2	AHU #3	AHU #4	AHU #5 #6	AHU #7	AHU #8	AHU #9	AHU #10	75 CFM	150 CFM	300 CFM	375 CFM
OUTSIDE AIR FLOW (CFM)(+)	860	340	360	4598	0	180	180	25				
RETURN AIR FLOW (CFM)	280	1320	1280	-598	800	2940	1240	360				
SUPPLY AIR FLOW (CFM)	1140	1660	1640	3600	800	3020	1420	375				
EXHAUST AIR FLOW (CFM)(-)	0	0	0	0	0	0	0	0				
BUILDING PRESSURE (CFM)	860	340	360	4598	1	180	180	25				
QUANTITIES	2	1	1	2	1	1	1	1				
TOTAL PRESSURIZATIONS	1720	340	360	9196	0	180	180	25				
RESULTING BUILDING PRESSURIZATION (CFM)	8101											

ALL UNITS COMBINED RATING EER 7.85; SEER/8. 70; SOUND RATING 8.0 DECIBELS

REFR. LO & HI PRESS SW., REFR. DRYER; EXTERNAL SERVICE VALVES, SIGHT GLASS

INLINE EXHAUST FANS FOR ASSY. AREA-1500 CFM EACH. CONNECT TO RUN WHEN A/C UNITS ARE IN COOLING MODE.

NOTE: SIZE DUCT WORK FOR: MAIN DUCT-900 FT./MIN. BRANCHES-600 FT./MIN.