

1899

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

HENRY H. FRY
DEPUTY ASSISTANT SECRETARY

AMENDED LETTER

EDWARD GREMILLION, P E, C E
DAMMON ENGINEERING, INC
1095 FLORIDA AVE
SLIDELL, LA 70458-0000

RE: P0322761
LIVING WORD INTERNATIONAL
MINISTRY
1000 CARUSO BLVD
SLIDELL, LA 70458-0000

NFPA 101, 2003

ASSEMBLY OVER 300 OCCUPANTS

Dear Applicant:

This is to advise that the previous review letter dated 02/22/2007 for this project is hereby amended as follows:

1. **This letter is to change the occupancy shown in the title block to correspond to the architectural review.**
2. **NOTE: Please enclose a copy of this letter with future submittals or other correspondence pertaining to this project.**

This review applies to the work indicated on the drawings or specifications.

This review shall in no way permit or authorize any omissions or deviations from the specific requirements of the adopted codes, rules and regulations in accordance with R.S. 40:1574.1(B).

The above amended review is valid if construction starts within 180 days from the above date of the original review letter.

Occupancy of the project will not be permitted until we receive the completed certificate and a satisfactory inspection of the completed construction has been made by this office.

To arrange for inspection of the project, please contact the District Office at the phone number below, two (2) to three (3) weeks in advance. Approved plans must be available on job site at time of inspection. Certificate of completion must be provided to inspecting Deputy for final inspection.

REVIEWED BY:
DONNA LEBLANC
MECHANICAL ENGINEER

CC:

Living Word International Ministries
American Sprinkler Co Inc
Property Insurance Association*
St Tammany Fire Protection District No 1*
City Of Slidell*
New Orleans District* 5042194600