

Dammon Engineering, Inc.

dammonengineering.com

1095 Florida Ave.
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

October 25, 2007

Mr. Jim Waite
Office of State Fire Marshal
8181 Independence Blvd.
Baton Rouge, LA 70806

RE: P0333770
Aldersgate United Methodist Church
360 Robert Road
Slidell, LA 70458-0000

Dear Mr. Waite,

With regard to the above referenced project, a supervised automatic sprinkler system has been added to cover the entire building. The sprinkler system negates the need for a 2-hour fire-area separation as well as a 1-hour rated corridor in the Business area. The fire rated walls will be reduced to smoke partitions. Since the sprinkler system has been added the area of refuge requirement has been eliminated as well. A sprinkler riser has been added to the General Purpose Equipment Room.

If you have any questions, please feel free to call.

Sincerely,

David Dammon
Project Manager