

# DAMMON ENGINEERING, INC.

dammonengineering.com

ARCHITECTS

ENGINEERS

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

1095 Florida Ave.  
Slidell, LA 70458

P.O. Box 2830  
Slidell, LA 70459

985-649-5832  
FAX 985-641-5950

January 23, 2009

Mr. Otis Ramke  
State of Louisiana Office of State Fire Marshal  
8181 Independence Blvd.  
Baton Rouge, Louisiana 70806

RE: PO337906  
Lakeshore Church  
Brewster Road  
Covington, La. 70433

LA. S.F.M. PLAN REVIEW  
PO# 337906 REVIEWER OTIS RAMKE  
READING FILE DATE MO 1 YR 09  
ORIG TO: \_\_\_\_\_  
SENDER  APPL. \_\_\_\_\_ OWNER \_\_\_\_\_  
CC'S \_\_\_\_\_  
COPY WHAT PGS. THIS PAGE ONLY  
B.R. \_\_\_\_\_ N.O.  ALEX \_\_\_\_\_ LAF. \_\_\_\_\_  
SHREVE \_\_\_\_\_ HC FILE \_\_\_\_\_ HO DEPT. \_\_\_\_\_  
DET FILE \_\_\_\_\_ HR FILE \_\_\_\_\_ NON-REQ. SYST. \_\_\_\_\_  
OTHER CITY OF COVINGTON  
DIVISION OF PERMITS & INSPECTIONS (STAM)  
DISTRICT 12 FIRE PREVENTION BUREAU

APPEARS TO BE ACCEPTABLE  
SEE AMENDED LETTER.



Dear Mr. Ramke,

The pastor for Lakeshore Church, Pastor Bryan Bilac, is requesting approval to eliminate the need for Fire Alarm and Smoke Detection for the above referenced project.

Pastor Bilac has determined that occupancy will not exceed two hundred at any given time and a doorman will be posted at the entrance with a manual counter to verify compliance with this request.

There will be no schooling or daycare at this facility, per Pastor Bilac and he shall post a placard at the entrance specifying the total occupancy allowed.

If you have any questions, or require any additional information, please feel free to call.

Sincerely,



Pete Dammon  
Dammon Engineering

1883