

NEW LAKESHORE CHURCH BREWSTER ROAD



FORM # 1 07/21/2007

ST. TAMMANY PARISH
DEPARTMENT OF PERMITS & REGULATORY
P. O. BOX 628
COVINGTON, LA 70434
PHONE: (985) 898-2574 or (985) 846-4166
FAX: (504) 896-2785
e-mail: permits@stpdgov.org

Kevin Davis
Parish President

898 2574

COMMERCIAL PLAN REVIEW STATUS

Arch

TECH LB

PERMIT # K072150 FLOOD ZONE _____ RECEIVED 11-26-07

PROJECT: Church

CONTACT PERSON: Design CONTRACTORS

PHONE: 985 626-1950 CELL: 774-1210 FAX: 626-1955

OFFICE USE ONLY

BUILDING

Specify allowable soil bearing capacity.
Verify same with a soil boring as per
article 1002.2.1 of the 2006 IBC.

Kevin G. Johnson
Bldg Plan Examiner
11/26/07

(EMMET PLUMBING)

ELECTRICAL Size The service disconnect in the MDP

11-26-07
PB UPS

Need - main serv.
disconnect,

MECHANICAL OK 8/27, 11-27-07

PLUMBING/GAS

OK LR 11-27-07

Patrick
Beaver



Equipment Schedule

Mega Air, Inc
2200 Front St
Slidell, La 70458

www.millcon.net

641-1277

A Professional Service Corporation

641-1375

Proposal Submitted in:	Phone	Project start	Date
Design Contractors	649-1950		1-07-07
Address	Lakewood Church		
22552 Hwy 1088			
Mandeville, La 70458	Fax	Reopen/cost	
	626-1955		

We hereby submit the following equipment schedule:

- Two 10 Ton systems with 30 Kw heat ----- Sanctuary
- One 7.5 Ton system with 15 Kw heat ----- Childrens Youth
- One 7.5 Ton system with 15 Kw heat ----- Foyer and reception
- One 4 Ton system with 15 Kw heat ----- Pro K
- One 3 Ton system with 10 Kw heat ----- Stage
- One 3 Ton system with 10 Kw heat ----- Offices

TOTAL TONNAGE ----- 45.

6555

225
95

45
~~38~~ 48

-190 kw