

FLOOR PLAN
SCALE: 1/8" = 1'-0"

NAME	FLOOR	BASE	WALLS	CEILING	REMARKS
FINISH SCHEDULE					
OFFICES	CARPET				
BATHROOMS	CONCRETE				
	VCT				
	NONE				
	CERAMIC TILE				
	CERAMIC TILE				
	RUBBER WALL BASE				
	WOOD BASE				
	NONE				
	GYPSUM BOARD				
	2'X2' LAY-IN PANELS				
	GYPSUM BOARD				
					CEILING HEIGHT TO
					CEILING HEIGHT TO

PROVIDE MOISTURE RESISTANT TYPE GYP. BD. IN ALL DAMP AREAS INCLUDING AT FUTURE BATHROOMS.

GENERAL NOTES

- INSULATION AND INSULATION ASSEMBLIES SHALL MEET THE REQUIREMENTS OF SECTION 719.
 - CONCEALED INSULATION SHALL HAVE A FLAME SPREAD OF 0-25 AND SMOKE DEVELOPED INDEX OF 0-450. EXCEPT THAT IN COMBUSTIBLE (WOOD FRAME) CONSTRUCTION.
 - FACING SHALL COMPLY WITH IBC 2006.
 - PROVIDE 5"x5" LANDING, LEVEL WITH FINISHED FLOOR, OUTSIDE EXTERIOR DOORS. THRESHOLDS SHALL BE NOT MORE THAN 1/2" IN HEIGHT AND SHALL BE BEVELLED IF MORE THAN 1/4".
- DIMENSIONS ARE TO CENTERLINE FACE OF STUDS, CENTER OF COLUMNS, OR FACE OF VENEER.
- CONTRACTOR TO VERIFY ALL SITE CONDITIONS, BUILDING LOCATIONS, AND DIMENSIONS PRIOR TO CONSTRUCTION.
- MATERIALS SHALL BE NEW AND U.L. LISTED.
- NO WORK SHALL BE CONCEALED UNTIL APPROVED BY LOCAL INSPECTORS.
- CONSTRUCTION SHALL COMPLY WITH ALL PARISH, STATE AND LOCAL CODES.
- CONTRACTOR TO GUARANTEE WORK FOR ONE YEAR.
- CONTRACTOR SHALL FURNISH WATER AND POWER FROM EXISTING SOURCES.
- EXTERIOR CAULK SHALL BE DOW CORNING 790 SILICONE. INSTALL IN ACCORDANCE WITH MANUFACTURER RECOMMENDATIONS. COORDINATE WITH ARCHITECT/OWNER AS TO COLOR. INTERIOR CAULKING TO BE EQUAL TO DAP PAINTABLE LATEX WITH SILICONE COATS. COLOR SELECTION BY OWNER.
- PROVIDE CLEANUP ON A REGULAR BASIS. NO TRASH STORED IN BUILDING.
- ALL BATT INSULATION SHALL HAVE A CLASS "A" (0-25) FLAME SPREAD IN COMPLIANCE WITH APPLICABLE CODE.
- USE 6" STUDS, OR 4" STAGGERED STUDS AT ALL PLUMBING WALLS.
- PROVIDE GALVANIZED METAL PAN WITH DRAIN AT WATER HEATER LOCATION.
- ALL CORNERS SHALL BE PROPERLY BRACED FOR WIND LOADS. A 48" SHEATHING SHALL BE PROVIDED EVERY 20 FEET OF WALL LENGTH.
- FLOORING SHALL BE NON-SLIP.
- INTERIOR LOCKS ON DOORS, IN MEANS OF EGRESS SHALL NOT REQUIRE THE USE OF A KEY, SPECIAL KNOWLEDGE, OR SPECIAL DEVICE TO OPEN IN THE DIRECTION OF EGRESS. ALL DOORS SHALL HAVE LEVER TYPE HANDLES.
- INTERIOR WALLS AND CEILINGS SHALL HAVE A FLAME SPREAD OF 0-200 AND A SMOKE DEVELOPMENT RATING OF 0-450.
- ALL WORK SHALL COMPLY WITH THE LATEST EDITION OF ALL LOCAL, STATE, AND NATIONAL CODES COVERING THE TYPE OF WORK BEING PERFORMED.
- PROVIDE PORTABLE FIRE EXTINGUISHERS IN ACCORDANCE WITH NFPA 101.1. SEE APPENDIX "E" OF NFPA 101 FOR DISTRIBUTION OF EXTINGUISHERS.
- ALL FIRE WALLS SHALL EXTEND TIGHT TO ROOF SHEATHING, AND BE SEALED WITH AN APPROVED FIRE CAULK.
- ALL ELECTRICAL, MECHANICAL, AND PLUMBING MATERIALS PENETRATING FIRE WALLS SHALL BE FIRE CALKED. (PENETRATIONS THROUGH RATED CONSTRUCTION SHALL BE SEALED WITH A MATERIAL CAPABLE OF PREVENTING THE PASSAGE OF FLAMES AND HOT GASES WHEN TESTED IN ACCORDANCE WITH ASTM-B114.)
- SERVICE COUNTER SHALL HAVE A HCP ACCESSIBLE WRITING SURFACE MAX 36" FROM F.F. (ADAAG MANUAL 1998, Pg 135)

WINDOW SCHEDULE


TYPE	FRAME	GLASS	UTES	ACCESSORIES	REMARKS
WINDOW	FIXED	S. HUNG			
	D. HUNG				
	HORIZ SLIDE				
	STEEL				
	ALUMINUM				
	WOOD				
	CASED OPENING				
	PRIVATEY				
	KEYED HANDLE				
	OFFICE/ENTRANCE				
	PUSH PULL				
	PANIC BAR				
	THRESHOLD				
	WEATHERSTRIP				
	DOOR STOP				
	ALARM				
	SILENCER				
	CLOSER				

DOOR & HARDWARE SCHEDULE

TYPE	FRAME	HINGE	LOOK	ACCESSORIES	REMARKS
DOOR - EXTERIOR	1	FR	30/27/0		
DOOR - INTERIOR	2	30/26/8			
	3	30/26/8			
	4	30/26/8			
	5	30/26/8			
	6	30/26/8			
	7	30/26/8			
	8	20/26/8			

DOOR & HARDWARE NOTES:

- ALL GLAZING TO BE DAMP ANVATED SAFETY GLASS.
- DOOR HINGES TO BE STANLEY FULL MORITSE STANDARD WEIGHT. BALL BEARING HINGES, STAINLESS STEEL WITH DARK BRONZE FINISH @ EXTERIOR & MATCHING DARK BRONZE FINISH ON STANDARD STEEL @ INTERIOR.
- PROVIDE LEVER HANDLE ADA APPROVED LOCKSETS WITH MATCHING DARK BRONZE FINISH TO BE SELECTED BY OWNER.
- COORDINATE KEYS SCHEDULE WITH OWNER.
- DOOR STOPS TO BE EQUAL TO IVES No. 436 OR 437, AS REQUIRED IN MATCHING FINISH.
- WEATHER-STRIP & THRESHOLD FINISH TO COMPLEMENT OTHER HARDWARE.



DAMMON ENGINEERING, INC

CHIEF ENGINEER
EMMETT DAMMON, P.E.
CHIEF ARCHITECT
ROBERT WILTSE

1095 FLORIDA AVENUE
SLIDELL, LA, 70458
OFFICE: 985-649-5832
FAX: 985-641-5950

WEBSITE:
WWW.DAMMONENGINEERING.COM
EMAIL:
DAMMONENG@BELL.SOUTH.NET

ARCHITECTURE
ENGINEERING
STUDIES
PLANNING
INVESTIGATION
EXPERT WITNESS

NEW CHURCH

TABERNACLE
BAPTIST CHURCH
FOURTH AVE
SUDELL, LA

PRELIMINARY
FLOOR PLAN

SCALE: AS NOTED

JOB#: 1978
DATE: 7-29-08

REVISIONS

A-1

OF