


MODEL 576 VENTILATION FAN



Quiet ventilator built with high performance blower and attractive grille.

FEATURES

GRILLE:

- Attractive grille conceals interior
- Matte white polymeric – blends well with any decor
- Torsion spring grille mounting – no tools required

BLOWER:

- Plug-in, permanently lubricated motor
- Designed for continuous operation

HOUSING:

- Rugged, 26-gage galvanized steel construction
- Integral key-holed mounting brackets for easy, secure installation directly to joist
- Provision for wire suspension when installed in a drop ceiling
- 4-inch round, tapered, polymeric duct fitting with built-in backdraft damper for easy, positive duct connection and no metallic clatter
- Fits in 2" x 6" ceiling or wall construction.

U.L. Listed for use in ceiling over bathtubs and showers when connected to a GFCI protected branch circuit

TYPICAL SPECIFICATION

Fan shall be Broan Model 576.

Unit shall have galvanized steel housing with integral mounting brackets. Unit shall have built-in backdraft damper and shall be ducted to a roof or wall cap.

Motor to be permanently lubricated and designed for continuous operation.

Air delivery shall be no less than 50 cfm and sound level no greater than 1.5 Sones. All air and sound ratings shall be certified by HVI.



Unit shall be U.L. Listed for use in ceiling over bathtubs and showers when connected to GFCI protected branch circuit.

SPECIFICATIONS

VOLTS	AMPS	STATIC PRESSURE	CFM	SONES	FAN WATTS	DUCT
120	0.2	0.10	50	1.5	17.5	4" Round



HVI-2100 CERTIFIED RATINGS comply with new testing technologies and procedures prescribed by the Home Ventilating Institute, for off-the-shelf products, as they are available to consumers. Product performance is rated at 0.1 in. static pressure, based on tests conducted in a state-of-the-art test laboratory. Sones are a measure of humanly-perceived loudness, based on laboratory measurements.



Broan-NuTone LLC Hartford, Wisconsin www.broan.com 800-558-1711

REFERENCE	QTY.	REMARKS	Project
			Location
			Architect
			Engineer
			Contractor
			Submitted by
			Date