



John Bel Edwards
GOVERNOR

Office of State Fire Marshal

8181 Independence Blvd. Baton Rouge, LA 70806
(225) 925-4911 (800) 256-5452 Fax (225) 925-4241

Cautionary Codes



H. "Butch" Browning
FIRE MARSHAL

Project Number:	AR-16-008577
Project Name:	BAYOU BAPTIST CHURCH

The items listed below are comments for informational purposes or identified requirements that will be verified upon final inspection by this office. These requirements need not be addressed back to the reviewer, however should be addressed prior to construction and inspection scheduling. Failure to comply with or otherwise address these items may affect final occupancy and use of the structure.

1	LRS 40:1731-(Effective 10/01/11) Provide access for persons with disabilities in accordance with the ADA-ABA Accessibility Guidelines, July 23, 2004 (also known as the 2010 Standards). This does not include a review for compliance with the Federal Americans with Disabilities (Civil Rights) Act of 1990. Compliance with state regulations and requirements does not guarantee compliance with federal law. NOTE: As per ADA-ABA 2004, Section F103, Office of State Fire Marshal appeal determinations are not valid for facilities that are designed, constructed, altered, or operated with federal funds, or leased by a federal agency. The authority having jurisdiction over such appeals is the administrator of the General Services Administration (GSA).
2	101:8.6.11 Draftstop concealed non-sprinklered spaces between ceiling and floor into areas not to exceed 1,000 sq. ft., if the concealed spaces have exposed combustible materials.
3	101:8.6.11 Draftstop non-sprinklered attic into areas not to exceed 3,000 sq. ft. each, if the attic has exposed combustible materials.
4	101:_.3.4 and IBC 907 Provide a fire alarm system in accordance with Section 9.6 and IBC 907.5.
5	101:_.3.5 and IBC 903 Provide supervised automatic sprinkler protection in accordance with 101:9.7 and the IBC.
6	NFPA 13:8.15.7.4 Sprinklers shall be installed under roofs or canopies over areas where combustibles are stored or handled.