



1 LIGHTING PLAN
SCALE 3/16\"/>

LEGEND	
	2x4 SUSPENDED FLUORESCENT LIGHT FIXTURE (3 - 32W BULB) LITHONIA 2678 3 32 A12
	CEILING MOUNTED FLUORESCENT STRIP FIXTURE (2 - 32W BULB)
	LED EXTERIOR MOTION LIGHT FIXTURE (2 BULB 5'W) WITH PHOTO TRIPPER (240V) LITHONIA 26712 35L A18 LP840
	DIRECTIONAL STAGE LIGHT (75W LED)
	CHANDELIER LIGHT FIXTURE (6 BULB 132W TOTAL)
	ELECTRIC PANEL BOARD
	EMERGENCY LIGHT FIXTURE (24V)
	EXIT LIGHT FIXTURE - WALL MOUNTED (100W)
	EXIT LIGHT FIXTURE - CEILING MOUNTED (100W)
	LED WALL MOUNTED LIGHT FIXTURE WITH 40 MIN. BACK-UP (75W)
	RECESSED CEILING LIGHT FIXTURE (40W)
	WALL-MOUNTED VANITY LIGHT FIXTURE (100W)
	CEILING MOUNTED LIGHT FIXTURE (100W)
	LED EXTERIOR MOTION LIGHT FIXTURE (2 BULB 5'W) WITH PHOTO TRIPPER (240V) LITHONIA 26712 35L A18 LP840
	CHANDELIER LIGHT FIXTURE (6 BULB 132W TOTAL)
	ELECTRIC PANEL BOARD
	EMERGENCY LIGHT FIXTURE (24V)
	EXIT LIGHT FIXTURE - WALL MOUNTED (100W)
	EXIT LIGHT FIXTURE - CEILING MOUNTED (100W)
	LED WALL MOUNTED LIGHT FIXTURE WITH 40 MIN. BACK-UP (75W)
	RECESSED CEILING LIGHT FIXTURE (40W)
	WALL-MOUNTED VANITY LIGHT FIXTURE (100W)
	CEILING MOUNTED LIGHT FIXTURE (100W)

- GENERAL NOTES**
- ALL WORK SHALL COMPLY WITH APPLICABLE NATIONAL, STATE AND LOCAL CODES, RULES, REGULATIONS, AND REQUIREMENTS OF THE SERVICE UTILITY COMPANY.
 - REFER TO ARCHITECTURAL DRAWINGS FOR EXACT LOCATION AND MOUNTING INSTRUCTIONS FOR ALL LIGHT FIXTURES. NOTIFY THE ARCHITECT AND ENGINEER OF ANY DISCREPANCIES BETWEEN THESE PLANS AND THE ARCHITECTURAL PLANS RELATING TO QUANTITY, TYPE AND LOCATION OF DEVICES AND/OR FIXTURES.
 - WHEN SPECIFIC LIGHT FIXTURE HAS BEEN SPECIFIED IN THE FUTURE SCHEDULE, ELECTRICAL SHALL PROVIDE COMPLETE ASSEMBLY, INCLUDING ALL PARTS AND HARDWARE TO INSURE PROPER FUNCTIONING OF THE FIXTURE.
 - ALL CONDUCTORS SHALL BE #12 AWG UNLESS NOTED OTHERWISE.
 - ALL 120V RINGS LONGER THAN 60 FEET SHALL BE #10 AWG AND 270V RINGS LONGER THAN 150 FEET SHALL BE #10 AWG UNLESS NOTED OTHERWISE.
 - ALL CONDUCTORS SHALL BE COPPER.
 - WHERE CONDUIT OR SEES ARE NOTED ON DRAWINGS THAT ARE SIZE SHALL BE LISTED. SEES ARE NOTED OTHERWISE.
 - MOUNTED LIGHT FIXTURES 48" AFT UNLESS NOTED OTHERWISE ON DRAWINGS.
 - ALL DIMENSIONED SWITCHES SHALL HAVE A COMMON SEWLESS FACEPLATE.
 - EACH DIMMER SWITCH SHALL BE NO MORE THAN SIX (6) SWITCHES LOCAL. ADDITIONAL MULTI-GANGED BOXES SHALL BE STACKED VERTICALLY AND THE WIDTH OF THE MULTI-GANGS SHALL BE AS EVEN AS POSSIBLE.
 - WHERE FLUORESCENT FIXTURES ARE SHOWN TO BE DIMMED THE DIMMER SHALL HAVE DIMMING TYPE BALLASTS WHICH ARE COMPATIBLE WITH THE SPECIFIED DIMMERS.
 - WHERE LED FIXTURES/LAMPS ARE SHOWN TO BE DIMMED THE DIMMER SHALL BE COMPATIBLE WITH THE FIXTURE/LAMP SPECIFIED OR PROVIDED.
 - ALL EMERGENCY LIGHT FIXTURES SHALL HAVE 40 MINUTE BATTERY BACKUP WITH INTEGRAL TEST BUTTON AND SHALL BE CONTROLLABLE.
 - ALL FLUORESCENT FIXTURES THAT UTILIZE DOUBLE-EENDED LAMPS AND CONTAIN BALLASTS SHALL BE PROVIDED WITH A DISCONNECTING MEANS IN ACCORDANCE WITH NEC 410.76.

REVISIONS	
#	DESCRIPTION

DAMMON ENGINEERING, INC.
LOUISIANA & MISSISSIPPI

Chief Engineer: Brian Mistich, PE
554 Old Spanish Trail
Sudley, LA 70458

www.dammonengineering.com
info@dammonengineering.com
PH: 985.649.5832 F: 985.641.5950

E102

64452 HIGHWAY 41, PEARL RIVER, LA 70492

JOB No: 2384 DATE: 9/15/2017

DRAWN BY: RLD CHECKED BY: CKD

SHEET TITLE: LIGHTING PLAN

SHEET No. 14 OF 15