

SPLIT SYSTEM AIR HANDLER UNIT/ CU SCHEDULE

AHU NO.	AREA	MBH				REHEAT			ESP	FAN HP	YORK MODEL AHU	CU TON
		SEN	LAT	TOTAL	CFM	O/A	HEAT	KW				
1	GOLF SHOP	52	46	98	2420	800	59	15	.44	1.50	KEU 090	7.5
2	FITNESS	58	34	92	3046	600	50	13	.48	1.50	KEU 090	7.5
3	LADIES' CARD.	52	34	86	2655	600	42	12	.30	1.50	KEU 090	7.5
4	MAIN BAR	72	68	140	3141	1200	77	14	.38	3.00	KEU 180	15
5	INFORM. DINING	54	36	90	2970	450	101	13	.34	1.50	KEU 090	7.5
6	FOUNDER	60	57	117	2800	1000	99	12	.35	2.00	KEU 120	10
7	KITCHEN	73	46	119	3740	600	14	8	.30	0.75	KEU 120	10
8	CHEF OFFICE	31	5	36	1933	400	13	9	.30	0.75	KEU 060	5
9	BANQUET	31	31	62	1565	400	3	7	.49	0.75	KEU 060	5
10	BANQUET	30	30	60	1500	400	25	8	.43	0.75	KEU 060	5
11	BANQUET	30	30	60	1806	400	32	10	.43	0.75	KEU 060	5
12	RECEPTION AREA	62	57	119	2832	1000	73	12	.26	2.00	KEU 120	10
13	2ND FLOOR LOCKER	28	28	56	1500	500	37	5	.37	0.75	KEU 060	5
14	2ND FLOOR SHOWER	21	23	44	1200	400	28	4	.31	0.75	KEU 060	5
15	BANQUET	20	48	68	925	925	50	-	0.50	2.00	SELECT BY CONTRACTOR	6
16	BANQUET	20	48	68	925	925	50	-	0.50	2.00	SELECT BY CONTRACTOR	6
17	BANQUET	20	48	68	925	925	50	-	0.50	2.00	SELECT BY CONTRACTOR	6
18	INFOR. DINE BANQUET	20	48	68	925	925	50		0.50	2.00	SELECT BY CONTRACTOR	6
	TOTALS:							142				

MBH= 1000 BTU/HR-
AHU/ CU= HORIZONTAL AIR HANDLER/ CONDENSING UNIT