

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

PAUL SMITH
FIRE MARSHAL

AMENDED LETTER

ROBERT SOLLBERGER
DAMMON ENGINEERING, INC
1095 FLORIDA AVE
SLIDELL, LA 70458-0000

RE: P0335458
REESE OWENS BUILDING- OAK HARBOR
OAK HARBOR BLVD
SLIDELL, LA 70458

NFPA 101, 2003

BUSINESS

Dear Applicant:

This is to advise that the previous review letter dated 10/23/2007 for this project is hereby amended as follows:

1. **Disregard item no. 4b.1, 2, and 3 of original review letter for this project.**

Subsequent correspondance indicates that the accessible walk slopes do not exceed 1:20. Ramp and handrail compliance are not required.

2. **Disregard items no. 19 through 27 of original review letter.**

The LSUCC review indicated was performed in error. The site location lies outside the city of Mandeville, and shall be performed by the St. Tammany Parish officials.

This review applies to the work indicated on the drawings or specifications.

This review shall in no way permit or authorize any omissions or deviations from the specific requirements of the adopted codes, rules and regulations in accordance with R.S. 40:1574.1(B).

The above amended review is valid if construction starts within 180 days from the above date of the original review letter.

Occupancy of the project will not be permitted until we receive the completed certificate and a satisfactory inspection of the completed construction has been made by this office.

To arrange for inspection of the project, please contact the District Office at the phone number below, two (2) to three (3) weeks in advance. Approved plans must be available on job site at time of inspection. Certificate of completion must be provided to inspecting Deputy for final inspection.

REVIEWED BY:
JAMES WAITE
ARCHITECT

Nov 18, 2007
P0335458 - PAGE 1

CC:

Owen Construction Co

St Tammany Fire Protection District No 1*

City Of Slidell*

New Orleans District* 5042194600