


EXHAUST FAN SCHEDULE				
LOC	CFM	VOLTAGE	TYPE	MANF.
TOILETS	SEE DWG	120	VENT/LIGHT	-

A/C SPLIT UNIT SCHEDULE								
NO.	TOTAL RTU	CFM	O.A.	HEAT (KW)	ELECTRICAL VOLTAGE	MECH CKT	BRKR	COMMENTS
A	72,000	2,000	300	20	240V, 1 $\phi$	37.4	MDF#9.11	CARRIER
B	72,000	2,000	500	20	240V, 1 $\phi$	37.4	MDF#8.10	CARRIER

LEGEND			
	A/C REGISTER		AIR RETURN
	SUPPLY DUCT #1		RETURN DUCT
	SUPPLY DUCT #2		



MECHANICAL PLAN  
SCALE: 3/16"=1'-0"



**DAMMON**  
ENGINEERING, INC.  
EMMETT  
DAMMON

ARCHITECT  
ROBERT  
WILTSE

1095 FLORIDA AVENUE  
SLIDELL, LA, 70458  
985-649-5832

WEBSITE:  
WWW.DAMMONENGINEERING.COM/  
EMAIL:  
DAMMONENG@BELLSOUTH.NET

ARCHITECTURE  
ENGINEERING  
STUDIES  
PLANNING  
INVESTIGATION  
EXPERT WITNESS

NEW OFFICE  
BUILDING

K.B. KAUFMANN  
TERRACE AVENUE  
SLIDELL, LA

MECHANICAL  
PLAN

REV:

SCALE: AS NOTED

JOB#: 1871

DATE: 10-31-07

SHEET

M-1

OF