

DAMMON ENGINEERING, INC

Date: 10-12-21 Project: Boyd Funeral Home
Reviewed: X
Reviewed as noted:
Revise and ReSubmit:
Rejected:
Other:

Correction or comments made on the shop drawings during this review do not relieve the contractor from compliance with requirements of the drawings and specifications. This check is only for review of the general conformance with the design concept of the project and general compliance with the information given in the contract documents. This contractor is responsible for: confirming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction; coordinating his other work with that of all other trades and performing all in a safe and satisfactory manner.

Submittal item: Sprinkler drawings
Comments:



Hydraulic Calculations by HydraCALC

Jefferson Sprinkler, Inc
P.O. Box 129
Gretna, LA 70054
504-362-0198

Job Name : BOYD FUNERAL HOME
Drawing : SHEET 1
Location : 4800 DOWNMAN RD, NEW ORLEANS, LA 70126
Remote Area : 1
Contract : 16228
Data File : Boyd Funeral Home Sprinkler Plans Area 1.WXF

HYDRAULIC CALCULATIONS
for

JOB NAME BOYD FUNERAL HOME
Location 4800 DOWNMAN RD, NEW ORLEANS, LA 70126
Drawing # SHEET 1
Contract # 16228
Date 04/22/2021

DESIGN

Remote area # 1
Remote area location ATTIC
Occupancy classification LIGHT HAZARD
Density 0.10 - Gpm/SqFt
Area of application 2535 (MIN.) - SqFt
Coverage/sprinkler 120 - SqFt
Type of sprinkler calculated VK3001 QR UPRIGHT K5.6 1/2"NPT 200F BRASS
Sprinklers calculated 24
In-rack demand N/A - GPM
Hose streams 100 - GPM
Total water required (including hose streams) 480.693 - GPM @ 47.694 - Psi
Type of system DRY
Volume of system (dry or pre-action) 171 - Gal

WATER SUPPLY INFORMATION

Test date 01/28/2021
Location DOWNMAN RD @ BABYLON ST
Source of info JSI

CONTRACTOR INFO JEFFERSON SPRINKLER

Address 1903 HANCOCK ST
Phone # (504) 393-7699
Name of designer BLAKE MICKLER
Authority having jurisdiction LASFM

NOTES:


text1(35) - invisible

Water Supply Curve

Jefferson Sprinkler, Inc
BOYD FUNERAL HOME

City Water Supply:
C1 - Static Pressure : 55
C2 - Residual Pressure: 54
C2 - Residual Flow : 920

Demand:
D1 - Elevation : 6.423
D2 - System Flow : 380.639
D2 - System Pressure : 49.694
Hose (Demand) : 100
D3 - System Demand : 480.639
Safety Margin : 5.005



Fittings Used Summary

Jefferson Sprinkler, Inc
BOYD FUNERAL HOME

Fitting Legend Abbrev. Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Dvk Dry Viking F1								3		5		49								
E NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zcd Colt C300 Horz Butt																				

Fitting generates a Fixed Loss Based on Flow

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

Node at Source	Static Pressure	Residual Pressure	Flow	Available Pressure	Total Demand	Required Pressure
TEST	55.0	54	920.0	54.699	480.64	49.694

NODE ANALYSIS

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes
1	11.79	5.6	8.02	15.86	0.1 120
2	11.79	5.6	8.06	15.9	0.1 120
3	11.79	5.6	8.14	15.98	0.1 120
4	11.79	5.6	8.31	16.15	0.1 120
5	11.79	5.6	8.62	16.44	0.1 120
6	11.79	5.6	9.09	16.88	0.1 120
7	11.79		23.63		
8	11.79		23.95		
9	11.79		26.18		
10	11.79		28.46		
TOR1	11.79		31.64		
DPV	5.0		35.73		
BOR	1.0		39.94		
TEST	1.0		49.69	100.0	
13	11.79	5.6	8.02	15.86	0.1 120
14	11.79	5.6	8.05	15.89	0.1 120
15	11.79	5.6	8.16	16.0	0.1 120
16	11.79	5.6	8.38	16.21	0.1 120
17	11.79	5.6	8.75	16.56	0.1 120
18	11.79	5.6	9.31	17.08	0.1 120
19	19.92	5.6	9.77	17.51	0.1 120
20	19.92	5.6	9.81	17.54	0.1 120
21	15.83		13.03		
22	15.83		14.38		
23	15.83	5.6	7.76	15.6	0.1 120
24	15.83	5.6	7.43	15.26	0.1 120
25	15.83	5.6	7.23	15.06	0.1 120
26	15.83	5.6	7.03	14.85	0.1 120
27	15.83	5.6	7.0	14.82	0.1 120
28	15.83	5.6	7.0	14.82	0.1 120
29	15.83	5.6	7.01	14.83	0.1 120
30	15.83	5.6	7.07	14.89	0.1 120
31	15.83	5.6	7.37	15.2	0.1 120
32	15.83	5.6	7.64	15.48	0.1 120

Final Calculations : Hazen-Williams

Jefferson Sprinkler, Inc
BOYD FUNERAL HOME

Page 5
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1 to 2	11.79 11.79	5.60	14.15	2	E 4.392	10.000 4.391	100	8.020 0.0			
			14.15	2.157		14.391	0.0028	0.041	Vel =	1.24	
2 to 3	11.79 11.79	5.60	15.90	2		6.820	100	8.061 0.0			
			30.05	2.157		6.820	0.0116	0.079	Vel =	2.64	
3 to 4	11.79 11.79	5.60	15.98	2		6.830	100	8.140 0.0			
			46.03	2.157		6.830	0.0255	0.174	Vel =	4.04	
4 to 5	11.79 11.79	5.60	16.14	2		6.830	100	8.314 0.0			
			62.17	2.157		6.830	0.0444	0.303	Vel =	5.46	
5 to 6	11.79 11.79	5.60	16.44	2		6.830	100	8.617 0.0			
			78.61	2.157		6.830	0.0687	0.469	Vel =	6.90	
6 to 7	11.79 11.79	5.60	16.88	2	4E T 17.567 8.783	121.740 26.350	100	9.086 0.0			
			95.49	2.157		148.090	0.0982	14.546	Vel =	8.38	
7 to 8	11.79 11.79		0.0	3		24.120	100	23.632 0.0			
			95.49	3.26		24.120	0.0131	0.317	Vel =	3.67	
8 to 9	11.79 11.79		185.84	3		22.990	100	23.949 0.0			
			281.33	3.26		22.990	0.0970	2.230	Vel =	10.81	
9 to 10	11.79 11.79		99.31	3	E 6.714	6.750 6.714	100	26.179 0.0			
			380.64	3.26		13.464	0.1697	2.285	Vel =	14.63	
10 to TOR1	11.79 11.79		0.0	3	E 6.714	12.000 6.714	100	28.464 0.0			
			380.64	3.26		18.714	0.1697	3.176	Vel =	14.63	
TOR1 to DPV	11.79 5		0.0	4	E Dvk 9.397 4.699	10.790 14.095	100	31.640 2.941			
			380.64	4.26		24.885	0.0461	1.148	Vel =	8.57	
DPV to BOR	5 1		0.0	4	2T B 52.668 15.8	6.790 68.468	120	35.729 1.732			
			380.64	4.26		75.258	0.0329	2.477	Vel =	8.57	
BOR to TEST	1 1		0.0	4	2E G 31.864 3.186	106.000 35.050	150	39.938 5.919		** Fixed Loss = 5.919	
			380.64	4.07	Zcd 0.0	141.050	0.0272	3.837	Vel =	9.39	
TEST			100.00 480.64					49.694		Qa = 100.00 K Factor = 68.18	
1 to 13	11.79 11.79		1.71	2		7.500	100	8.020 0.0			
			1.71	2.157		7.500	0	0.0	Vel =	0.15	
13 to 14	11.79 11.79	5.60	15.86	2		7.510	100	8.020 0.0			
			17.57	2.157		7.510	0.0044	0.033	Vel =	1.54	
14 to 15	11.79 11.79	5.60	15.89	2		7.510	100	8.053 0.0			
			33.46	2.157		7.510	0.0141	0.106	Vel =	2.94	

Final Calculations : Hazen-Williams

Jefferson Sprinkler, Inc
BOYD FUNERAL HOME

Page 6
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
15 to 16	11.79 11.79	5.60	16.00 49.46	2 2.157			7.510 7.510	100 0.0290	8.159 0.0 0.218			Vel = 4.34
16 to 17	11.79 11.79	5.60	16.20 65.66	2 2.157			7.510 7.510	100 0.0491	8.377 0.0 0.369			Vel = 5.76
17 to 18	11.79 11.79	5.60	16.56 82.22	2 2.157			7.510 7.510	100 0.0744	8.746 0.0 0.559			Vel = 7.22
18 to 9	11.79 11.79	5.60	17.09 99.31	2 2.157	3E T	13.175 8.783	137.820 21.957 159.777	100 0.1056	9.305 0.0 16.874			Vel = 8.72
9			0.0 99.31						26.179			K Factor = 19.41
19 to 20	19.920 19.920	5.60	17.51 17.51	2 2.157			7.950 7.950	100 0.0043	9.773 0.0 0.034			Vel = 1.54
20 to 21	19.920 15.83	5.60	17.53 35.04	2 2.157	3E T	13.175 8.783	72.540 21.957 94.497	100 0.0154	9.807 1.771 1.453			Vel = 3.08
21 to 22	15.83 15.83		78.96 114.0	2 2.157	T	8.783	1.120 8.783 9.903	100 0.1363	13.031 0.0 1.350			Vel = 10.01
22 to 8	15.83 11.79		71.84 185.84	2 2.157	T	8.783	14.440 8.783 23.223	100 0.3366	14.381 1.750 7.818			Vel = 16.32
8			0.0 185.84						23.949			K Factor = 37.97
21 to 23	15.83 15.83		-78.96 -78.96	2 2.157	E	4.392	71.900 4.391 76.291	100 -0.0691	13.031 0.0 -5.272			Vel = 6.93
23 to 24	15.83 15.83	5.60	15.60 -63.36	2 2.157			7.220 7.220	100 -0.0460	7.759 0.0 -0.332			Vel = 5.56
24 to 25	15.83 15.83	5.60	15.26 -48.1	2 2.157			7.200 7.200	100 -0.0276	7.427 0.0 -0.199			Vel = 4.22
25 to 26	15.83 15.83	5.60	15.05 -33.05	2 2.157	E	4.392	10.000 4.391 14.391	100 -0.0138	7.228 0.0 -0.198			Vel = 2.90
26 to 27	15.83 15.83	5.60	14.85 -18.2	2 2.157			6.200 6.200	100 -0.0047	7.030 0.0 -0.029			Vel = 1.60
27 to 28	15.83 15.83	5.60	14.82 -3.38	2 2.157			6.200 6.200	100 -0.0002	7.001 0.0 -0.001			Vel = 0.30
28 to 29	15.83 15.83	5.60	14.82 11.44	2 2.157			6.200 6.200	100 0.0019	7.000 0.0 0.012			Vel = 1.00

Final Calculations : Hazen-Williams

Jefferson Sprinkler, Inc
BOYD FUNERAL HOME

Page 7
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
29 to 30	15.83 15.83	5.60	14.82 26.26	2 2.157			6.240 6.240	100 0.0090	7.012 0.0 0.056		Vel = 2.31	
30 to 31	15.83 15.83	5.60	14.89 41.15	2 2.157	E	4.392	10.210 4.391 14.601	100 0.0207	7.068 0.0 0.302		Vel = 3.61	
31 to 32	15.83 15.83	5.60	15.21 56.36	2 2.157			7.260 7.260	100 0.0371	7.370 0.0 0.269		Vel = 4.95	
32 to 22	15.83 15.83	5.60	15.47 71.83	2 2.157	3E T	13.175 8.783	94.260 21.957 116.217	100 0.0580	7.639 0.0 6.742		Vel = 6.31	
22			0.0 71.83						14.381		K Factor = 18.94	