PANEL SCHEDULE

PANEL: PP1 | LOCATION: ELECTRICAL ROOM | FEEDER SOURCE: UTILITY | INTERRUPTING RATING = 24 KAIC | VOLTAGE: 240/120V, 400A, 1Φ, 3W WITH MAIN BREAKER | ENCLOSURE: SURFACE MOUNTED W/ EQUIPMENT GND BAR SQUARE-D, I-LINE PANELBOARD

CKT NO	THHN WIRE SIZE	LOAD DESCRIPTION / LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	AΦ	CΦ	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION / LOCATION	THHN WIRE SIZE	CKT NO
1	#12	RECEPTACLES, BATH ROOM	20	1	540	540		530	1	20	BATH ROOM 1, EXHAUST FANS AND LIGHTS	#12	2
3	#12	RECEPTACLE, WATER FOUNTAIN	20	1	1000		530	530	1	20	BATH ROOM 2, EXHAUST FANS AND LIGHTS	#12	4
5	#12	RECEPTACLES, BATH ROOM	20	1	540	300		300	1	20	LIGHTS, CORRIDOR AND PORCH	#12	6
7	#12	RECEPTACLE, WASHER	20	1	500		250	250	2	20	EXTERIOR POLE TOP LIGHTING	#10	8
9	#10	DRYER	30	2	2500	250							10
11					2500		2500		1	20	SPARE		12
13	#10	WATER HEATER 1	30	2	2500	2500			1	20	SPARE		14
15					2500		2500		1	20	SPARE		16
17	#10	WATER HEATER 2	30	2	2500	2500			1	20	SPARE		18
19					2500		2500		1	20	SPARE		20
21		PREPARED SPACE	-	1					1	-	PREPARED SPACE		22
23		PREPARED SPACE	-	1					1	-	PREPARED SPACE		24
25		PREPARED SPACE	-	1					1	-	PREPARED SPACE		26
27		PREPARED SPACE	-	1					1	-	PREPARED SPACE		28
29		PREPARED SPACE	-	1					1	-	PREPARED SPACE		30
31		PREPARED SPACE	-	1					1	-	PREPARED SPACE		32
33		PREPARED SPACE	-	1					1	-	PREPARED SPACE		34
35	350 KCM	FEEDER TO CAMPER SITES	200	2	28800				1	-	PREPARED SPACE		36
37					28800				1	-	PREPARED SPACE		38
39	350 KCM	FEEDER TO CAMPER SITES	200	2	24000			24000	2	200	FEEDER TO CAMPER SITES	350 KCM	40
41					24000			24000					42

SOLID NEUTRAL NEUTRAL WIRE (N) | TOTAL CONNECTED LOAD (VA) = 173,040 | AΦ = 86,460 | BΦ = 86,580 | GROUND BUS GROUND WIRE (G)

PANEL SCHEDULE

PANEL: PP2 | LOCATION: ELECTRICAL ROOM | FEEDER SOURCE: UTILITY | INTERRUPTING RATING = 24 KAIC | VOLTAGE: 240/120V, 400A, 1Φ, 3W WITH MAIN BREAKER | ENCLOSURE: SURFACE MOUNTED W/ EQUIPMENT GND BAR SQUARE-D, I-LINE PANELBOARD

CKT NO	THHN WIRE SIZE	LOAD DESCRIPTION / LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	AΦ	CΦ	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION / LOCATION	THHN WIRE SIZE	CKT NO
1	#12	RECEPTACLES, BATH ROOM	20	1	540	540		530	1	20	BATH ROOM 1, EXHAUST FANS AND LIGHTS	#12	2
3	#12	RECEPTACLE, WATER FOUNTAIN	20	1	1000		530	530	1	20	BATH ROOM 2, EXHAUST FANS AND LIGHTS	#12	4
5	#12	RECEPTACLES, BATH ROOM	20	1	540	300		300	1	20	LIGHTS, CORRIDOR AND PORCH	#12	6
7	#12	RECEPTACLE, WASHER	20	1	500		250	250	2	20	EXTERIOR POLE TOP LIGHTING	#10	8
9	#10	DRYER	30	2	2500	250							10
11					2500		2500		1	20	SPARE		12
13	#10	WATER HEATER 1	30	2	2500	2500			1	20	SPARE		14
15					2500		2500		1	20	SPARE		16
17	#10	WATER HEATER 2	30	2	2500	2500			1	20	SPARE		18
19					2500		2500		1	20	SPARE		20
21		PREPARED SPACE	-	1					1	-	PREPARED SPACE		22
23		PREPARED SPACE	-	1					1	-	PREPARED SPACE		24
25		PREPARED SPACE	-	1					1	-	PREPARED SPACE		26
27		PREPARED SPACE	-	1					1	-	PREPARED SPACE		28
29		PREPARED SPACE	-	1					1	-	PREPARED SPACE		30
31		PREPARED SPACE	-	1					1	-	PREPARED SPACE		32
33		PREPARED SPACE	-	1					1	-	PREPARED SPACE		34
35	350 KCM	FEEDER TO CAMPER SITES	200	2	28800				1	-	PREPARED SPACE		36
37					28800				1	-	PREPARED SPACE		38
39	350 KCM	FEEDER TO CAMPER SITES	200	2	28800			24000	2	200	FEEDER TO CAMPER SITES	350 KCM	40
41					28800			24000					42

SOLID NEUTRAL NEUTRAL WIRE (N) | TOTAL CONNECTED LOAD (VA) = 182,840 | AΦ = 91,260 | BΦ = 91,380 | GROUND BUS GROUND WIRE (G)

PANEL SCHEDULE

PANEL: PP3 | LOCATION: ELECTRICAL ROOM | FEEDER SOURCE: UTILITY | INTERRUPTING RATING = 24 KAIC | VOLTAGE: 240/120V, 400A, 1Φ, 3W WITH MAIN BREAKER | ENCLOSURE: SURFACE MOUNTED W/ EQUIPMENT GND BAR SQUARE-D, I-LINE PANELBOARD

CKT NO	THHN WIRE SIZE	LOAD DESCRIPTION / LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	AΦ	CΦ	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION / LOCATION	THHN WIRE SIZE	CKT NO
1	#12	RECEPTACLES, BATH ROOM	20	1	540	540		530	1	20	BATH ROOM 1, EXHAUST FANS AND LIGHTS	#12	2
3	#12	RECEPTACLE, WATER FOUNTAIN	20	1	1000		530	530	1	20	BATH ROOM 2, EXHAUST FANS AND LIGHTS	#12	4
5	#12	RECEPTACLES, BATH ROOM	20	1	540	300		300	1	20	LIGHTS, CORRIDOR AND PORCH	#12	6
7	#12	RECEPTACLE, WASHER	20	1	500		250	250	2	20	EXTERIOR POLE TOP LIGHTING	#10	8
9	#10	DRYER	30	2	2500	250							10
11					2500		2500		1	20	SPARE		12
13	#10	WATER HEATER 1	30	2	2500	2500			1	20	SPARE		14
15					2500		2500		1	20	SPARE		16
17	#10	WATER HEATER 2	30	2	2500	2500			1	20	SPARE		18
19					2500		2500		1	20	SPARE		20
21		PREPARED SPACE	-	1					1	-	PREPARED SPACE		22
23		PREPARED SPACE	-	1					1	-	PREPARED SPACE		24
25		PREPARED SPACE	-	1					1	-	PREPARED SPACE		26
27		PREPARED SPACE	-	1					1	-	PREPARED SPACE		28
29		PREPARED SPACE	-	1					1	-	PREPARED SPACE		30
31		PREPARED SPACE	-	1					1	-	PREPARED SPACE		32
33		PREPARED SPACE	-	1					1	-	PREPARED SPACE		34
35	350 KCM	FEEDER TO CAMPER SITES	200	2	24000				1	-	PREPARED SPACE		36
37					24000				1	-	PREPARED SPACE		38
39	350 KCM	FEEDER TO CAMPER SITES	200	2	24000			24000	2	200	FEEDER TO CAMPER SITES	350 KCM	40
41					24000			24000					42

SOLID NEUTRAL NEUTRAL WIRE (N) | TOTAL CONNECTED LOAD (VA) = 183,440 | AΦ = 91,660 | BΦ = 91,780 | GROUND BUS GROUND WIRE (G)

PANEL SCHEDULE

PANEL: PP4 | LOCATION: ELECTRICAL ROOM | FEEDER SOURCE: UTILITY | INTERRUPTING RATING = 24 KAIC | VOLTAGE: 240/120V, 400A, 1Φ, 3W WITH MAIN BREAKER | ENCLOSURE: SURFACE MOUNTED W/ EQUIPMENT GND BAR SQUARE-D, I-LINE PANELBOARD

CKT NO	THHN WIRE SIZE	LOAD DESCRIPTION / LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	AΦ	CΦ	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION / LOCATION	THHN WIRE SIZE	CKT NO
1	#12	RECEPTACLES, BATH ROOM	20	1	540	540		530	1	20	BATH ROOM 1, EXHAUST FANS AND LIGHTS	#12	2
3	#12	RECEPTACLE, WATER FOUNTAIN	20	1	1000		530	530	1	20	BATH ROOM 2, EXHAUST FANS AND LIGHTS	#12	4
5	#12	RECEPTACLES, BATH ROOM	20	1	540	300		300	1	20	LIGHTS, CORRIDOR AND PORCH	#12	6
7	#12	RECEPTACLE, WASHER	20	1	500		250	250	2	20	EXTERIOR POLE TOP LIGHTING	#10	8
9	#10	DRYER	30	2	2500	250							10
11					2500		2500		1	20	SPARE		12
13	#10	WATER HEATER 1	30	2	2500	2500			1	20	SPARE		14
15					2500		2500		1	20	SPARE		16
17	#10	WATER HEATER 2	30	2	2500	2500			1	-	PREPARED SPACE		18
19					2500		2500		1	-	PREPARED SPACE		20
21	#6	WATER WELL *	60	2	3300	3300			1	-	PREPARED SPACE		22
23					3300		3300		1	-	PREPARED SPACE		24
25		PREPARED SPACE	-	1					1	-	PREPARED SPACE		26
27		PREPARED SPACE	-	1					1	-	PREPARED SPACE		28
29		PREPARED SPACE	-	1					1	-	PREPARED SPACE		30
31		PREPARED SPACE	-	1					1	-	PREPARED SPACE		32
33		PREPARED SPACE	-	1					1	-	PREPARED SPACE		34
35	350 KCM	FEEDER TO CAMPER SITES	200	2	24000				1	-	PREPARED SPACE		36
37					24000				1	-	PREPARED SPACE		38
39	350 KCM	FEEDER TO CAMPER SITES	200	2	24000			14200	2	200	FEEDER TO CAMPER SITES	350 KCM	40
41					24000			14200					42

SOLID NEUTRAL NEUTRAL WIRE (N) | TOTAL CONNECTED LOAD (VA) = 180,440 | AΦ = 90,160 | BΦ = 90,280 | GROUND BUS GROUND WIRE (G)

* BEFORE ROUTING FEEDER, TO WATER WELL, VERIFY EQUIPMENT AND SIZE CIRCUIT ACCORDINGLY.

PANEL SCHEDULE

PANEL: PP5 | LOCATION: ELECTRICAL ROOM | FEEDER SOURCE: UTILITY | INTERRUPTING RATING = 24 KAIC | VOLTAGE: 240/120V, 400A, 1Φ, 3W WITH MAIN BREAKER | ENCLOSURE: SURFACE MOUNTED W/ EQUIPMENT GND BAR SQUARE-D, I-LINE PANELBOARD

CKT NO	THHN WIRE SIZE	LOAD DESCRIPTION / LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	AΦ	CΦ	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION / LOCATION	THHN WIRE SIZE	CKT NO
1	#12	RECEPTACLES, BATH ROOM	20	1	540	540		530	1	20	BATH ROOM 1, EXHAUST FANS AND LIGHTS	#12	2
3	#12	RECEPTACLE, WATER FOUNTAIN	20	1	1000		530	530	1	20	BATH ROOM 2, EXHAUST FANS AND LIGHTS	#12	4
5	#12	RECEPTACLES, BATH ROOM	20	1	540	300		300	1	20	LIGHTS, CORRIDOR AND PORCH	#12	6
7	#12	RECEPTACLE, WASHER	20	1	500		250	250	2	20	EXTERIOR POLE TOP LIGHTING	#10	8
9	#10	DRYER	30	2	2500	250							10
11					2500		2500		1	20	SPARE		12
13	#10	WATER HEATER 1	30	2	2500	2500			1	20	SPARE		14
15					2500		2500		1	20	SPARE		16
17	#10	WATER HEATER 2	30	2	2500	2500			1	-	PREPARED SPACE		18
19					2500		2500		1	-	PREPARED SPACE		20
21	#6	LIFT STATION 2 X 2 HP	50	2	3300	3300			1	-	PREPARED SPACE		22
23					3300		3300		1	-	PREPARED SPACE		24
25		PREPARED SPACE	-	1					1	-	PREPARED SPACE		26
27		PREPARED SPACE	-	1					1	-	PREPARED SPACE		28
29		PREPARED SPACE	-	1					1	-	PREPARED SPACE		30
31		PREPARED SPACE	-	1					1	-	PREPARED SPACE		32
33		PREPARED SPACE	-	1					1	-	PREPARED SPACE		34
35	350 KCM	FEEDER TO CAMPER SITES	200	2	24000				1	-	PREPARED SPACE		36
37					24000				1	-	PREPARED SPACE		38
39	350 KCM	FEEDER TO CAMPER SITES	200	2	24000			24000	2	200	FEEDER TO CAMPER SITES	350 KCM	40
41					24000			24000					42

SOLID NEUTRAL NEUTRAL WIRE (N) | TOTAL CONNECTED LOAD (VA) = 170,040 | AΦ = 84,960 | BΦ = 85,080 | GROUND BUS GROUND WIRE (G)

PANEL SCHEDULE

PANEL: PP6 | LOCATION: ELECTRICAL ROOM | FEEDER SOURCE: UTILITY | INTERRUPTING RATING = 24 KAIC | VOLTAGE: 240/120V, 400A, 1Φ, 3W WITH MAIN BREAKER | ENCLOSURE: SURFACE MOUNTED W/ EQUIPMENT GND BAR SQUARE-D, I-LINE PANELBOARD

CKT NO	THHN WIRE SIZE	LOAD DESCRIPTION / LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	AΦ	CΦ	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION / LOCATION	THHN WIRE SIZE	CKT NO
1	#12	RECEPTACLES, MAIN ROOM	20	1	1280	1280		600	1	20	LIGHTING, EQUIPMENT ROOM, BATHROOM, EXTERIOR	#12	2
3	#12	RECEPTACLES, OFFICE	20	1	1280		900	900	1	20	LIGHTING, EQUIPMENT ROOM, BATHROOM, EXTERIOR	#12	4
5	#12	RECEPTACLES, EQUIPMENT ROOM BATH ROOMS, COUNTER	20	1	1080	250							6
7	#12	RECEPTACLE, COUTER	20	1	180		250	250	2	20	EXTERIOR POLE TOP LIGHTING	#10	8
9	#12	RECEPTACLE, COOLER 1	20	1	1200	1200			1	20	SPARE		10
11	#12	RECEPTACLE, COOLER 2	20	1	1200		1200		1	20	SPARE		12
13	#12	RECEPTACLE, COOLER 3	20	1	1200	1200			1	20	SPARE		14
15	#12	RECEPTACLE, WATER FOUNTAIN	20	1	1000		1000		1	-	PREPARED SPACE		16
17	#12	SMALL APPLIANCE RECEPTACLE	20	1	1500	1500			1	-	PREPARED SPACE		18
19	#12	SMALL APPLIANCE RECEPTACLE	20	1	1500		1500		1	-	PREPARED SPACE		20
21	#10	WATER HEATER	30	1	2500	2500			1	-	PREPARED SPACE		22
23					2500		2500		1	-	PREPARED SPACE		24
25	#10	AHU	30	1	1800	1800			1	-	PREPARED SPACE		26
27					1800		1800		1	-	PREPARED SPACE		28
29	#12	GU	20	1	1000	1000			1	-	PREPARED SPACE		30
31					1000		1000		1	-	PREPARED SPACE		32
33		SPARE	20	1					1	-	PREPARED SPACE		34
35	350 KCM	FEEDER TO CAMPER SITES	200	2	24000				1	-	PREPARED SPACE		36
37					24000				1	-	PREPARED SPACE		38
39	350 KCM	FEEDER TO CAMPER SITES	200	2	24000			24000	2	200	FEEDER TO CAMPER SITES	350 KCM	40
41					24000			24000					42

SOLID NEUTRAL NEUTRAL WIRE (N) | TOTAL CONNECTED LOAD (VA) = 167,980 | AΦ = 84,340 | BΦ = 83,540 | GROUND BUS GROUND WIRE (G)

DAMMON ENGINEERING, INC.
LOUISIANA & MISSISSIPPI
www.dammonengineering.com
info@dammonengineering.com
PH: 985.649.5832
Chief Engineer: Brian Mistich, PE
554 Old Spanish Trail
Slidell, LA 70458

REVISIONS

#	DESCRIPTION	DATE

SEAL:

NEW RECREATIONAL R/V SITE
EXIT 1 R.V. LLC.
RESORT,

GLYDE MEITZER ROAD
NICHOLSON MS 39565PP 39466

JOB No:	2436
DRAWN BY:	DD/JTL
DATE:	09-26-2024
CHECKED BY:	BAM

The ideas and designs shown on this drawing are and shall remain the property of Dammon Engineering, and no part thereof shall be copied, disclosed to others or used in connection with any work or project other than the specific project for which the ideas have been prepared and developed without written consent of Dammon Engineering. Visual contact with these drawings shall constitute conclusive evidence of acceptance of these restrictions. © 2024 DAMMON ENGINEERING, INC.

SHEET TITLE:
ELECTRICAL PANEL SCHEDULES

DRAWING NUMBER:
E104

SHEET No: 19 of 19