



- PLAN NOTES: UNLESS NOTED OTHERWISE:**
- TOP OF SLAB EL. 45'-0".
 - EXISTING CONCRETE WAFFLE JOIST FLOOR SYSTEM (14"x3" CONCRETE SLAB+17" TOTAL THICKNESS).
 - (E) - INDICATES EXISTING CONSTRUCTION.
 - (N) - INDICATES NEW CONSTRUCTION.
 - INDICATES FLOOR SYSTEM TO CONSIST OF LIGHT WEIGHT CONCRETE (115PCF, Fc=4,000 PSI) ON 1/2" DEEP 20 GAGE GALVANIZED COMPOSITE METAL DECKING. TOTAL THICKNESS=4 1/2". REINFORCE CONCRETE SLAB WITH 6#-W4x14 W.W.F. LOCATED 1" BELOW TOP OF SLAB. TOP OF STEEL EL. 47'-0".
 - INDICATES NEW IN-FILL SLAB TO CONSIST OF 3" THICK CONCRETE SLAB THROUGHOUT (Fc=4,000PSI, NORMAL WEIGHT). TOP OF SLAB EL. TO MATCH EXISTING. COORD. WITH EXIST. FINISHES.
 - INDICATES NEW SLAB EXTENSION TO CONSIST OF 6" THICK CONCRETE SLAB THROUGHOUT (Fc=4,000PSI, NORMAL WEIGHT). TOP OF SLAB EL. TO MATCH EXISTING. COORD. WITH EXIST. FINISHES.
 - INDICATES FLOOR SYSTEM TO CONSIST OF LIGHT WEIGHT CONCRETE (115PCF, Fc=4,000 PSI) ON 1/2" DEEP 20 GAGE GALVANIZED COMPOSITE METAL DECKING. TOTAL THICKNESS=6". REINFORCE CONCRETE SLAB WITH 6#-W4x14 W.W.F. LOCATED 1" BELOW TOP OF SLAB. TOP OF STEEL EL. 47'-0".
 - INDICATES FLOOR SYSTEM TO CONSIST OF LIGHT WEIGHT CONCRETE (115PCF, Fc=4,000 PSI) ON 1/2" DEEP 20 GAGE GALVANIZED COMPOSITE METAL DECKING. TOTAL THICKNESS=6". REINFORCE CONCRETE SLAB WITH 6#-W4x14 W.W.F. LOCATED 1" BELOW TOP OF SLAB. TOP OF STEEL EL. 47'-0".
 - INDICATES NEW EPOXY TOPPING SLAB AT EXISTING DEPRESSIONS.
 - INDICATES ROOF SYSTEM TO CONSIST OF 1/2" DEEP TYPE "B" 20 GAGE GALVANIZED METAL ROOF DECKING. SEE ARCHITECTURAL DRAWINGS FOR INSULATION & ROOF ON TOP OF DECKING.
 - INDICATES DIRECTION OF SPAN OF STEEL DECKING.
 - W16x26(36) - INDICATES W16x26 BEAM WITH 36"x3/8"x3/8" AUTOMATIC END WELDED SHEAR CONNECTORS EQUALLY SPACED ALONG CENTERLINE OF BEAM. STUDS ARE TO BE FIELD INSTALLED.
 - INDICATES MOMENT CONNECTION. SEE SHEET S-1.
 - INDICATES MISC. OPEN'G. SEE S-1. COORD. SIZE & LOCATION W/ ARCH.
 - INDICATES X-BRACING. SEE 2/S2-7.
 - INDICATES K-BRACING. SEE 3/S2-7.

1 500 LEVEL FRAMING PLAN
1/8"=1'-0"

PRELIMINARY
NOT FOR CONSTRUCTION

No.	Date	Issue	No.	Date	Issue
1	12.23.10	SD PRICING SET			
2	01.18.11	100% SD SET			
3	05.18.11	LNO Meeting			
4	09.15.11	100% DD/ PRICING			

MORPHY CONSULTING ENGINEERS
336 N. Jeff Davis Pkwy.
New Orleans, LA 70119
TEL: (504) 488-1317
FAX: (504) 488-9294
WEB: www.mmi-eng.com
INCORPORATED JOB NO. 10128

HOLABIRD & ROOT | **HOLLY & SMITH LLC**
140 South Dearborn Avenue, Suite 500, Chicago, IL 60660
541 Julia Street, Suite 201, New Orleans, LA 70130
312.357.1771 (toll free), 312.357.1909 (fax)
504.585.1315 (toll free), 504.585.1316 (fax)
www.holabird.com | www.hollyandsmith.com

Project Number	15248.00
Drawn	RAB
Checked	JAS
Proj. Arch./Eng.	JAS

LOYOLA UNIVERSITY NEW ORLEANS
Monroe Hall
Renovation

500 LEVEL FRAMING PLAN
Sheet Name
Drawing No. S2-5