

DAMMON ENGINEERING, INC.

dammonengineering.com

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

554 Old Spanish Trail
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

August 24, 2011

To: Hunter Charbonnet
Casey Civil, LLC
1080 Old Spanish Trail, Ste.8
Slidell, LA 70458

REF: Owens & Minor Tenant Buildout, Opening Reinforcement Design
2700 Brittmore Rd.
Houston, TX 77043

Dear Mr. Charbonnet,

We have received the plans and details on the existing concrete wall panels. Based on the new available information:

1. Precast panels are +/- 20'-0" wide.
2. Reinforcement consists:
 - Vertical: #4 12" o.c. (each face)
 - Horizontal: #4 15" o.c. (each face)
3. Concrete compressive strength = 3,000 psi @ 28 days

Considering the substantial steel reinforcement and panel width, no steel lintel will be required. Once the opening has been cut, please verify that the reinforcing steel that is called out on the plans was *actually* installed in the precast panels.

Sincerely,

Emmett G. Dammon, P.E.
Dammon Engineering