

SYMBOL LIST

<p>+18" INDICATES MOUNTING HEIGHTS ARE TO CENTERLINE OF DEVICE ABOVE FINISH FLOOR OR FINISH GRADE</p> <p>AFF INDICATES ABOVE FINISHED FLOOR</p> <p>AL INDICATES ALUMINUM</p> <p>ATS INDICATES AUTOMATIC TRANSFER SWITCH</p> <p>C INDICATES CONDUIT WITH PULL-LINE ONLY</p> <p>AFCI INDICATES ARC FAULT CIRCUIT INTERRUPTER CIRCUITS PROTECTED WITH AFCI SHALL BE PROVIDED WITH DEDICATED NEUTRALS</p> <p>GFCI INDICATES GROUND FAULT CIRCUIT INTERRUPTER CIRCUITS PROTECTED WITH GFCI SHALL BE PROVIDED WITH DEDICATED NEUTRALS</p> <p>GFP INDICATES GROUND FAULT PROTECTION</p> <p>GRND INDICATES GROUND</p> <p>HOA INDICATES HAND-OFF-AUTO</p> <p>NC INDICATES NORMALLY CLOSED</p> <p>NO INDICATES NORMALLY OPEN</p> <p>NVE INDICATES NEVADA ENERGY</p> <p>PNL INDICATES PANEL</p> <p>S/N SOLID NEUTRAL</p> <p>UPS INDICATES UNINTERRUPTIBLE POWER SYSTEM</p> <p>WP INDICATES WEATHER-PROOF (NEMA 3R)</p> <p>XFMR INDICATES TRANSFORMER</p> <p>XP INDICATES EXPLOSION PROOF</p> <p>—F—F— FIBER OPTIC LIGHTING</p> <p>—N—N— NEON/COLD CATHODE LIGHTING</p> <p>—O—O— COVE/LOW VOLTAGE LIGHTING</p> <p>—LED— LED LIGHTING</p> <p> DECORATIVE LIGHT FIXTURE (OWNER FURNISHED AND CONTRACTOR INSTALLED)</p> <p> FLUORESCENT FIXTURE</p> <p> FLUORESCENT FIXTURE WITH (1) LAMP ON EMERGENCY</p> <p> FLUORESCENT FIXTURE ON EMERGENCY CIRCUIT OR INTEGRAL BATTERY BACK-UP</p> <p> LETTER INDICATES LIGHT FIXTURE TYPE AS INDICATED ON FIXTURE SCHEDULE</p> <p> FLUORESCENT FIXTURE</p> <p> FLUORESCENT FIXTURE</p> <p> FLUORESCENT FIXTURE</p> <p> FLUORESCENT FIXTURE</p> <p> DOWNLIGHT FIXTURE</p> <p> DOWNLIGHT FIXTURE ON EMERGENCY CIRCUIT OR INTEGRAL BATTERY BACK-UP</p> <p> EMERGENCY BATTERY LIGHTING UNIT WITH TWIN HEADS</p> <p> EMERGENCY BATTERY LIGHTING UNIT WITH TWIN HEADS AND EXIT SIGN</p> <p> STEP LIGHT</p> <p> WALL WASH/ACCENT LIGHT</p> <p> WALL MOUNTED FIXTURE</p> <p> POLE MOUNTED FIXTURE</p> <p> TRACK LIGHT WITH FIXTURE HEADS</p> <p> EXIT LIGHT WITH DIRECTIONAL ARROWS AS INDICATED CEILING MOUNTED</p>	<p> EXIT LIGHT WITH DIRECTIONAL ARROWS AS INDICATED WALL MOUNTED</p> <p> DOUBLE FACE EXIT LIGHT WITH DIRECTIONAL ARROWS AS INDICATED CEILING MOUNTED</p> <p>S SINGLE POLE SWITCH @ +48" UNLESS NOTED</p> <p>SS DUAL SWITCH @ +48" UNLESS NOTED</p> <p>S₃ 3-WAY POLE SWITCH @ +48" UNLESS NOTED</p> <p>S₄ 4-WAY POLE SWITCH @ +48" UNLESS NOTED</p> <p>S_P SWITCH WITH NEON PILOT LIGHT @ +48" UNLESS NOTED</p> <p>S_L BACKLIT SWITCH @ +48" UNLESS NOTED</p> <p>S_D DIMMER SWITCH - SOLID STATE TYPE @ +48" UNLESS NOTED</p> <p>S_{2P} 2 POLE SWITCH</p> <p>S_K SWITCH - KEY OPERATED</p> <p>S_M SWITCH WITH MOTION SENSOR</p> <p>S_{2M} DUAL SWITCH WITH MOTION SENSOR</p> <p> CEILING MOUNTED MOTION SENSOR</p> <p>S_T THERMAL OVERLOAD SWITCH</p> <p>S_{TM} SWITCH WITH DIGITAL TIMER</p> <p> SINGLE RECEPTACLE @ +18" UNLESS NOTED</p> <p> DUPLEX RECEPTACLE @ +18" UNLESS NOTED</p> <p> GFCI RECEPTACLE @ +48" UNLESS NOTED</p> <p> DOUBLE DUPLEX RECEPTACLE @ +18" UNLESS NOTED</p> <p> ISOLATED GROUND TYPE (ORANGE) DUPLEX RECEPTACLE @ +18" UNLESS NOTED</p> <p> SPECIAL RECEPTACLE @ +18" UNLESS NOTED</p> <p> 100 AMP PIN & SLEEVE RECEPTACLE</p> <p> CLOCK RECEPTACLE @ +90" UNLESS NOTED</p> <p> FLUSH FLOOR DUPLEX RECEPTACLE</p> <p> FLUSH FLOOR DOUBLE DUPLEX RECEPTACLE</p> <p> CEILING MOUNTED DUPLEX RECEPTACLE</p> <p> 1/2 SWITCHED (BOTTOM HALF) DUPLEX RECEPTACLE @ +18" UNLESS NOTED</p> <p> DOUBLE SWITCHED DUPLEX RECEPTACLE @ +18" UNLESS NOTED</p> <p> DOUBLE DUPLEX (HALF NORMAL/HALF ISOLATED GRND) @ +18" UNLESS NOTED</p> <p> AV RECEPTACLE</p> <p> RECEPTACLE FOR INSECT LIGHT TRAP INSTALL 2'-6" BELOW FINISHED CEILING</p> <p> RECEPTACLE INSTALLED ABOVE COUNTER</p> <p> FOOD CART RECEPTACLE</p> <p> RECEPTACLE INSTALLED HORIZONTALLY</p> <p> TIMECLOCK RECEPTACLE</p> <p> FLUSH FLOOR SPECIAL RECEPTACLE</p> <p> MULTI-OUTLET PLUGSTRIP</p> <p> FLOOR BOX</p> <p> VOLUME CONTROL</p> <p> OPERATIONS PANEL</p> <p> WALL BOX</p> <p> MICROPHONE OUTLET</p>	<p> JUNCTION BOX</p> <p> JUNCTION BOX AND SWITCH WITH CONNECTION TO FIRE/SMOKE DAMPER. COORDINATE REQUIREMENTS WITH FIRE ALARM SYSTEM AND MECHANICAL CONTROL DIAGRAMS</p> <p> JUNCTION BOX AND SWITCH WITH CONNECTION TO VARIABLE AIR VOLUME BOX. COORDINATE REQUIREMENTS WITH MECHANICAL CONTROL DIAGRAMS</p> <p> DOOR HARDWARE CONNECTION</p> <p> DOOR HOLD OPEN</p> <p> NON-FUSED DISCONNECT SWITCH - 30A, 3P, UNLESS NOTED OTHERWISE</p> <p> FUSED DISCONNECT SWITCH - 30A, 3P WITH 30A FUSES UNLESS NOTED OTHERWISE</p> <p> COMPANY SWITCH</p> <p> MAGNETIC MOTOR STARTER - FVNR, NEMA SIZE #1 (UNLESS NOTED OTHERWISE) WITH HOA, RED RUN PILOT LIGHT, CONTROL XFMR, SOLID STATE OVERLOADS, (2) NO AND (2) NC CONTACTS</p> <p> COMBINATION FUSED SWITCH & STARTER AS NOTED ABOVE</p> <p> COMBINATION NON-FUSED SWITCH & STARTER AS NOTED ABOVE</p> <p> RELAY</p> <p> CONTACTOR</p> <p> POWER SUPPLY</p> <p> TIMESWITCH</p> <p> PHOTOCCELL (INSTALL ON ROOF FACING NORTH)</p> <p> THERMOSTAT OUTLET @ +44" UNLESS NOTED</p> <p> PUSHBUTTON TYPE CONTROL STATION</p> <p> SPEAKER</p> <p> CIRCUIT BREAKER</p> <p> FOOD SERVICE EQUIPMENT - SEE FOOD SERVICE DRAWINGS</p> <p> SURFACE MOUNTED PANELBOARD</p> <p> FLUSH MOUNTED PANELBOARD</p> <p> MAIN SWITCHBOARD, MOTOR CONTROL CENTER OR DISTRIBUTION BOARD</p> <p> CONCRETE PULLBOX WITH HEAVY DUTY STEEL TRAFFIC COVER</p> <p> TRANSFORMER</p> <p> MOTOR OUTLET</p> <p> HOMERUN CONDUIT - STROKES INDICATE QUANTITY OF CONDUCTORS</p> <p> CONDUIT AND/OR WIRE CONCEALED IN WALL OR ABOVE CEILING EXCEPT IN EXPOSED STRUCTURE AREAS</p> <p> CONDUIT AND/OR WIRE BELOW FLOOR OR GRADE</p> <p> EXISTING CONDUIT AND/OR WIRE TO BE REMOVED</p> <p> EXISTING CONDUIT AND/OR WIRE TO REMAIN (SHOWN LIGHT LINEWEIGHT)</p> <p> CONDUIT STUB-OUT</p> <p> CONDUIT AND/OR WIRE RISER UP/RISER DOWN</p> <p> CIRCUITING - STROKE WITH DOT INDICATES ISOLATED GROUND CONDUCTOR</p> <p>1/2"-2 #12 & 1 #12 GRND THWN UNLESS NOTED</p> <p>1/2"-3 #12 & 1 #12 GRND THWN UNLESS NOTED</p>	<p> PRIMARY MEDIUM VOLTAGE SWITCH EXTERIOR PAD MOUNT</p> <p> CIRCUIT BREAKER</p> <p> SHUNT TRIP CIRCUIT BREAKER</p> <p> DRAW-OUT CIRCUIT BREAKER - MEDIUM VOLTAGE</p> <p> DRAW-OUT CIRCUIT BREAKER - 600 VOLT</p> <p> FUSIBLE SWITCH</p> <p> BOLTED PRESSURE SWITCH WITH GROUND FAULT PROTECTION</p> <p> KIRK-KEY SWITCH</p> <p> GENERATOR</p> <p> GROUNDING ELECTRODE</p> <p> SINGLE METER WITH CT</p> <p> AUTOMATIC TRANSFER SWITCH</p> <p> SHUNT TRIP DEVICE LOCATED IN METAL ENCLOSURE WITH HINGED AND LOCKABLE COVER</p> <p> FEEDER - SIZE AS INDICATED ON FEEDER SCHEDULE</p> <p> DIVISION 15 EQUIPMENT - SEE HVAC AND PLUMBING DRAWINGS</p> <p> CAPACITOR</p> <p> METER</p> <p> TRANSIENT VOLTAGE SURGE SUPPRESSOR</p> <p> ELEVATOR/ESCALATOR CONTROLLER</p> <p> GROUND BUS & GROUND ELECTRODES</p> <p> GROUND GRID</p> <p> FUSIBLE MEDIUM VOLTAGE SWITCH</p> <p> MEDIUM VOLTAGE MODULAR CONNECTORS</p>
---	--	--	--

THE SAENGER THEATRE RENEWAL PROJECT

142 North Rampart Street
New Orleans, LA

Client
Saenger Theatre Redevelopment Company
200 West Loop South, Suite
1040 Houston TX 77027

Architect
MARTINEZ+JOHNSON
ARCHITECTURE

1412 Eye St., NW
Washington, DC 20005
202.333.4480

Structural Engineer
Shawn J. Franke, P.E.
549 Heiner Road, San
Antonio TX 78232
210.979.7900

Theatre Consultant
Schuler Shook
123 Third Street North #210
Minneapolis, MN 55401
612.333.5659

Acoustical Engineer
Akustiks
93 North Main Street South
Norwalk, CT 06584
202.299.1904

MEP Engineer
JBA Consulting Engineers, Inc.
3525 N. Causeway Blvd. Suite
500 Metairie, LA 70002
504.830.0139

Civil Engineer
Linfield, Hunter, & Junius, Inc.
3608 18th Street Suite 200
Metairie, LA 70002
504.833.5359

Architectural Historian
EHT Traceries, Inc.
1121 Fifth Street NW
Washington, DC 20001
202.393.1199

THESE DRAWINGS, SPECIFICATIONS, AND OTHER DOCUMENTS, COLLECTIVELY, THE "DOCUMENTS" INCLUDING WITHOUT LIMITATION ELECTRONIC VERSIONS THEREOF AND THE IDEAS, DESIGNS, AND ARRANGEMENTS REPRESENTED THEREBY, ARE AND SHALL REMAIN THE PROPERTY OF MARTINEZ & JOHNSON ARCHITECTURE PC. AS PART OF ANY CONTRACTUAL AGREEMENTS ("THE AGREEMENTS") AND AS PROTECTED BY THE COPYRIGHT STATUTES OF THE UNITED STATES, USE OF THE DOCUMENTS SHALL BE STRICTLY LIMITED TO THE PROJECT FOR WHICH THEY WERE PREPARED AND DEVELOPED ("THE PROJECT") FOR THE TERM OF THE AGREEMENTS. NO PART OF THE DOCUMENTS SHALL BE COPIED, DISCLOSED TO OTHERS, OR USED IN CONNECTION WITH ANY OTHER WORK OR PROJECT, OR BY ANY OTHER PERSONS FOR ANY PURPOSES, OTHER THAN THE COMPLETION OF THE PROJECT, WITHOUT THE SPECIFIC WRITTEN AUTHORIZATION OF MARTINEZ & JOHNSON ARCHITECTURE PC. THE DRAWING, COPYING, OR VIEWING OF ELECTRONIC VERSIONS OF THE DOCUMENTS OR VISUAL CONTACT WITH ANY PRINTED FORM THEREOF SHALL CONSTITUTE CONCLUSIVE EVIDENCE OF ACCEPTANCE OF THESE RESTRICTIONS.

7502

DATE:	No.:	ISSUE:
02.19.10	1	PERMIT SET
04.02.10	2	GMP CONTRACT SET

DATE:	No.:	REVISION:
11.11.10		CONTRACT SET

SHEET TITLE:
SYMBOL LIST

E0.01

09.0394