



DAMMON
ENGINEERING, INC.

554 Old Spanish Trail
Slidell, LA 70458
Phone: 985-649-5832

dammonengineering.com
info@dammonengineering.com

June 23, 2025

Kenny Wortmann, Director
St. Tammany Parish Department of Permits
21490 Koop Drive
Mandeville, Louisiana 70471

Re: Permit #2024-2265
Mike Divinvinti
55 N. Treasure Isles Dr.
Slidell, La. 70461

Dear Mr. Wortmann

Per our site visit at the above address. The breakaway walls are modified to meet the FEMA breakaway requirement. Some studs were removed to meet the stud spacing. Some utility pipes were rerouted off the breakaway walls. Where a utility lines passes through the breakaway wall it is blocked out per FEMA design. Also, flood vents are installed per FEMA design.

Sincerely,

Brian A Mistich, P.E.
La. License No. 0030187