

**DAMMON**  
**ENGINEERING, INC.**  
*Architects & Engineers*  
**Engineer's Field Report**

554 Old Spanish Trail  
Slidell, LA 70458  
985.649.5832  
www.dammonengineering.com  
info@dammonengineering.com

Owner   
Engineer   
Consultant   
Contractor

---

PROJECT: HVAC System Replacement  
State Police Troop L Headquarters  
Mandeville, Louisiana

FIELD REPORT NUMBER: 015

FP&C PROJECT NUMBER: 01-107-06B-11

---

DATE: 6/7/2022      TIME: 9:30 Am      WEATHER : Sun      TEMP : 85°

1 Year Warranty Inspection

Attendees: Lt Russell Mayfield, State Police Troop L  
David Dammon, Dammon Engineering  
Bill Winsor, Dammon Engineering

---

**OBSERVATIONS:**

---

1. A review of the primary project was discussed and no issues with this project were noted.
  2. The site was having some issues with the chiller; however, the chiller was not part of this contract.
  3. They are having difficulties when changing the air filters on the air handler and would like to have another access door installed. This would not be covered under warranty. Dammon Engineering will contact the contractor to get a cost to add another access door on the opposite side of air handling unit.
- 

---

REPORT BY: David Dammon

---