FM Program | Home | Building Info

Homogeneous Area Information

State ID	00814	**Date of Inspection**	12/8/1992
Building Name	TROOP L HEADQUARTERS		Positive
Accredited Building Inspector	JOSEPH RID		
LADEQ Accreditation No.	3I0438		
Imminent Hazard Samples	1		
Total Samples Collected	1		

Sample Location Information

Sample No.	H.A. No.	Floor No.	Room No.	Location within Room
003	3	1	119	NORTH AREA

Sample Laboratory Results

Sample No.	H.A. No.	Result	ASBESTOS					Non-ASBESTOS			
			Chry.	Amos.	Croc.	Other	Total	Synth.	F/G	Cell	Non-Fib
003	3	POSITIVE	5%	ND	ND	Other	5%	ND	5%	20%	