



*Remote Alarm  
Possible wireless  
Double pumps*

NOTES:  
 - Design flow into wet well is approximated as 120 gpm based on three pumps operating simultaneously at 40 gpm each.  
 - Design flow out of wet well is approximated as 500 gpm based on T-4 performance curves.

REFERENCES:  
 - ARO Diaphragm Pumps Data Sheet, Pages 32-33  
 - Super T Series Data Sheet, Page 2

<b>TANGIPAHOA PARISH REGIONAL SOLID WASTE FACILITY INDEPENDENCE, LOUISIANA</b>	
for <b>TANGIPAHOA PARISH GOVERNMENT AMITE, LOUISIANA</b>	
 <b>Fourier &amp; de Abreu Engineers, L.L.C.</b> Environmental and Civil Engineering	
3084 WESTFORK DR. SUITE A BATON ROUGE, LA 70816	PHONE: 225-677-7950 contact@fdaengineers.com www.fdaengineers.com
<b>CONCEPTUAL WET WELL PLAN (CELL 13)</b>	
Project Engineer:	Project No.:   Date: