



- GENERAL NOTES THIS SHEET:**
- ALL RACEWAYS SHALL BE 1/2" C AND SHALL CONTAIN 2-#12 AWG AND 1-#12 INSULATED GRD. UNLESS NOTED OTHERWISE. HATCH LINES DO NOT INDICATE A GROUND WIRE.
 - COORDINATE EXACT LOCATION OF ALL LIGHTING FIXTURES WITH ARCHITECTURAL DRAWINGS PRIOR TO INSTALLATION.
 - CONNECT UNSWITCHED HOT LEGS TO ALL EXIT SIGNS, EMERGENCY BALLASTS AND NIGHT LIGHTS.
- SPECIFIC NOTES THIS SHEET:**
- 6" FIREWATER LINE.
 - 3" COLD WATER LINE.
 - 4" WASTE LINE.
 - SEE SHEET M101 FOR CONTINUATION.
 - 4" CHILLED WATER SUPPLY AND RETURN CONTINUED ON SHEET M201.
 - 1" C.W. LINE CONTINUED ON SHEET M101.
 - SEE CIVIL DRAWINGS FOR CONTINUATION.
 - UNDERGROUND SERVICE ENTRANCE. SEE FEEDER DIAGRAM SHEET E401.
 - APPROXIMATE LOCATION OF EXISTING POWER POLE. FIELD VERIFY.
 - APPROXIMATE LOCATION OF EXISTING JUNCTION BOXES TO CATV, DATA, AND TELEPHONE CONDUITS.
 - ROUTE 6" C WITH 2-2" INNER DUCT AND FULL WIRE FROM EXISTING JUNCTION BOX UP THROUGH STORAGE ROOM 101A AND CONTINUE TO ROOM 203T FOR INCOMING TELEPHONE SERVICE.
 - ROUTE 6" C WITH 2-2" INNER DUCT AND FULL WIRE FROM EXISTING JUNCTION BOX UP THROUGH STORAGE ROOM 101A AND CONTINUE TO ROOM 203T FOR INCOMING DATA SERVICE.
 - ROUTE 2" C WITH FULL WIRE FROM EXISTING JUNCTION BOX UP THROUGH STORAGE ROOM 101A AND CONTINUE TO ROOM 203T FOR INCOMING CATV SERVICE.
 - 3/4" C WITH 2-#6 AND 1-#8 GRD.
 - 2.5" C, 4-#4/O AWG AND 1-#2 GRD.
 - OUTDOOR RECEPTACLE.
 - MONUMENTAL SIGN.
 - 14" ROUND SONOTUBE AT 24" IN DEPTH PROVIDE 1/2" NPT FEMALE PIPE STUB FOR FIXTURE MOUNTING. PIPE SHALL BE MOUNTED 12" INTO CONCRETE LIGHT PAD. PIPE SHALL EXTEND 3" ABOVE TOP OF PAD.
 - SEE SHEET E101 NOTE 3.

**LUCIEN T. VIVIEN JR.
AND ASSOCIATES, INC.
CONSULTING ENGINEERS**
1321 HICKORY AVENUE - SUITE 100
HARRAHAN, LOUISIANA 70123
T (504) 218-5409 F (504) 218-5412
www.vivienengineers.com

PROJECT DESIGN GROUP, LLC
300 LAFAYETTE STREET, SUITE 200
NEW ORLEANS, LOUISIANA 70130
(504) 523-6472 FAX (504) 529-1181

REK ARCHITECTS, LLC
21489 KOOP DRIVE, SUITE 5
MANDEVILLE, LOUISIANA 70471
(985) 875-7534 FAX (985) 875-7837

revisions		
no.	revision	date
1	ADDENDUM #2	11-13-09
2		
3		
4		
5		

**SLIDELL MUNICIPAL CENTER
BUILDING 2**
SLIDELL, LA

SITE PLAN - MECHANICAL AND ELECTRICAL

no.	revision	date
1	ADDENDUM #2	11-13-09
2		
3		
4		
5		

file name	drawing number
ME101.dwg	ME101
project number	51093.02
date	9-05-09
phase	100% FIRE MARSHAL

1 **SITE PLAN - MECHANICAL AND ELECTRICAL**
ME101 1"=20'-0"
NORTH

Lucien Eugene Vivien
Professional Engineer
License No. 7955
State of Louisiana
SEPTEMBER 5, 2009

THE INFORMATION CONTAINED IN THIS DOCUMENT IS PROPRIETARY TO LUCIEN T. VIVIEN, JR., & ASSOC., INC. THE DOCUMENT MAY NOT BE DISCLOSED, DUPLICATED, OR USED FOR ANY PURPOSE, IN WHOLE OR IN PART, WITHOUT THE PRIOR WRITTEN CONSENT OF LUCIEN T. VIVIEN, JR., & ASSOC., INC.