

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

H "BUTCH" BROWNING
FIRE MARSHAL

AMENDED LETTER

EDWARD GREMILLION, P E, C E
DAMMON ENGINEERING, INC
1095 FLORIDA AVE
SLIDELL, LA 70458-0000

RE: P0320959
ST TAMMANY PARISH SLIDELL
ADMINISTRATIVE COMPLEX
520 OLD SPANISH TRAIL
SLIDELL, LA 70458-0000

NFPA 101, 2009

BUSINESS

Dear Applicant:

This is to advise that the previous review letter dated 02/13/2007 for this project is hereby amended as follows:

1. **Our review of drawings and/or specifications for the subject project dated February 13, 2007 is amended as follows:**

NOTE: THE FOLLOWING COMMENTS IDENTIFY ISSUES FOR INFORMATIONAL AND CAUTIONARY PURPOSES OR ISSUES THAT COULD NOT BE VERIFIED IN THE SUBMITTED DOCUMENTS.

2. **There is a discrepancy between Sheets A-1 and S-1 regarding location of two hour fire walls. This office recognizes the location for the two hour construction as indicated on sheet A-1. DISREGARD THE TWO HOUR RATED CONSTRUCTION AND PENETRATIONS AROUND THE TOILETS AND EXTENDING TO VESTIBULE 118 AS INDICATED ON SHEET S-1. A TWO HOUR RATED CORRIDOR IS NOT REQUIRED AT THIS LOCATION.**
3. **The following sheets were not previously submitted for Restamp in the previous package (RESTAMP DONE ON JAN. 13, 2009) : C-7, D-6, P-1 THRU P-9. INCLUDE THESE SHEETS IN THE RESTAMP SUBMITTAL.**
4. **NOTE: The rest of the original review letter for this project shall remain applicable. Please enclose a copy of this letter with future submittals or other correspondence pertaining to this project.**

This review applies to the work indicated on the drawings or specifications.

This review shall in no way permit or authorize any omissions or deviations from the specific requirements of the adopted codes, rules and regulations in accordance with R.S. 40:1574.1(B).

The above amended review is valid if construction starts within 180 days from the above date of the original review letter.

Occupancy of the project will not be permitted until we receive the completed certificate and a satisfactory inspection of the completed construction has been made by this office.

To arrange for inspection of the project, please contact the District Office at the phone number below, two (2) to three (3) weeks in advance. Approved plans must be available on job site at time of inspection. Certificate of completion must be provided to inspecting Deputy for final inspection.

REVIEWED BY:
DAVID JONES
ARCHITECT

CC:
St Tammany Parish Government
St Tammany Fire Protection District No 1*
City Of Slidell*
New Orleans District* 5044557313