

The following items need to be addressed:

1. Note: Sheet 2 shows the quantity for the director to be (1). There are two directories required for each floor. They need to be shown on the schedule.
2. Room 201 in addition to the signage designating it a Mechanical Room it also needs a sign on each door that reads - NO EXIT - .
3. Men and Women toilet signs not needed on any floor. This is due to getting the color system approved to match these signs which are presently in place.
4. There should be a narrative describing the sign that spells out what the materials are use. They need to match the signs we have installed, thus should be plastic and the same colors.
5. Note: Sheet 2, under TYPE B it shows a question mark in each under text. Those on corridor should have the numbers provided and I would assume the ones for all adjoining rooms would have the corresponding number and the Owner would provide the name of the person or department.
6. On Damon's signage schedule it shows room 208 as not to have a number, however on the supplementary numbering is shows it to be 2A. This needs to be clarified.
7. Provide signage at the entrance of each floor from the stairs. Follow the example previously provided. Two needed for each floor

Questions for Chuck:

1. DA bathroom has a handicap sign, does it need to say restroom? *YES*
2. Drug court has a handicap sign, does it need to say restroom? *YES*
3. Rooms 315 and 318 are rooms, you show signage to be provided. Do you want sign for a corridor? *TWO INSERTS FOR 315, TWO INSERTS FOR 318*
4. Was the signage for the Kitchen intended to be an insert, RM 606? *INSERT*
5. Room 210 is an interior closet does it need an identification? *INSERT*
6. Note 2B and 2C missing from corridor markup.
7. Room 208 is shown as N/A yet on the supplementary information Dammon showed it as 2A. *NO SIGN*

2) NEEDS INSERT SIGN

