LOWER GAINESVILLE RD.

6" FIRE HYDRANT, SEE DETAIL SHT. C6.5 LOCATED 5' OFF ROAD

8" FIRE WATER LINE

6" STUB UP FOR SPRINKLER, SEE DETAIL SHT. C6.5

6" POST INDICATOR VALVE WITH CHAIN AND LOCK, SEE DETAIL SHT. C6.5

BOAT STORAGE BLDG. 2442

FIRE DEPARTMENT CONNECTION, SEE DETAIL SHT. C6.5

1" WATER LINE

FOR PIPE INTERSECTION DETAIL SEE SHT C6.1

LIFT STATION SEE SHEET C6.5 FOR DETAILS

SEWER TIE-IN INVERT 11.80'

FIRE DEPARTMENT CONNECTION, SEE DETAIL SHT. C6.5

C.L. ELEV. OF SEWER LINE=8.5' IN THIS LOCATION TO ALLOW REQD. COVER UNDER DRAINAGE SWALE

8" WATER LINE

1 1/2" FORCE MAIN SCH. 40 PVC

8" FIRE WATER LINE

MAINTENANCE BLDG. 2441

OPERATIONS BLDG. 2440

FIRE DEPARTMENT CONNECTION, SEE DETAIL SHT. C6.5

8" STUB UP FOR SPRINKLER, SEE DETAIL SHT. C6.5

EXIST. 6" WATER

MATCHLINE SEE SHT C6.3

MATCHLINE SEE SHT C6.3

MATCHLINE SEE SHT C6.3

LEGEND

SYMBOL	DESCRIPTION
—S—S—S—	SANITARY SEWER
—PW—PW—	COLD WATER (POTABLE)
— — — —	EXISTING SEWER
—F—F—F—	FIRE PROTECTION

PLAN NORTH

UTILITY PLAN PART 1

SCALE: 1"=30'-0"

30' 20' 0 30' 60' 90'

ROBERT LEE WILTSE REG. NO. 27739 STATE OF LOUISIANA REGISTERED ARCHITECT

MATCHLINE SEE SHT C6.4

STM	DESCRIPTION	DATE	APPR

NAVFAC

DAMMON ENGINEERING, INC.
CHIEF ENGINEER EMMETT DAMMON, P.E. | CHIEF ARCHITECT ROBERT WILTSE
1095 FLORIDA AVENUE
SLIDELL, LA 70458
(985) 649-5832
SEPTEMBER 4, 2009

EMMETT G. DAMMON LICENSED PROFESSIONAL ENGINEER 9652 STATE OF MISSISSIPPI

DES: C. DAMMON | DRW: J. TIFFANY
REVIEWED BY: R. WILTSE
PM/DM: T. ARTRIP
CHIEF ENG/ARCH. P. DAMMON

DEPARTMENT OF THE NAVY
NAVAL FACILITIES ENGINEERING COMMAND SOUTHEAST
NAVAL FACILITIES ENGINEERING COMMAND
NAVAL AIR STATION JACKSONVILLE
JOHN C. STENNIS SPACE CENTER MISSISSIPPI
IPT GULF COAST

SOF RIVERINE AND COMBATANT CRAFT OPERATIONS FACILITY - PRE-FINAL

UTILITY PLAN PART 1

CODE ID. NO. N4412	SIZE D
SCALE:	AS SHOWN
MAXIMO NO.	######
STA. PROJ. NO.	P-210
WORK ORDER NO.	510247
CONSTR. CONTR. NO.	N62467-05-D-0096
NAVFAC DRAWING NO.	15026673
SHEET	26 OF 132

C6.2

DRAWFORM REVISION: 01 JAN 2009

REVDATE: