

Permit		Permittee: DEPT OF PUBLIC SAFETY		Facility: DEPT OF PUBLIC SAFETY - STATE POLICE TROOP L	
Permit #: LAG481115	Major: No	Permittee Address: 2600 N CAUSEWAY BLVD MANDEVILLE, LA 70471	Facility Location: 2600 N CAUSEWAY BLVD MANDEVILLE, LA 70471		
Permitted Feature: 001 External Outfall	Discharge: 001-S Outfall 001				

Report Dates & Status
Monitoring Period: From 01/01/22 to 06/30/22 | **DMR Due Date:** 07/28/22 | **Status:** NetDMR Validated

Considerations for Form Completion
 TSS limit for oxidation ponds shall be 90 mg/L Monthly Average and 135 mg/L Daily Maximum Fecal Coliform limit for oyster propagation area shall be 14 #/100ml Monthly Average and 43 #/100ml Daily Maximum

Principal Executive Officer
First Name: | **Title:** | **Telephone:**
Last Name:

No Data Indicator (NODI)
 Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Ty			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00400	pH	1 - Effluent Gross	0	--							=	7.8			=	7.8	12 - SU	0	01/6M - Once Every 6 Months	GR - GRAE
											>=	6.0 INST MIN			<=	9.0 INST MAX	12 - SU	0	01/6M - Once Every 6 Months	GR - GRAE
00530	Solids, total suspended	1 - Effluent Gross	0	--								=	21.0		=	21.0	19 - mg/L	0	01/6M - Once Every 6 Months	GR - GRAE
												<=	30.0 MO AVG		<=	45.0 DAILY MX	19 - mg/L	0	01/6M - Once Every 6 Months	GR - GRAE
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--									=	62.2		19 - mg/L	0	01/6M - Once Every 6 Months	GR - GRAE	
														Req Mon DAILY MX	19 - mg/L	0	01/6M - Once Every 6 Months	GR - GRAE		
X 00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--								=	60.6		=	60.6	19 - mg/L	1	01/6M - Once Every 6 Months	GR - GRAE
												<=	5.0 MO AVG		<=	10.0 DAILY MX	19 - mg/L	1	01/6M - Once Every 6 Months	GR - GRAE
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--									=	8.36		19 - mg/L	0	01/6M - Once Every 6 Months	GR - GRAE	
														Req Mon DAILY MX	19 - mg/L	0	01/6M - Once Every 6 Months	GR - GRAE		
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--		=	200.0	=	200.0	07 - gal/d								0	01/6M - Once Every 6 Months	ES - ESTII
							Req Mon MO AVG		Req Mon DAILY MX	07 - gal/d								0	01/6M - Once Every 6 Months	ES - ESTII
X 74055	Coliform, fecal general	1 - Effluent Gross	0	--								>	2419.6		>	2419.6	13 - #/100mL	1	01/6M - Once Every 6 Months	GR - GRAE
												<=	200.0 MOAV GEO		<=	400.0 DAILY MX	13 - #/100mL	1	01/6M - Once Every 6 Months	GR - GRAE
X 80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--								=	40.0		=	40.0	19 - mg/L	1	01/6M - Once Every 6 Months	GR - GRAE
												<=	10.0 MO AVG		<=	15.0 DAILY MX	19 - mg/L	1	01/6M - Once Every 6 Months	GR - GRAE

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
74055	Coliform, fecal general	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
74055	Coliform, fecal general	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments
 Please see attached non-compliance form.

Attachments

Name	Type	Size
TroopLOutfall0011B2022.pdf	pdf	160894.0

User: JDU PONT1980
Name: Jennifer Dupont
E-Mail: jdupont@eeusa.com
Date/Time: 2022-07-13 14:16 (Time Zone: -05:00)

Report Last Signed By

User: LSP_TROOPL
Name: Louis Calato
E-Mail: louis.calato@la.gov
Date/Time: 2022-07-13 15:19 (Time Zone: -05:00)

Submission Receipt

Submission Date: 07-13-2022

Submitter Name: Louis Calato

Submitter Telephone: (985) 893-6250

Attachment 1



Non-Compliance Report Form

Facility Name: Department of Public Safety State Police Troop L

Facility Address: (Semi-Annual) 2600 N. Causeway Blvd., Mandeville, LA 70471

Person Reporting: Lt. Louis Calato **Title:** Lieutenant

Phone Number: 985-893-6239 **Parish:** St. Tammany

LPDES Number: LAG481115 **AI#:** 22734

Receiving Waters: From Bayou Tete L' Ours via local Drainage in (subsegment 040808) of the Lake Pontchartrain Basin.

(Refer to Subject Line on Permit Cover Letter)

Date of Non-Compliance	Parameter/Description (e.g. TSS, Overflow)	Outfall No./Location (e.g. 001, 123 Main St.)	Permit Limit	Reported Value
05-26-22	CBOD ₅	Outfall 001	10	40
05-26-22	Fecal Coliform	Outfall 001	200	>2,419.6
05-26-22	Ammonia Nitrogen	Outfall 001	5	60.6

Cause of Violation(s): The aeration pump was not working.

Corrective Action/Preventative Measures/Remediation: The pump was not working due to an electric breaker being flipped. The breaker was reset and the pump is now working.

Please submit as a PDF attachment in NetDMR or mail non-compliance reports to the following address:

**Office of Environmental Compliance
Attn: Permit Compliance Unit
P.O. Box 4312
Baton Rouge, LA 70821-4312**