

**ARC MECHANICAL
CONTRACTORS, INC.**
P.O. Box 6720
SLIDELL, LOUISIANA 70469
Phone 661-9191

LETTER OF TRANSMITTAL

DATE	1/25/2011	JOB NO.	ARC 10-21
ATTENTION			
Mr. Chuck Dammon			
RE:	Pharmacy Upgrades @ SMH		

TO Dammon Engineering
1095 Florida Avenue
Slidell, Louisiana 70458

WE ARE SENDING YOU Attached Under separate cover via _____ the following items:

Shop drawings Prints Plans Samples Specifications

Copy of letter Change order _____

COPIES	DATE	NO.	DESCRIPTION
1	01/14/11		Test And Balance Report

THESE ARE TRANSMITTED as checked below:

- For approval Approved as submitted Resubmit _____ copies for approval
- For your use Approved as noted Submit _____ copies for distribution
- As requested Returned for corrections Return _____ corrected prints
- For review and comment _____
- FOR BIDS DUE _____ 20 _____ PRINTS RETURNED AFTER LOAN TO US

REMARKS _____

COPY TO _____

SIGNED: *T. King*

If enclosures are not as noted, kindly notify us at once.



COASTAL AIR BALANCE, CORP.

4604 Jefferson Highway Jefferson, LA 70121 Phone (504) 834-4537 Fax (504) 834-2361

TEST AND BALANCE ANALYSIS REPORT

Job Name: SLIDELL MEMORIAL HOSPITAL-PHARMACY UPGRADES - SLIDELL, LA

Contractor: ARC MECHANICAL CONTRACTORS, INC.

Architect: - Engineer: DAMON ENGINEERING

CERTIFICATION:

AIR DISTRIBUTION SYSTEM HAS BEEN COMPLETELY BALANCED AS PER REQUIREMENTS OF SPECIFICATIONS AND RESULTS OF TEST HEREIN LISTED.

BY: COASTAL AIR BALANCE, CORP.

DATE: JANUARY 14, 2011

Approved: ROY A. ST. PAUL

TABLE OF CONTENTS

SUMMARY

AIR MOVING EQUIPMENT TEST SHEET

DUCT TRAVERSE ZONE TOTALS TEST SHEET

DIFFUSER & GRILLE TEST SHEET

EXHAUST FAN TEST SHEET



COASTAL AIR BALANCE, CORP.

4604 JEFFERSON HIGHWAY • JEFFERSON, LOUISIANA 70121 • TELEPHONE (504) 834-4537 • FAX (504) 834-2361

SLIDELL MEMORIAL HOSPITAL PHARMACY
SLIDELL, LA.
SUMMARY

The airflows for DX-1 were balanced to meet the pressurization requirements for new Pharmacy area.



Professional Engineers: Test Adjust, Balance, Commissioning and IAQ
SERVING THE GULF SOUTH FOR OVER 30 YEARS

