

**STATE OF LOUISIANA**  
Department of Public Safety and Corrections  
Office of State Fire Marshal Code Enforcement and Building Safety  
8181 Independence Boulevard  
Baton Rouge, Louisiana 70806  
225-925-4920

H "BUTCH" BROWNING  
FIRE MARSHAL

**NEW CONSTRUCTION**

JOSEPH SCHNEIDER  
105 EVANGELINE DR  
SLIDELL, LA 70460-7046

RE: P0359020  
NEW DENTAL OFFICE  
SECTION 36- SW 114 - SW 114  
SLIDELL, LA 70469

NFPA 101, 2006

BUSINESS

Dear Applicant:

This is to advise that we have reviewed the drawings and specifications for the subject proposed construction and have determined that they appear to satisfactorily comply with the adopted laws, codes, rules and regulations of The State Fire Marshal subject to the following requirements:

1. **RS 40:1574 "DEADLINE IMPOSED" - The Professional of Record, if applicable, otherwise the owner, shall furnish documentation addressing item(s) number 4, 17, 18, 19, AND 21 of this letter to this office within 21 days of the date on this letter, or this review may be rescinded and found "Not In Compliance". Construction shall NOT be authorized for all areas which may be affected by the item(s) listed in this paragraph. The state inspector shall verify that written documentation has been received and acknowledged by the Plan Review Section of this office prior to allowing occupancy.**
2. **This work entails the construction of a new wood framed, single story, building and the associated site development.**
3. **LRS 40:1730.45 and LAC 55:V:2601 The documentation provided for the subject facility appears to comply with The Commercial Building Energy Conservation Code based on ANSI/ASHRAE/IESNA 90.1- 2004, or the International Energy Conservation Code, 2006 edition, as applicable.**
4. **101:6.1.5 This review applies to a business occupancy classification. If four or more patients are treated at the same time making them incapable of self-preservation without assistance from others during times of emergency, then the project shall be resubmitted for review as an ambulatory health care occupancy. (See NFPA 101:18.1.3 for definition).**

**PROVIDE DOCUMENTATION FROM THE OWNER, THAT NO MORE THAN 3 PERSONS WILL BE UNDER THE EFFECTS OF ANESTHESIA , INCLUDING BUT NOT LIMITED TO NITROUS OXIDE, AT ANY MOMENT IN TIME THAT THE BUILDING IS IN OPERATION, OR RESUBMIT THE BUILDING OR REVIEW AS AN AMBULATORY CARE OCCUPANCY.**