

**Jefferson Parish
Inspection and Code Enforcement**

**West Bank
400 Maple Ave.
Harvey, LA 70058
(504) 364-3512**

Plumbing Section

**East Bank
1221 Elmwood Park Blvd.
Suite 101 Jefferson, LA 70123
(504) 736-6957**

Friday, August 2, 2019

Jefferson Community Health Care

3932 US HWY 90
AVONDALE LA 70094

Re: Permit Application # 19-396974 JEFFERSON COMMUNITY HEALTH

3932 HWY 90 W, WAGGAMAN, LA 70094
Commercial Remodeling/Renovations

The application listed above cannot be approved until the following requirements are met:

Plumbing Department

8/2/2019 Isometric drawing required showing Potable water system to all fixtures including dental chairs with required reduced pressure back flow device. Separate reduce pressure back flow device is required for water lines to dental chair's. If dental chair's have built in reduce pressure back flow device's specification reflecting this will be required. Revise drawing to reflect this change and resubmit for further plumbing plan review.

Roland Morvant, rmorvant@jeffparish.net

CC:

**Jefferson Parish
Inspection and Code Enforcement**

**West Bank
400 Maple Ave.
Harvey, LA 70058
(504) 364-3512**

Plumbing Section

**East Bank
1221 Elmwood Park Blvd.
Suite 101 Jefferson, LA 70123
(504) 736-6957**

Friday, August 2, 2019

Eagle Eye Investments
Brett Fouquet
19189 Township Rd
Covington LA 70435

Re: Permit Application # 19-396974 JEFFERSON COMMUNITY HEALTH
3932 HWY 90 W, WAGGAMAN, LA 70094
Commercial Remodeling/Renovations

The application listed above cannot be approved until the following requirements are met:

Plumbing Department

8/2/2019 Isometric drawing required showing Potable water system to all fixtures including dental chairs with required reduced pressure back flow device. Separate reduce pressure back flow device is required for water lines to dental chair's. If dental chair's have built in reduce pressure back flow device's specification reflecting this will be required. Revise drawing to reflect this change and resubmit for further plumbing plan review.

Roland Morvant, rmorvant@jeffparish.net

CC:

**Jefferson Parish
Inspection and Code Enforcement**

**West Bank
400 Maple Ave.
Harvey, LA 70058
(504) 364-3512**

Plumbing Section

**East Bank
1221 Elmwood Park Blvd.
Suite 101 Jefferson, LA 70123
(504) 736-6957**

Friday, August 2, 2019

Eagle Eye Investments
CHRIS BOUDREAU
19189 Township Rd
Covington LA 70435

Re: Permit Application # 19-396974 JEFFERSON COMMUNITY HEALTH
3932 HWY 90 W, WAGGAMAN, LA 70094
Commercial Remodeling/Renovations

The application listed above cannot be approved until the following requirements are met:

Plumbing Department

8/2/2019 Isometric drawing required showing Potable water system to all fixtures including dental chairs with required reduced pressure back flow device. Separate reduce pressure back flow device is required for water lines to dental chair's. If dental chair's have built in reduce pressure back flow device's specification reflecting this will be required. Revise drawing to reflect this change and resubmit for further plumbing plan review.

Roland Morvant, rmorvant@jeffparish.net

CC:

**Jefferson Parish
Inspection and Code Enforcement**

**West Bank
400 Maple Ave.
Harvey, LA 70058
(504) 364-3512**

Plumbing Section

**East Bank
1221 Elmwood Park Blvd.
Suite 101 Jefferson, LA 70123
(504) 736-6957**

Friday, August 2, 2019

INTERGRATED DESIGN STUDIO
Henry SCHEIN
10920 W. LINCOLN AVE
WEST ALLIS WI 53227

Re: Permit Application # 19-396974 JEFFERSON COMMUNITY HEALTH
3932 HWY 90 W, WAGGAMAN, LA 70094
Commercial Remodeling/Renovations

The application listed above cannot be approved until the following requirements are met:

Plumbing Department

8/2/2019 Isometric drawing required showing Potable water system to all fixtures including dental chairs with required reduced pressure back flow device. Separate reduce pressure back flow device is required for water lines to dental chair's. If dental chair's have built in reduce pressure back flow device's specification reflecting this will be required. Revise drawing to reflect this change and resubmit for further plumbing plan review.

Roland Morvant, rmorvant@jeffparish.net

CC: