

PANEL SCHEDULE

PANEL LOCATION	AC	22,000
120240V, 1PH,3W	FULLY RATED	
20200V, 3PH,4W, WYE	PANEL HAS FRONT ACCESS ONLY	
277480V, 3PH,4W, WYE	ALL COPPER BUSING	
FACTORY MAIN CIRCUIT BREAKER	FURNISH ADDITIONAL ISOLATED GROUND BAR KIT	
SHUNT TRIP MAIN CB	SERVICE ENTRANCE LABEL	
MAIN LUGS ONLY	NAMEPLATE, 2"x4" ENGRAVED LAMINATED PLASTIC	
UL LISTED FEED-THRU LUGS	USE 1/4" LETTERING FOR PANEL NAME, 1 LINE	
MAIN FUSIBLE SWITCH,	MONTHLY, INSTALLED, 4 LINES	
FURNISH FUSES	WHITE FIELD, BLACK LETTERS	
	RED FIELD, WHITE LETTERS	

CT # OF TRIP POLE AMPS	LOAD DESCRIPTION	CONNECTED LOAD VA	VOLT-AMP	TRIP # OF CT AMPS POLE #
1	CLIN12	760	104	15
2	CLIN12	840	104	2
3	AC-N15	760	104	4
4	AC-N15	864	104	4
5	AC-N12	760	104	15
6	AC-N12	864	104	2
7	CLIN6	760	104	15
8	CLIN6	864	104	2
9	CLIN6	760	104	15
10	CLIN6	864	104	2
11	SPARE	760	104	15
12	SPARE	864	104	2
13	SPARE	760	104	15
14	SPARE	864	104	2
15	SPARE	760	104	15
16	SPARE	864	104	2
17	SPARE	760	104	15
18	SPARE	864	104	2
19	SPARE	760	104	15
20	SPARE	864	104	2
21	SPARE	760	104	15
22	SPARE	864	104	2
23	SPARE	760	104	15
24	SPARE	864	104	2
25	SPARE	760	104	15
26	SPARE	864	104	2
27	SPARE	760	104	15
28	SPARE	864	104	2
29	SPARE	760	104	15
30	SPARE	864	104	2

NOTE: TVSS CIRCUIT BREAKER TO BE SIZED IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS

PANEL SCHEDULE

PANEL LOCATION	AC	22,000
120240V, 1PH,3W	FULLY RATED	
20200V, 3PH,4W, WYE	PANEL HAS FRONT ACCESS ONLY	
277480V, 3PH,4W, WYE	ALL COPPER BUSING	
FACTORY MAIN CIRCUIT BREAKER	FURNISH ADDITIONAL ISOLATED GROUND BAR KIT	
SHUNT TRIP MAIN CB	SERVICE ENTRANCE LABEL	
MAIN LUGS ONLY	NAMEPLATE, 2"x4" ENGRAVED LAMINATED PLASTIC	
UL LISTED FEED-THRU LUGS	USE 1/4" LETTERING FOR PANEL NAME, 1 LINE	
MAIN FUSIBLE SWITCH,	MONTHLY, INSTALLED, 4 LINES	
FURNISH FUSES	WHITE FIELD, BLACK LETTERS	
	RED FIELD, WHITE LETTERS	

CT # OF TRIP POLE AMPS	LOAD DESCRIPTION	CONNECTED LOAD VA	VOLT-AMP	TRIP # OF CT AMPS POLE #
1	CLIN12	900	1200	20
2	CLIN12	1620	1200	20
3	CLIN12	1620	1200	20
4	CLIN12	1620	1200	20
5	CLIN12	1620	1200	20
6	CLIN12	1620	1200	20
7	CLIN12	1620	1200	20
8	CLIN12	1620	1200	20
9	CLIN12	1620	1200	20
10	CLIN12	1620	1200	20
11	CLIN12	1620	1200	20
12	CLIN12	1620	1200	20
13	CLIN12	1620	1200	20
14	CLIN12	1620	1200	20
15	CLIN12	1620	1200	20
16	CLIN12	1620	1200	20
17	CLIN12	1620	1200	20
18	CLIN12	1620	1200	20
19	CLIN12	1620	1200	20
20	CLIN12	1620	1200	20
21	CLIN12	1620	1200	20
22	CLIN12	1620	1200	20
23	CLIN12	1620	1200	20
24	CLIN12	1620	1200	20
25	CLIN12	1620	1200	20
26	CLIN12	1620	1200	20
27	CLIN12	1620	1200	20
28	CLIN12	1620	1200	20
29	CLIN12	1620	1200	20
30	CLIN12	1620	1200	20

NOTE: TVSS CIRCUIT BREAKER TO BE SIZED IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS

PANEL SCHEDULE

PANEL LOCATION	AC	22,000
120240V, 1PH,3W	FULLY RATED	
20200V, 3PH,4W, WYE	PANEL HAS FRONT ACCESS ONLY	
277480V, 3PH,4W, WYE	ALL COPPER BUSING	
FACTORY MAIN CIRCUIT BREAKER	FURNISH ADDITIONAL ISOLATED GROUND BAR KIT	
SHUNT TRIP MAIN CB	SERVICE ENTRANCE LABEL	
MAIN LUGS ONLY	NAMEPLATE, 2"x4" ENGRAVED LAMINATED PLASTIC	
UL LISTED FEED-THRU LUGS	USE 1/4" LETTERING FOR PANEL NAME, 1 LINE	
MAIN FUSIBLE SWITCH,	MONTHLY, INSTALLED, 4 LINES	
FURNISH FUSES	WHITE FIELD, BLACK LETTERS	
	RED FIELD, WHITE LETTERS	

CT # OF TRIP POLE AMPS	LOAD DESCRIPTION	CONNECTED LOAD VA	VOLT-AMP	TRIP # OF CT AMPS POLE #
1	XRFR1-D	43757	23784	125
2	XRFR1-D	41137	21184	2
3	XRFR1-D	39423	3476	4
4	XRFR1-D	32626	19960	10
5	XRFR1-D	19960	19960	12
6	XRFR1-D	19960	19960	12
7	XRFR1-D	19960	19960	12
8	XRFR1-D	19960	19960	12
9	XRFR1-D	19960	19960	12
10	XRFR1-D	19960	19960	12
11	XRFR1-D	19960	19960	12
12	XRFR1-D	19960	19960	12
13	XRFR1-D	19960	19960	12
14	XRFR1-D	19960	19960	12
15	XRFR1-D	19960	19960	12
16	XRFR1-D	19960	19960	12
17	XRFR1-D	19960	19960	12
18	XRFR1-D	19960	19960	12
19	XRFR1-D	19960	19960	12
20	XRFR1-D	19960	19960	12
21	XRFR1-D	19960	19960	12
22	XRFR1-D	19960	19960	12
23	XRFR1-D	19960	19960	12
24	XRFR1-D	19960	19960	12
25	XRFR1-D	19960	19960	12
26	XRFR1-D	19960	19960	12
27	XRFR1-D	19960	19960	12
28	XRFR1-D	19960	19960	12
29	XRFR1-D	19960	19960	12
30	XRFR1-D	19960	19960	12

NOTE: TVSS CIRCUIT BREAKER TO BE SIZED IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS

PANEL SCHEDULE

PANEL LOCATION	AC	22,000
120240V, 1PH,3W	FULLY RATED	
20200V, 3PH,4W, WYE	PANEL HAS FRONT ACCESS ONLY	
277480V, 3PH,4W, WYE	ALL COPPER BUSING	
FACTORY MAIN CIRCUIT BREAKER	FURNISH ADDITIONAL ISOLATED GROUND BAR KIT	
SHUNT TRIP MAIN CB	SERVICE ENTRANCE LABEL	
MAIN LUGS ONLY	NAMEPLATE, 2"x4" ENGRAVED LAMINATED PLASTIC	
UL LISTED FEED-THRU LUGS	USE 1/4" LETTERING FOR PANEL NAME, 1 LINE	
MAIN FUSIBLE SWITCH,	MONTHLY, INSTALLED, 4 LINES	
FURNISH FUSES	WHITE FIELD, BLACK LETTERS	
	RED FIELD, WHITE LETTERS	

CT # OF TRIP POLE AMPS	LOAD DESCRIPTION	CONNECTED LOAD VA	VOLT-AMP	TRIP # OF CT AMPS POLE #
1	EXAM ROOMS - RECEPTACLES	1200	1200	20
2	EXAM ROOMS - RECEPTACLES	2400	1200	20
3	EXAM ROOMS - RECEPTACLES	1200	1200	20
4	EXAM ROOMS - RECEPTACLES	1200	1200	20
5	EXAM ROOMS - RECEPTACLES	1200	1200	20
6	EXAM ROOMS - RECEPTACLES	1200	1200	20
7	EXAM ROOMS - RECEPTACLES	1200	1200	20
8	EXAM ROOMS - RECEPTACLES	1200	1200	20
9	EXAM ROOMS - RECEPTACLES	1200	1200	20
10	EXAM ROOMS - RECEPTACLES	1200	1200	20
11	EXAM ROOMS - RECEPTACLES	1200	1200	20
12	EXAM ROOMS - RECEPTACLES	1200	1200	20
13	EXAM ROOMS - RECEPTACLES	1200	1200	20
14	EXAM ROOMS - RECEPTACLES	1200	1200	20
15	EXAM ROOMS - RECEPTACLES	1200	1200	20
16	EXAM ROOMS - RECEPTACLES	1200	1200	20
17	EXAM ROOMS - RECEPTACLES	1200	1200	20
18	EXAM ROOMS - RECEPTACLES	1200	1200	20
19	EXAM ROOMS - RECEPTACLES	1200	1200	20
20	EXAM ROOMS - RECEPTACLES	1200	1200	20
21	EXAM ROOMS - RECEPTACLES	1200	1200	20
22	EXAM ROOMS - RECEPTACLES	1200	1200	20
23	EXAM ROOMS - RECEPTACLES	1200	1200	20
24	EXAM ROOMS - RECEPTACLES	1200	1200	20
25	EXAM ROOMS - RECEPTACLES	1200	1200	20
26	EXAM ROOMS - RECEPTACLES	1200	1200	20
27	EXAM ROOMS - RECEPTACLES	1200	1200	20
28	EXAM ROOMS - RECEPTACLES	1200	1200	20
29	EXAM ROOMS - RECEPTACLES	1200	1200	20
30	EXAM ROOMS - RECEPTACLES	1200	1200	20

NOTE: TVSS CIRCUIT BREAKER TO BE SIZED IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS

PANEL SCHEDULE

PANEL LOCATION	AC	22,000
120240V, 1PH,3W	FULLY RATED	
20200V, 3PH,4W, WYE	PANEL HAS FRONT ACCESS ONLY	
277480V, 3PH,4W, WYE	ALL COPPER BUSING	
FACTORY MAIN CIRCUIT BREAKER	FURNISH ADDITIONAL ISOLATED GROUND BAR KIT	
SHUNT TRIP MAIN CB	SERVICE ENTRANCE LABEL	
MAIN LUGS ONLY	NAMEPLATE, 2"x4" ENGRAVED LAMINATED PLASTIC	
UL LISTED FEED-THRU LUGS	USE 1/4" LETTERING FOR PANEL NAME, 1 LINE	
MAIN FUSIBLE SWITCH,	MONTHLY, INSTALLED, 4 LINES	
FURNISH FUSES	WHITE FIELD, BLACK LETTERS	
	RED FIELD, WHITE LETTERS	

CT # OF TRIP POLE AMPS	LOAD DESCRIPTION	CONNECTED LOAD VA	VOLT-AMP	TRIP # OF CT AMPS POLE #
1	EXAM ROOMS - RECEPTACLES	4150	3715	20
2	EXAM ROOMS - RECEPTACLES	3640	1500	20
3	EXAM ROOMS - RECEPTACLES	3535	2650	20
4	EXAM ROOMS - RECEPTACLES	3315	2975	20
5	EXAM ROOMS - RECEPTACLES	3315	2975	20
6	EXAM ROOMS - RECEPTACLES	3315	2975	20
7	EXAM ROOMS - RECEPTACLES	3315	2975	20
8	EXAM ROOMS - RECEPTACLES	3315	2975	20
9	EXAM ROOMS - RECEPTACLES	3315	2975	20
10	EXAM ROOMS - RECEPTACLES	3315	2975	20
11	EXAM ROOMS - RECEPTACLES	3315	2975	20
12	EXAM ROOMS - RECEPTACLES	3315	2975	20
13	EXAM ROOMS - RECEPTACLES	3315	2975	20
14	EXAM ROOMS - RECEPTACLES	3315	2975	20
15	EXAM ROOMS - RECEPTACLES	3315	2975	20
16	EXAM ROOMS - RECEPTACLES	3315	2975	20
17	EXAM ROOMS - RECEPTACLES	3315	2975	20
18	EXAM ROOMS - RECEPTACLES	3315	2975	20
19	EXAM ROOMS - RECEPTACLES	3315	2975	20
20	EXAM ROOMS - RECEPTACLES	3315	2975	20
21	EXAM ROOMS - RECEPTACLES	3315	2975	20
22	EXAM ROOMS - RECEPTACLES	3315	2975	20
23	EXAM ROOMS - RECEPTACLES	3315	2975	20
24	EXAM ROOMS - RECEPTACLES	3315	2975	20
25	EXAM ROOMS - RECEPTACLES	3315	2975	20
26	EXAM ROOMS - RECEPTACLES	3315	2975	20
27	EXAM ROOMS - RECEPTACLES	3315	2975	20
28	EXAM ROOMS - RECEPTACLES	3315	2975	20
29	EXAM ROOMS - RECEPTACLES	3315	2975	20
30	EXAM ROOMS - RECEPTACLES	3315	2975	20

NOTE: TVSS CIRCUIT BREAKER TO BE SIZED IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS

PANEL SCHEDULE

PANEL LOCATION	AC	22,000
120240V, 1PH,3W	FULLY RATED	
20200V, 3PH,4W, WYE	PANEL HAS FRONT ACCESS ONLY	
277480V, 3PH,4W, WYE	ALL COPPER BUSING	
FACTORY MAIN CIRCUIT BREAKER	FURNISH ADDITIONAL ISOLATED GROUND BAR KIT	
SHUNT TRIP MAIN CB	SERVICE ENTRANCE LABEL	
MAIN LUGS ONLY	NAMEPLATE, 2"x4" ENGRAVED LAMINATED PLASTIC	
UL LISTED FEED-THRU LUGS	USE 1/4" LETTERING FOR PANEL NAME, 1 LINE	
MAIN FUSIBLE SWITCH,	MONTHLY, INSTALLED, 4 LINES	
FURNISH FUSES	WHITE FIELD, BLACK LETTERS	
	RED FIELD, WHITE LETTERS	

CT # OF TRIP POLE AMPS	LOAD DESCRIPTION	CONNECTED LOAD VA	VOLT-AMP	TRIP # OF CT AMPS POLE #
1	EXAM ROOMS - RECEPTACLES	4150	3715	20
2	EXAM ROOMS - RECEPTACLES	3640	1500	20
3	EXAM ROOMS - RECEPTACLES	3535	2650	20
4	EXAM ROOMS - RECEPTACLES	3315	2975	20
5	EXAM ROOMS - RECEPTACLES	3315	2975	20
6	EXAM ROOMS - RECEPTACLES	3315	2975	20
7	EXAM ROOMS - RECEPTACLES	3315	2975	20
8	EXAM ROOMS - RECEPTACLES	3315	2975	20
9	EXAM ROOMS - RECEPTACLES	3315	2975	20
10	EXAM ROOMS - RECEPTACLES	3315	2975	20
11	EXAM ROOMS - RECEPTACLES	3315	2975	20
12	EXAM ROOMS - RECEPTACLES	3315	2975	20
13	EXAM ROOMS - RECEPTACLES	3315	2975	20
14	EXAM ROOMS - RECEPTACLES	3315	2975	20
15	EXAM ROOMS - RECEPTACLES	3315	2975	20
16	EXAM ROOMS - RECEPTACLES	3315	2975	20
17	EXAM ROOMS - RECEPTACLES	3315	2975	20
18	EXAM ROOMS - RECEPTACLES	3315	2975	20
19	EXAM ROOMS - RECEPTACLES	3315	2975	20
20	EXAM ROOMS - RECEPTACLES	3315	2975	20
21	EXAM ROOMS - RECEPTACLES	3315	2975	20
22	EXAM ROOMS - RECEPTACLES	3315	2975	20