PANEL: MDP
LOCATION: 1ST FLR. ELECTRICAL ROOM
FEEDER SOURCE: ENTERGY
VOLTAGE: 120/208V, 2000A 3ø, 4W
ENCLOSURE: SURFACE MOUNTED W/EQUIPMENT GRND BAR
SQUARE D TYPE QO LOAD CENTER

CKT NO.	LOAD DESCRIPTION LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION LOCATION	CKT NO.
1	PANEL P-1	200	3	–	–	3	200	PANEL P-8	2
3									4
5									6
7	PANEL P-2	200	3	–	–	3	200	PANEL P-9	8
9									10
11									12
13	PANEL P-3	200	3	–	–	3	200	PANEL P-10	14
15									16
17									18
19	PANEL P-4	200	3	–	–	3	200	PANEL L-1	20
21									22
23									24
25	PANEL P-5	200	3	–	–	3	200	PANEL L-2	26
27									28
29									30
31	PANEL P-6	200	3	–	–	3	200	PANEL L-3	32
33									34
35									36
37	PANEL P-7	200	3	–	–	1	20	SPARE	38
39					–	1	20	SPARE	40
41					–	1	20	SPARE	42

SOLID NEUTRAL / NEUTRAL WIRE (W) — TOTAL CONNECTED LOAD (VA): A# B# C# — GROUND BUS / GROUND WIRE (G)

NEW PANEL: P-3
LOCATION: 1ST FLOOR ELECTRICAL ROOM
FEEDER SOURCE: MDP
VOLTAGE: 208/120V, 200A 3ø, 4W
ENCLOSURE: SURFACE MOUNTED W/EQUIPMENT GRND BAR
SQUARE D TYPE QO LOAD CENTER

CKT NO.	LOAD DESCRIPTION LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION LOCATION	CKT NO.
1	UNIT 6 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 7 A/C RECEPTACLE	2
3									4
5	UNIT 8 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 9 A/C RECEPTACLE	6
7									8
9	UNIT 10 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 11 A/C RECEPTACLE	10
11									12
13	UNIT 12 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 13 A/C RECEPTACLE	14
15									16
17	UNIT 14 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 14 A/C RECEPTACLE (BACK ROOM)	18
19									20
21	UNIT 15 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 16 A/C RECEPTACLE	22
23									24
25	UNIT 17 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 18 A/C RECEPTACLE	26
27									28
29	UNIT 19 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 20 A/C RECEPTACLE	30
31									32
33	UNIT 21 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 22 A/C RECEPTACLE	34
35									36
37	UNIT 23 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 24 A/C RECEPTACLE	38
39									40
41	AUTOMATIC DOOR POWER	20	1	–	–	1	20	AUTOMATIC DOOR POWER	42

SOLID NEUTRAL / NEUTRAL WIRE (W) — TOTAL CONNECTED LOAD (VA): A# B# — GROUND BUS / GROUND WIRE (G)

NEW PANEL: P-6
LOCATION: 3RD FLOOR STORAGE ROOM
FEEDER SOURCE: MDP
VOLTAGE: 208/120V, 200A 3ø, 4W
ENCLOSURE: SURFACE MOUNTED W/EQUIPMENT GRND BAR
SQUARE D TYPE QO LOAD CENTER

CKT NO.	LOAD DESCRIPTION LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION LOCATION	CKT NO.
1	UNIT 59 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 60 A/C RECEPTACLE	2
3									4
5	UNIT 61 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 62 A/C RECEPTACLE	6
7									8
9	UNIT 63 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 64 A/C RECEPTACLE	10
11									12
13	UNIT 65 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 66 A/C RECEPTACLE	14
15									16
17	UNIT 67 A/C RECEPTACLE	30	2	–	–	2	30	3RD FLOOR COORDOR A/C RECEPACLE	18
19									20
21	3RD FLOOR CORRIDOR A/C RECEPTACLE	30	2	–	–	2	30	3RD FLOOR LINEN ROOM A/C RECEPACLE	22
23									24
25	3RD FLOOR SMOKE DETECTORS	20	1	–	–	1	20	SPARE	26
27	SPARE	20	1	–	–	1	20	SPARE	28
29	SPARE	20	1	–	–	1	20	SPARE	30
31	SPARE	20	1	–	–	1	20	SPARE	32
33	SPARE	20	1	–	–	1	20	SPARE	34
35	SPARE	20	1	–	–	1	20	SPARE	36
37	SPARE	20	1	–	–	1	20	SPARE	38
39	SPARE	20	1	–	–	1	20	SPARE	40
41	SPARE	20	1	–	–	1	20	SPARE	42

SOLID NEUTRAL / NEUTRAL WIRE (W) — TOTAL CONNECTED LOAD (VA): A# B# — GROUND BUS / GROUND WIRE (G)

NEW PANEL: P-9
LOCATION: 3RD FLOOR STORAGE ROOM
FEEDER SOURCE: MDP
VOLTAGE: 208/120V, 200A 3ø, 4W
ENCLOSURE: SURFACE MOUNTED W/EQUIPMENT GRND BAR
SQUARE D TYPE QO LOAD CENTER

CKT NO.	LOAD DESCRIPTION LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION LOCATION	CKT NO.
1	UNIT 41 OUTLETS	20	1	–	–	1	20	UNIT 42 OUTLETS	2
3	UNIT 41 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 42 OUTLETS (W-W & RED'S).	4
5	UNIT 43 OUTLETS	20	1	–	–	1	20	UNIT 44 OUTLETS	6
7	UNIT 43 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 44 OUTLETS (W-W & RED'S).	8
9	UNIT 45 OUTLETS	20	1	–	–	1	20	UNIT 46 OUTLETS	10
11	UNIT 45 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 46 OUTLETS (W-W & RED'S).	12
13	UNIT 47 OUTLETS	20	1	–	–	1	20	UNIT 48 OUTLETS	14
15	UNIT 47 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 48 OUTLETS (W-W & RED'S).	16
17	UNIT 49 OUTLETS	20	1	–	–	1	20	UNIT 50 OUTLETS	18
19	UNIT 49 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 50 OUTLETS (W-W & RED'S).	20
21	UNIT 51 OUTLETS	20	1	–	–	1	20	UNIT 52 OUTLETS	22
23	UNIT 51 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 52 OUTLETS (W-W & RED'S).	24
25	UNIT 53 OUTLETS	20	1	–	–	1	20	UNIT 54 OUTLETS	26
27	UNIT 53 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 54 OUTLETS (W-W & RED'S).	28
29	UNIT 55 OUTLETS	20	1	–	–	1	20	UNIT 56 OUTLETS	30
31	UNIT 55 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 56 OUTLETS (W-W & RED'S).	32
33	UNIT 57 OUTLETS	20	1	–	–	1	20	UNIT 58 OUTLETS	34
35	UNIT 57 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 58 OUTLETS (W-W & RED'S).	36
37	UNIT 59 OUTLETS	20	1	–	–	1	20	UNIT 60 OUTLETS	38
39	UNIT 59 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 60 OUTLETS (W-W & RED'S).	40
41	3RD FLOOR SMOKE DETECTORS	20	1	–	–	1	20	SPARE	42

SOLID NEUTRAL / NEUTRAL WIRE (W) — TOTAL CONNECTED LOAD (VA): A# B# — GROUND BUS / GROUND WIRE (G)

NEW PANEL: L-2
LOCATION: 2ND FLOOR STORAGE ROOM
FEEDER SOURCE: MDP
VOLTAGE: 208/120V, 200A 3ø, 4W
ENCLOSURE: SURFACE MOUNTED W/EQUIPMENT GRND BAR
SQUARE D TYPE QO LOAD CENTER

CKT NO.	LOAD DESCRIPTION LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION LOCATION	CKT NO.
1	UNIT 14 LIGHTS	20	1	–	–	1	20	UNIT 15 LIGHTS	2
3	UNIT 16 LIGHTS	20	1	–	–	1	20	UNIT 17 LIGHTS	4
5	UNIT 18 LIGHTS	20	1	–	–	1	20	UNIT 19 LIGHTS	6
7	UNIT 20 LIGHTS	20	1	–	–	1	20	UNIT 21 LIGHTS	8
9	UNIT 22 LIGHTS	20	1	–	–	1	20	UNIT 23 LIGHTS	10
11	UNIT 24 LIGHTS	20	1	–	–	1	20	UNIT 25 LIGHTS	12
13	UNIT 26 LIGHTS	20	1	–	–	1	20	UNIT 27 LIGHTS	14
15	UNIT 28 LIGHTS	20	1	–	–	1	20	UNIT 29 LIGHTS	16
17	UNIT 30 LIGHTS	20	1	–	–	1	20	UNIT 31 LIGHTS	18
19	UNIT 32 LIGHTS	20	1	–	–	1	20	UNIT 33 LIGHTS	20
21	UNIT 34 LIGHTS	20	1	–	–	1	20	UNIT 35 LIGHTS	22
23	UNIT 36 LIGHTS	20	1	–	–	1	20	UNIT 37 LIGHTS	24
25	UNIT 38 LIGHTS	20	1	–	–	1	20	UNIT 39 LIGHTS	26
27	UNIT 40 LIGHTS	20	1	–	–	1	20	2ND FLOOR CORRIDOR WALL SCONCE LIGHTS	28
29	2ND FLOOR CORRIDOR WALL SCONCE LIGHTS	20	1	–	–	1	20	2ND FLR. VENDING AREA LIGHTS	30
31	2ND FLOOR CORRIDOR CEILING LIGHTS	20	1	–	–	1	20	2ND FLOOR EMERGENCY LIGHTS	32
33	N. STAIR EMERGENCY LIGHTS	20	1	–	–	1	20	2ND FLOOR EXIT LIGHTS	34
35	S. STAIR EMERGENCY LIGHTS	20	1	–	–	1	20	2ND FLR. LINEN ROOM LIGHTS	36
37	STORAGE ROOM LIGHTS	20	1	–	–	1	20	SPARE	38
39	SPARE	20	1	–	–	1	20	SPARE	40
41	SPARE	20	1	–	–	1	20	SPARE	42

SOLID NEUTRAL / NEUTRAL WIRE (W) — TOTAL CONNECTED LOAD (VA): A# B# — GROUND BUS / GROUND WIRE (G)

NEW PANEL: P-1
LOCATION: 1ST FLOOR ELECTRICAL ROOM
FEEDER SOURCE: MDP
VOLTAGE: 208/120V, 200A 3ø, 4W
ENCLOSURE: SURFACE MOUNTED W/EQUIPMENT GRND BAR
SQUARE D TYPE QO LOAD CENTER

CKT NO.	LOAD DESCRIPTION LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION LOCATION	CKT NO.
1	LOBBY VIDEO CAMERA POWER	20	1	–	–	1	20	FRONT DESK VIDEO CAMERA POWER	2
3	FRONT DESK ISOLATED GROUND RECEPTACLES	20	1	–	–	1	20	FRONT DESK/ WORK RM./ SALES RM. RECEPTACLES	4
5	LOBBY FLOOR/ WALL RECEPT.	20	1	–	–	1	20	CORRIDOR/ JANITOR/GEN. MGR. BUSINESS CENTER RECEPTACLES	6
7	BUSINESS CENTER ISOLATED GROUND RECEPTACLES	20	1	–	–	1	20	PANTRY RECEPTACLES	8
9	BREAKFAST AREA RECEPTACLES	20	1	–	–	1	20	MEETING ROOM ISOLATED GROUND RECEPTACLES	10
11	BREAKFAST AREA 20ø RECEPTACLE	30	2	–	–	1	20	MENS/ WOMENS RESTROOM/ LAUND. TOILET GFI RECEPTACLES	12
13					–	1	20	VENDING MACHINE RECEPTACLE	14
15	VENDING MACHINE RECEPTACLE	20	1	–	–	1	20	VENDING MACHINE RECEPTACLE	16
17	VENDING MACHINE RECEPTACLE	20	1	–	–	1	20	GUEST LAUNDRY RECEPTACLES	18
19	GUEST LAUNDRY 208V DRYER RECEPTACLE	30	2	–	–	2	30	GUEST LAUNDRY 208V A/C RECEPACLE	20
21									22
23	CORRIDOR/ STORAGE/ MAINT./ ELECT. RM. RECEPTACLES	20	1	–	–	2	30	MAINT. ELECT. ROOM 208V DRYER RECEPTACLE	24
25	SPARE	20	1	–					26
27	HOT WATER HEATER #1	20	1	–	–	1	20	SPARE	28
29	MECHANICAL ROOM 208V RECEPTACLE	30	2	–	–	1	20	HOT WATER HEATER #2	30
31					–	1	20	HOUSE LAUNDRY/ ELEV. EQUIP./ BREAK ROOM RECEPTACLES	32
33	ELEVATOR EQUIPMENT RM. 208V A/C RECEPTACLE	30	2	–	–	1	20	LNDRY/ TELE.– VIDEO ROOM RECEPTACLES	34
35					–	1	20	GEN. MGR./ SALES ROOM ISOLATED GROUND RECEPTACLES	36
37	EXTERIOR DOOR CARD READER	20	1	–	–	1	20	EXERCISE ROOM RECEPTACLES	38
39	EXTERIOR WEATHERPROOF GFI RECEPTACLES	20	1	–	–	1	20	EXTERIOR DOOR CARD READER	40
41	SPARE	20	1	–	–	1	20	SPARE	42

SOLID NEUTRAL / NEUTRAL WIRE (W) — TOTAL CONNECTED LOAD (VA): A# B# — GROUND BUS / GROUND WIRE (G)

NEW PANEL: P-4
LOCATION: 2ND FLOOR STORAGE ROOM
FEEDER SOURCE: MDP
VOLTAGE: 208/120V, 200A 3ø, 4W
ENCLOSURE: SURFACE MOUNTED W/EQUIPMENT GRND BAR
SQUARE D TYPE QO LOAD CENTER

CKT NO.	LOAD DESCRIPTION LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION LOCATION	CKT NO.
1	UNIT 25 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 26 A/C RECEPTACLE	2
3									4
5	UNIT 27 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 27 A/C RECEPTACLE (BACK ROOM)	6
7									8
9	UNIT 29 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 28 A/C RECEPTACLE	10
11									12
13	UNIT 31 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 30 A/C RECEPTACLE	14
15									16
17	UNIT 33 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 32 A/C RECEPTACLE	18
19									20
21	UNIT 35 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 34 A/C RECEPTACLE	22
23									24
25	UNIT 37 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 36 A/C RECEPTACLE	26
27									28
29	UNIT 39 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 38 A/C RECEPTACLE	30
31									32
33	2ND FLOOR CORRIDOR A/C RECEPTACLE	30	2	–	–	2	30	UNIT 40 A/C RECEPTACLE	34
35									36
37	2ND FLOOR LINEN ROOM A/C RECEPTACLE	30	2	–	–	2	30	2ND FLOOR CORRIDOR A/C RECEPTACLE	38
39									40
41	VENDING RECEPTACLE	20	1	–	–	1	20	VENDING RECEPTACLE	42

SOLID NEUTRAL / NEUTRAL WIRE (W) — TOTAL CONNECTED LOAD (VA): A# B# — GROUND BUS / GROUND WIRE (G)

NEW PANEL: P-7
LOCATION: 1ST FLOOR ELECTRICAL ROOM
FEEDER SOURCE: MDP
VOLTAGE: 208/120V, 200A 3ø, 4W
ENCLOSURE: SURFACE MOUNTED W/EQUIPMENT GRND BAR
SQUARE D TYPE QO LOAD CENTER

CKT NO.	LOAD DESCRIPTION LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION LOCATION	CKT NO.
1	UNIT 1 OUTLETS	20	1	–	–	1	20	UNIT 2 OUTLETS	2
3	UNIT 3 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 2 OUTLETS (W-W & RED'S).	4
5	UNIT 3 OUTLETS	20	1	–	–	1	20	UNIT 4 OUTLETS	6
7	UNIT 3 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 4 OUTLETS (W-W & RED'S).	8
9	UNIT 5 OUTLETS	20	1	–	–	1	20	UNIT 6 OUTLETS	10
11	UNIT 5 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 6 OUTLETS (W-W & RED'S).	12
13	UNIT 7 OUTLETS	20	1	–	–	1	20	UNIT 8 OUTLETS	14
15	UNIT 7 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 8 OUTLETS (W-W & RED'S).	16
17	UNIT 9 OUTLETS	20	1	–	–	1	20	UNIT 10 OUTLETS	18
19	UNIT 9 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 10 OUTLETS (W-W & RED'S).	20
21	UNIT 11 OUTLETS	20	1	–	–	1	20	UNIT 12 OUTLETS	22
23	UNIT 11 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 12 OUTLETS (W-W & RED'S).	24
25	UNIT 13 OUTLETS	20	1	–	–	1	20	UNIT 14 OUTLETS	26
27	UNIT 13 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 14 OUTLETS (W-W & RED'S).	28
29	UNIT 15 OUTLETS	20	1	–	–	1	20	UNIT 16 OUTLETS	30
31	UNIT 15 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 16 OUTLETS (W-W & RED'S).	32
33	UNIT 17 OUTLETS	20	1	–	–	1	20	UNIT 18 OUTLETS	34
35	UNIT 17 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 18 OUTLETS (W-W & RED'S).	36
37	UNIT 19 OUTLETS	20	1	–	–	1	20	UNIT 20 OUTLETS	38
39	UNIT 19 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 20 OUTLETS (W-W & RED'S).	40
41	1ST FLOOR SMOKE DETECTORS	20	1	–	–	1	20	SPARE	42

SOLID NEUTRAL / NEUTRAL WIRE (W) — TOTAL CONNECTED LOAD (VA): A# B# — GROUND BUS / GROUND WIRE (G)

NEW PANEL: P-10
LOCATION: 3RD FLOOR STORAGE ROOM
FEEDER SOURCE: MDP
VOLTAGE: 208/120V, 200A 3ø, 4W
ENCLOSURE: SURFACE MOUNTED W/EQUIPMENT GRND BAR
SQUARE D TYPE QO LOAD CENTER

CKT NO.	LOAD DESCRIPTION LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION LOCATION	CKT NO.
1	UNIT 61 OUTLETS	20	1	–	–	1	20	UNIT 62 OUTLETS	2
3	UNIT 61 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 62 OUTLETS (W-W & RED'S).	4
5	UNIT 63 OUTLETS	20	1	–	–	1	20	UNIT 64 OUTLETS	6
7	UNIT 63 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 64 OUTLETS (W-W & RED'S).	8
9	UNIT 65 OUTLETS	20	1	–	–	1	20	UNIT 66 OUTLETS	10
11	UNIT 65 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	UNIT 66 OUTLETS (W-W & RED'S).	12
13	UNIT 67 OUTLETS	20	1	–	–	1	20	UNIT 68 RECEPTACLE	14
15	UNIT 67 OUTLETS (W-W & RED'S).	20	1	–	–	1	20	VENDING RECEPTACLE	16
17	3RD FLOOR CORRIDOR RECEPTACLES	20	1	–	–	1	20	MIRACLE VENT POWER SUPPLY	18
19	EXHAUST CHASE EXIT FAN #1	20	1	–	–	1	20	EXHAUST CHASE EXIT FAN #2	20
21	EXHAUST CHASE EXIT FAN #3	20	1	–	–	1	20	EXHAUST CHASE EXIT FAN #4	22
23	EXHAUST CHASE EXIT FAN #5	20	1	–	–	1	20	EXHAUST CHASE EXIT FAN #6	24
25	EXHAUST CHASE EXIT FAN #7	20	1	–	–	1	20	EXHAUST CHASE EXIT FAN #8	26
27	EXHAUST CHASE EXIT FAN #9	20	1	–	–	1	20	EXHAUST CHASE EXIT FAN #10	28
29	EXHAUST CHASE EXIT FAN #11	20	1	–	–	1	20	EXHAUST CHASE EXIT FAN #12	30
31	EXHAUST CHASE EXIT FAN #13	20	1	–	–	1	20	EXHAUST CHASE EXIT FAN #14	32
33	EXHAUST CHASE EXIT FAN #15	20	1	–	–	1	20	EXHAUST CHASE EXIT FAN #16	34
35	SPARE	20	1	–	–	1	20	SPARE	36
37	SPARE	20	1	–	–	1	20	SPARE	38
39	SPARE	20	1	–	–	1	20	SPARE	40
41	SPARE	20	1	–	–	1	20	SPARE	42

SOLID NEUTRAL / NEUTRAL WIRE (W) — TOTAL CONNECTED LOAD (VA): A# B# — GROUND BUS / GROUND WIRE (G)

NEW PANEL: L-3
LOCATION: 3RD FLOOR STORAGE ROOM
FEEDER SOURCE: MDP
VOLTAGE: 208/120V, 200A 3ø, 4W
ENCLOSURE: SURFACE MOUNTED W/EQUIPMENT GRND BAR
SQUARE D TYPE QO LOAD CENTER

CKT NO.	LOAD DESCRIPTION LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION LOCATION	CKT NO.
1	UNIT 41 LIGHTS	20	1	–	–	1	20	UNIT 42 LIGHTS	2
3	UNIT 43 LIGHTS	20	1	–	–	1	20	UNIT 44 LIGHTS	4
5	UNIT 45 LIGHTS	20	1	–	–	1	20	UNIT 46 LIGHTS	6
7	UNIT 47 LIGHTS	20	1	–	–	1	20	UNIT 48 LIGHTS	8
9	UNIT 49 LIGHTS	20	1	–	–	1	20	UNIT 50 LIGHTS	10
11	UNIT 51 LIGHTS	20	1	–	–	1	20	UNIT 52 LIGHTS	12
13	UNIT 53 LIGHTS	20	1	–	–	1	20	UNIT 54 LIGHTS	14
15	UNIT 55 LIGHTS	20	1	–	–	1	20	UNIT 56 LIGHTS	16
17	UNIT 57 LIGHTS	20	1	–	–	1	20	UNIT 58 LIGHTS	18
19	UNIT 59 LIGHTS	20	1	–	–	1	20	UNIT 60 LIGHTS	20
21	UNIT 61 LIGHTS	20	1	–	–	1	20	UNIT 62 LIGHTS	22
23	UNIT 63 LIGHTS	20	1	–	–	1	20	UNIT 64 LIGHTS	24
25	UNIT 65 LIGHTS	20	1	–	–	1	20	UNIT 66 LIGHTS	26
27	UNIT 67 LIGHTS	20	1	–	–	1	20	3RD FLOOR CORRIDOR WALL SCONCE LIGHTS	28
29	3RD FLOOR CORRIDOR WALL SCONCE LIGHTS	20	1	–	–	1	20	3RD FLR. VENDING AREA LIGHTS	30
31	3RD FLOOR CORRIDOR CEILING LIGHTS	20	1	–	–	1	20	3RD FLOOR EMERGENCY LIGHTS	32
33	N. STAIR EMERGENCY LIGHTS	20	1	–	–	1	20	3RD FLOOR EXIT LIGHTS	34
35	S. STAIR EMERGENCY LIGHTS	20	1	–	–	1	20	3RD FLR. LINEN ROOM LIGHTS	36
37	STORAGE ROOM LIGHTS	20	1	–	–	1	20	SPARE	38
39	SPARE	20	1	–	–	1	20	SPARE	40
41	SPARE	20	1	–	–	1	20	SPARE	42

SOLID NEUTRAL / NEUTRAL WIRE (W) — TOTAL CONNECTED LOAD (VA): A# B# — GROUND BUS / GROUND WIRE (G)

NEW PANEL: P-2
LOCATION: 1ST FLOOR ELECTRICAL ROOM
FEEDER SOURCE: MDP
VOLTAGE: 208/120V, 200A 3ø, 4W
ENCLOSURE: SURFACE MOUNTED W/EQUIPMENT GRND BAR
SQUARE D TYPE QO LOAD CENTER

CKT NO.	LOAD DESCRIPTION LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION LOCATION	CKT NO.
1									2
3	AHU #1	60	3	–	–	3	60	AHU #1 15 KW HEAT W/ SAFETY SWITCH	4
5									6
7									8
9	AHU #2	60	3	–	–	3	60	AHU #2 15 KW HEAT W/ SAFETY SWITCH	10
11									12
13									14
15	ELEVATOR POWER	60	3	–	–	3	60	HOUSE LAUNDRY WASHER	16
17									18
19									20
21	HOUSE LAUNDRY WASHER	60	3	–	–	3	60	HOUSE LAUNDRY DRYER	22
23									24
25									26
27	HOUSE LAUNDRY DRYER	60	3	–	–	2	30	UNIT 1 A/C RECEPTACLE (BACK ROOM)	28
29									30
31	UNIT 1 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 3 A/C RECEPTACLE	32
33									34
35	UNIT 2 A/C RECEPTACLE	30	2	–	–	2	30	UNIT 5 A/C RECEPTACLE	36
37					–	1	20	MECH. ROOM HEATERS (ELIM-3)	38
39	UNIT 4 A/C RECEPTACLE	30	2	–	–	1	20	AHU #3 (CEILING MOUNTED) (TELEPHONE/ VIDEO RM.)	40
41									42

SOLID NEUTRAL / NEUTRAL WIRE (W) — TOT