

PRODUCT SPECIFICATIONS

11.7 EER / 3.4 COP

Product Features

- Quiet operation: STC of 28
- Assembled in the USA for 30 years
- Increased dehumidification capacity
- 100% run-tested at our plant in Fayetteville, TN, for leaks
- 7 $\frac{1}{2}$ " unit front depth: one of the shallowest silhouettes in the industry today
- Removable condenser shroud allows easy access to enable regular cleaning of coils
- Easy pull-out filters that are washable and easy to maintain
- Filter drier for sealed system refrigerant
- 7-Button touch pad provides complete control to guests for in-room comfort while maintaining energy efficiency
- Condensate dispersion system removes condensate from indoor cooling operation and evaporates it into the atmosphere through the condenser
- Digismart™ front desk control & energy management software
- Room freeze protection is activated when the unit senses temperatures of 40°F or below
- Versatile style that blends into any room's color scheme and decor
- Easy to service with on-board led diagnostics
- Digismart™ wireless remote thermostat is available
- Remote temperature sensing for guest climate control
- Extended heat pump heating down to as low as 24°F outdoor ambient temperature
- Zero floor clearance allows unit to be installed flush to a finished floor
- 30-second fan-off delay
- Compressor lock-in prevents compressor short-cycling
- Constant fan mode
- Hidden ventilation control
- High-pressure switch



DigiSmart CONTROL BOARD



First-Year Warranty: Parts & Labor

Second through Fifth Year: Parts & Labor on certain sealed system components

Second through Fifth Year: on certain functional parts only

* Complete warranty details available at www.amana-ptac.com.

NOMENCLATURE

		PTC	07	3	G	35	AXXX	AA			
		1,2,3	4,5	6	7	8,9	10,11,12,13	14,15			
Basic Model Type								Engineering			
PTC	Standard Cooler PTAC							Major & Minor Revisions			
PTH	Standard Heat Pump PTHP										
DRY	Dehumid Cooler PTAC							Features Code			
Cooling Capacity								A	Standard Model		
07	7,000 BTU/h	60 Hz							C	Corrosion Protection (Seacoast)	
09	9,000 BTU/h	60 Hz							D	Power Door	
10	10,000 BTU/h	50 Hz							F	Fuse Holder (230/208 Only)	
12	12,000 BTU/h	50 or 60 Hz							H	Hydronic Heat-Capable	
15	15,000 BTU/h	60 Hz							P	Condensate Pump (PTH Only)	
17	17,000 BTU/h	60 Hz							Q	Quiet STC 31 Chassis	
Rated Voltage								R	RF Antenna		
2	115V, 60 Hz, 1 Ph							V	Power Vent		
3	230/208V, 60 Hz, 1 Ph							X	placeholder		
4	265V, 60 Hz, 1 Ph							W	Hard-Wired (PTQC)		
5	240/220V, 50 Hz, 1 Ph							Use up to 4 as needed in alphabetical order			
Design Series								Examples:			
G	R-410A							PTC123*50AXXX	PTC073*35CRXX		
Heater Size								PTC123*50CXXX	PTC073*25CQRW		
00	No Electric Heat	35	3.5 kW (230/208V)								
15	1.5 kW		3.7 kW (265V)								
25	2.5 kW	50	5.0 kW								



PRODUCT SPECIFICATIONS: PTC MODELS — COOLING/ELECTRIC HEAT



230/208 VOLTS

MODEL ^{6, 8, 9}		PTC 073G***XXX	PTC 093G***XXX	PTC 123G***XXX	PTC 153G***XXX	PTC 173G***XXX
Voltage ³		230 / 208	230 / 208	230 / 208	230 / 208	230 / 208
Capacity (BTU/h)		7,700	9,000	11,700 / 11,500	15,000 / 14,700	16400 / 16200
Amps ¹⁰		3.5	4.1	5.6	7.0	8.4
Watts ¹⁰		670/660	805/785	1135/1105	1500/1470	1740/1720
EER		11.5/11.7	11.2/11.5	10.3/10.4	10.0/10.0	9.4
UNIT WITHOUT ELECTRIC HEATER						
Min. Circuit Amps ^{2, 4, 10}		4.2	4.9	6.8	8.5	10.2
CFM (Cool/Wet Coil)	High	290	290	290	340	340
	Low	264	264	264	314	314
CFM (Dry Coil)	High	310	310	310	360	360
	Low	282	282	282	332	332
Ventilated Air, CFM (Fan Only)*		65*	65*	65*	65*	65*
Dehumidification (Pints/Hr.)		1.7	2.2	3.6	4.4	4.8
Net Weight (lbs.)		98	102	102	113	113
Ship Weight (lbs.)		113	117	119	130	130

265/277 VOLTS

Model ^{1, 6, 8}		PTC 074G***XXX	PTC 094G***XXX	PTC 124G***XXX	PTC 154G***XXX
Voltage ^{1, 3}		265	265	265	265
Capacity (BTU/h)		7,700	9,000	12,000	14,800
Amps ¹⁰		3.0	3.6	4.8	6.0
Watts ¹⁰		670	795	1,165	1,480
EER		11.5	11.3	10.3	10.0
UNIT WITHOUT ELECTRIC HEATER					
Min. Circuit Amps ^{2, 4, 10}		3.6	4.4	5.9	7.4
CFM (Cool/Wet Coil)	High	290	290	290	340
	Low	264	264	264	314
CFM (Dry Coil)	High	310	310	310	360
	Low	282	282	282	332
Ventilated Air, CFM (Fan Only)*		65*	65*	65*	65*
Dehumidification (Pints/Hr.)		1.7	2.2	3.6	4.4
Net Weight (lbs.)		98	102	102	113
Ship Weight (lbs.)		113	117	119	130

* Actual vent CFM performance will vary due to application and installation conditions.

NOTES

- All 265-volt models must use an Amana® brand sub-base (PTSB4**E) or an Amana® brand hard-wire kit PTPWHWK4 and disconnect switch PSHW04A.
- Minimum Circuit Ampacity (MCA) ratings conform to the National Electric Code; however, local codes should apply.
- Minimum voltage on 230/208-volt models is 197 volts; maximum is 253 volts. Minimum voltage on 265-volt models is 239 volts; maximum is 292 volts.
- Overcurrent protection for all units without electric heaters is 15 amps. Overcurrent protection on 265-volt models must be cartridge-style time-delay fuses (included and factory-installed on all Amana® brand 265-volt chassis). See heater performance.
- Heating capacity and efficiency based on unit operation without condensate pump; unit automatically switches to electric heat at approximately 24°F outdoor ambient.
- Specify two-digit heater kW size to complete model number.
- R-410A refrigerant used in all systems.
- All units meet or exceed ASHRAE 90.1 standards.
- All units less than 250 volts have a Leak Current Detector Interrupter (LCDI) power cord and meet UL 484 standards.
- Refer to electric heat performance data for total MCA and recommended overcurrent protection. Amps and Watts notation refers to compressor only.

PRODUCT SPECIFICATIONS: PTH MODELS — COOLING/HEAT PUMP/ELECTRIC HEAT



MODEL ^{1, 6, 8, 9}	PTH073G **AXXX	PTH093G **AXXX	PTH123G **AXXX	PTH153G **AXXX	PTH074G **AXXX	PTH094G **AXXX	PTH124G **AXXX	PTH154G **AXXX
Voltage ^{1, 3}	230 / 208	230 / 208	230 / 208	230 / 208	265	265	265	265
Capacity (BTU/h)	7,700	9,000	12,000	14,400	7,700	9,100	12,000	14,400
Amps ¹⁰	3.9	4.2	5.8	7.0	3.1	3.7	5.0	6.1
Watts ¹⁰	650 / 650	785 / 785	1,120 / 1,120	1,480 / 1,480	650	790	1,120	1,480
EER	11.7 / 11.7	11.5 / 11.5	10.7 / 10.7	9.7 / 9.7	11.7	11.5	10.7	9.7
UNIT WITHOUT ELECTRIC HEATER								
Min. Circuit Amps ^{2, 4, 10}	4.7	5.1	7.1	8.5	3.8	4.5	6.1	7.4
CFM (Cool/Wet Coil)	High	340	330	340	390	340	330	340
	Low	245	245	245	340	245	245	245
CFM (Dry Coil)	High	370	360	370	410	370	360	370
	Low	270	270	270	370	270	270	270
Ventilated Air, CFM (Fan Only)*	65*	65*	65*	65*	65*	65*	65*	65*
Dehumidification (Pints/Hr.)	1.7	2.2	3.6	4.4	1.7	2.2	3.6	4.4
Net Weight (lbs.)	108	112	115	126	108	112	115	125
Ship Weight (lbs.)	123	127	132	143	123	127	132	142

* Actual vent CFM performance will vary due to application and installation conditions.

NOTES

¹ All 265-volt models must use an Amana® brand sub-base (PTSB4**E) or an Amana® brand hard-wire kit (PTPWHWK4).

² Minimum Circuit Ampacity (MCA) ratings conform to the National Electric Code; however, local codes should apply.
Minimum voltage on 230/208-volt models is 197 volts; maximum is 253 volts.

³ Minimum voltage on 265-volt models is 239 volts; maximum is 292 volts.

⁴ Overcurrent protection for all units without electric heaters is 15 amps. Overcurrent protection on 265-volt models must be cartridge-style time-delay fuses (included and factory-installed on all Amana® brand 265-volt chassis).

⁵ Heating capacity and efficiency based on unit operation without condensate pump; unit automatically switches to electric heat at approximately 24°F outdoor ambient.

⁶ Specify two-digit heater kW size to complete model number.

⁷ R-410A refrigerant used in all systems.

⁸ All units meet or exceed ASHRAE 90.1 standards.

⁹ All units less than 250 volts have a Leak Current Detector Interrupter (LCDI) power cord and meet UL 484 standards.

¹⁰ Refer to electric heat performance data for total MCA and recommended overcurrent protection. Amps and Watts notation refers to compressor only.

PRODUCT SPECIFICATIONS: PTC MODELS — COOLING (UNITS FOR HYDRONIC HEATING)

MODEL ^{5, 6}		PTC 072G00XXX	PTC 092G00XXX
Voltage 2		115	115
Capacity (BTU/h)		7000	9000
Amps		6.9	8.3
Watts		585	795
EER		11.9	11.3
Min. Circuit Amps 1· 3		8.3	10.1
CFM (Cool/Wet Coil)	High	290	290
	Low	264	264
CFM (Dry Coil)	High	310	310
	Low	282	282
Ventilated Air, (Fan Only)*		65*	65*
Dehumidification (Pints/Hr.)		1.7	2.3
Net Weight (lbs.)		98	102
Ship Weight (lbs.)		113	117

* Actual vent CFM performance will vary due to application and installation conditions.

NOTES

¹ Minimum Circuit Ampacity (MCA) ratings conform to the National Electric Code; however, local codes should apply.

² Minimum voltage on 115-volt models is 109 volts; maximum is 127 volts.

³ Overcurrent protection for all units without electric heaters is 15 amps.

⁴ R-410A refrigerant used in all systems.

⁵ All units meet or exceed ASHRAE 90.1 standards.

⁶ All units less than 250 volts have a Leak Current Detector Interrupter (LCDI) power cord and meet UL 484 standards.

PRODUCT SPECIFICATIONS: PTC / PTH MODELS — ELECTRIC HEAT PERFORMANCE



(Primary Heating for PTC Models; Auxiliary Heating for PTH Models; See below for Power Cord Configuration)

VOLTAGE	ELECTRIC HEATER SIZE (kW)	NO. OF STAGES	NOMINAL HEATING (BTU/H)			TOTAL WATTS ⁶	TOTAL AMPS	MIN. CIRCUIT AMPACITY ²	MOD ⁴ (AMPS)	POWER CORD
			@ 230V	@ 208V	@ 265V					
230/208V	2.5	1	8,500	6,800	--	2,570 / 2,115	11.2 / 10.1	14.1	15	6-15 P
230/208V	3.5	1	12,000	9,900	--	3,570 / 2,935	15.5 / 14.1	19.5	20	6-20 P
230/208V	5	1	17,100	14,000	--	5,070 / 4,160	22.1 / 20.0	27.6	30	6-30 P
265V	2.5	1	--	--	8,500	2,570	9.7	12.2	15	7-20 P
265V	3.7	1	--	--	12,600	3,770	14.2	17.9	20	7-20 P
265V	5	1	--	--	17,100	5,070	19.2	23.9	25	7-30 P

NOTES

¹ All 265-volt models must use an Amana® brand sub-base (PTSB4**E) or an Amana® brand hard-wire kit (PTPWHWK4).

² Minimum branch circuit ampacity ratings conform to the National Electric Code; however, local codes should apply.

³ Minimum voltage on 230/208-volt models is 197 volts; maximum is 253 volts. Minimum voltage on 265-volt models is 239 volts; maximum is 292 volts.

⁴ Overcurrent protection for all units without electric heaters is 15 amps. Overcurrent protection on 265-volt models must be cartridge-style time-delay fuses (included and factory-installed on all Amana® brand 265-volt chassis).

⁵ Heating capacity and efficiency based on unit operation without condensate pump; unit automatically switches to electric heat at approximately 24°F outdoor ambient.

⁶ Total watts for 15,000 BTU/h models; subtract 20 watts for PT07/09/12

⁷ Specify two-digit heater kW size to complete model number.

⁸ R-410A refrigerant used in all systems.

⁹ All units meet or exceed ASHRAE 90.1 standards.

¹⁰ All units less than 250 volts have a Leak Current Detector Interrupter (LCDI) power cord and meet UL 484 standards.

PRODUCT SPECIFICATIONS: PTH MODELS — REVERSE-CYCLE HEATING PERFORMANCE

HEATING CAPACITY ¹	PTH073G **AXXX	PTH093G **AXXX	PTH123G **AXXX	PTH153G **AXXX	PTH074G **AXXX	PTH094G **AXXX	PTH124G **AXXX	PTH154G **AXXX
Voltage ^{1, 3}	230 / 208	230 / 208	230 / 208	230 / 208	265	265	265	265
BTU/h ⁵	6,800 / 6,800	8,300 / 8,100	11,500 / 11,300	13,800 / 13,600	6,800	8,300	11,400	13,700
Amps ¹⁰	3.9	4.2 / 4.2	5.8 / 5.8	7.0 / 7.0	3.1	3.7	5.0	6.1
Watts ¹⁰	585 / 570	715 / 700	1085 / 1035	1350 / 1330	570	715	1080	1340
COP ⁵	3.4 / 3.5	3.4 / 3.4	3.1 / 3.2	3.0 / 3.0	3.5	3.4	3.1	3.0
CFM (Dry)	370	360	370	410	370	360	370	410

COP = Coefficient of Performance; per AHRI Test Procedures, units are rated for capacities and efficiencies.

NOTES

- ¹ All 265-volt models must use an Amana® brand sub-base (PTSB4**E) or an Amana® brand hard-wire kit (PTPWHWK4).
- ² Minimum branch circuit ampacity ratings conform to the National Electric Code; however, local codes should apply.
- ³ Minimum voltage on 230/208-volt models is 197 volts; maximum is 253 volts.
Minimum voltage on 265-volt models is 239 volts; maximum is 292 volts.
- ⁴ Overcurrent protection for all units without electric heaters is 15 amps. Overcurrent protection on 265-volt models must be cartridge-style time-delay fuses (included and factory-installed on all Amana® brand 265-volt chassis).
- ⁵ Heating capacity and efficiency based on unit operation without condensate pump; unit automatically switches to electric heat at approximately 24°F outdoor ambient.
- ⁶ Specify two-digit heater kW size to complete model number.
- ⁷ R-410A refrigerant used in all systems.
- ⁸ All units meet or exceed ASHRAE 90.1 standards.
- ⁹ All units less than 250 volts have a Leak Current Detector Interrupter (LCDI) power cord and meet UL 484 standards.
- ¹⁰ Refer to electric heat performance data for total MCA and recommended overcurrent protection.
Amps and Watts notation refers to compressor only.

CONTRACTOR'S BID SHEET

Furnish and install air-cooled through-the-wall package terminal air conditioners and heat pumps (assembled in the USA). Units are rated in accordance with the ARI (Air Conditioning & Refrigeration Institute) Standards 310/380-93, CSA (Canadian Standards Association) EEV certification programs and listed by U. L. (Underwriters Laboratories).

RATINGS

Each unit must meet the following specifications:

ARI rating of _____ BTUH cooling (and _____ BTUH reverse cycle heating with a COP of _____ at 47° F O.D.)

Electric resistance heat of _____ BTUH. Total Amp draw must be of _____ and _____ Watts at _____ volts.

The unit must remove a minimum of _____ pints of moisture per hour when operated at rating conditions. The EER must be a minimum of _____ EER.

UNIT CHASSIS

Each unit must be slide out design shipped with room cabinet front installed. Unit chassis must have the ability to be installed with 0 clearance from finished floor. An electrical power cord must be included with chassis and installed by the manufacturer to assure proper NEMA 6 or 7 configuration and UL-approved length. Units less than 250 volts must also have a LCDI power cord. Unit must be tested for conformance to ASTM E water infiltration specification ASTM E 331-86, which ensures no water infiltration when tested at 8" rain per hour at 63 mph wind for 15 minutes.

ROOM CABINET

The monochromatic front of the room cabinet must be able to be field-secured to chassis to inhibit tampering. Filter must be accessible without removing room front. Cabinet depth must not exceed 7 1/2" to minimize unit's impact on room space.

COILS

Unit's coils must have rifled copper tubing expanded into rippled-edge louvered aluminum fins. Exterior coil must be of a two-row bent coil design with removable shroud top to allow easy-access for cleaning of the exterior coil.

HEAT PUMPS

Each unit must include a change-over thermistor that senses an outside ambient switch-over temperature as low as 24°F, lock-open refrigerant reversing valve during heat pump operation, temperature-activated defrost drain and automatic emergency heat operation to override the heat pump's change-over thermostat and bring on electric resistance heaters in the event of a sealed system failure. Unit must not operate compressor and electric heaters simultaneously.

COMPRESSOR

The compressor must be hermetically sealed, internally isolated, rotary-type and permanently mounted on rubber isolators. No removal or adjustment of compressor hold-down bolts is to be required during installation.

WARRANTY

The warranty is for Full One Year on the entire unit; Full 2nd through 5th Year on the entire sealed refrigerant system components; Limited Second through Fifth Year on functional parts only.

UNIT DIGITAL CONTROLS

The unit's control must be completely wired and accessible from the top of the chassis. Controls shall be a LED touch-pad design with seven large, easy-to-read and use buttons: Heat – Cool – Off – Fan – Temp+ (plus) – Temp- (minus) and two red seven-segment LED temperature displays. Unit shall have a green status LED to advise owner of operational diagnostic messages. Unit shall have one-button activation via membrane touch-pad. Unit control board shall have an 18-pin low-voltage connector to allow for easy connection to remote wired devices. Unit shall have two serial-port connectors for easy connection to wired or wireless EMS (Energy Management Systems).

Unit must have the ability to easily configure owner-selectable and programmable functions:

- Fan-cycle operation
- Electronic temperature limiting for cooling
- Electronic temperature limiting for heating
- Enhanced dehumidification cooling operation
- Unoccupied 18-hour temperature set-back
- Un-rented temperature set-back
- Multiple unit twinning to one wired thermostat
- Load-shedding operation
- Front-desk on-off or temperature set-back

Unit must be able to connect to approved remote devices:

- Wired thermostat
- Wired door motion sensor

- Wired room motion sensor
- Wired room-to-room transfer fan
- Front Desk Control
- Future RF wireless communications devices

Unit must be able to acquire and display operational temperature data from up to six installed thermistors to include:

- IAT—Indoor air temperature (black)
- ICT—Indoor coil temperature (red)
- IDT—Indoor discharge temperature (yellow)
- OCT—Outdoor coil temperature (blue) (heat pumps & Wireless cooler models)
- OAT— Outdoor Air Temperature (Wireless-ready models only)
- Orange—Miscellaneous thermistor or analog device (optional)

EVAPORATOR/CONDENSER FANS

Direct drive with a permanent, split-capacitor, two-speed indoor motor. Condensate must be directed onto the back and sides of the coil to aid in evaporation and removal.

AIR DISCHARGE

Must be a sloped surface so that obstructions cannot be placed on the unit. Discharge conditioned air can be directed into the room at an angle of 16 or 56 degrees from the vertical position. The discharge grille must be of polycarbonate material to resist bending, cracking, rusting and corrosion.

New installations typically require a minimum of WS900E wall sleeve and an outdoor grille.

WALL SLEEVES (WS900E)

The wall sleeve must be industry-accepted dimensions: 14½" depth x 42" width x 16⅞" height and constructed of G90 HDG galvanized steel with a baked corrosion-inhibiting urethane primer and baked-polyester topcoat enamel. Sleeve must be insulated and shipped with a weather resistant rear closure panel installed.

The optional accessories listed below perform specific functions required in some installations.

CONDENSATE DRAIN KIT (DK900D)

Attaches to the bottom of the wall sleeve for directional-controlled internal or external disposal of condensate, defrost or rain water.

SUB-BASE KIT (PTSB***E)

Necessary for UL listing requirements for 265V units (Hard Wire Kit may be substituted for Sub-base kit). Optional for 230/208V units. Must be pre-wired to facilitate field-electrical connections and include an NEMA 6 or 7 configuration electrical receptacle. It must have two leveling screws for sleeve support and accurate unit leveling during installation. Locations for field installation of physical disconnect switches, cartridge-style fuse holders and circuit breakers must be provided. Side-skirts must be provided with sub-bases. *(PTSB000E Non-Electrical Sub-base available.)*

OUTDOOR GRILLES

Outdoor grille must be architecturally extruded, louvered aluminum (AGK01*B), one-piece polymer-blend injection molded louver (PGK01*B) or standard stamped aluminum (SGK**B). All other grilles must be submitted to the PTAC manufacturer for feasibility, airflow characteristics and compliance with UL regulations, where necessary.

POWER VENT & DAMPER

Must be provided to maximize ventilation air intake to up to approximately 95 CFM. Power vent must be off and damper door closed when unit fan is de-energized.

FUSE HOLDER (INCLUDED IN 265V CHASSIS)

Must be installed either in the unit or the sub-base and must match the electrical requirements of the chassis.

SECURITY KEY LOCKS (KL03E)

Must be installed to prevent tampering of the unit controls. Unit room cabinet must also be secured to the chassis with field supplied screws. UL-approved for institutional use only.

DISCONNECT SWITCH

Power disconnect switch must be installed in sub-base for use as a physical disconnect, where required by local codes.

CONTRACTOR'S BID SHEET (CONT.)

DUCT KITS (MDK01E, EDK02B, TDK02B, PTDK01E, DDK01E)

Three kits must be supplied to provide ducted, conditioned air into a second room: a main duct kit, an extension duct kit and a terminal duct kit.

HYDRONIC HEAT KIT

Is required for heating functions instead of electric resistance heaters. Unit must retain complete service access with the kit installed. Proper water or steam valves must be used.

CONDENSATE REMOVAL PUMP (HEAT PUMPS ONLY)

Must be installed to assist in removing the condensate developed by the heat pump operation and transfer it to the indoor coil to dissipate into the room, adding humidity to the room.

CIRCUIT BREAKER KIT

Must be installed in sub-base to provide overcurrent protection for proper 230/208V amperage. Can also be used as a physical disconnect where local codes permit for 230/208 voltage.

HARD WIRE KIT

Must be used to permanently wire chassis for hard wire purposes. (For 265V units, Hard Wire Kit may be substituted with Sub-base Kit.)

THERMOSTATS

A manufacturer-approved manual, auto changeover or programmable traditionally wired thermostat must be installed to provide full remote operation of the chassis. A Remote Escutcheon Kit must be used to indicate remote operation.

MONTHLY MAINTENANCE

INTAKE AIR FILTERS

It is extremely important to clean the inlet air filters once a month (or more often if operated in dusty or dirty locations or conditions) to properly maintain the operational performance of the PTAC unit. The two intake air filters (constructed of durable polypropylene) can be easily inserted into the cabinet front using the cabinet filter guides. Before cleaning the intake filters, turn the unit off by setting the mode switch to the OFF position. Filters should be cleaned as required. The following procedure is used to remove the intake filters:

1. Facing the unit, pull up on the filter handles located at the front top of the unit.
2. Pull each filter upward and remove.
3. Clean filters with vacuum or with running water. Reverse this procedure to reinstall the filters.

Note: Accessory filter kits are available from your sales person. All filters are permanent and cleanable. Consult your I&O Manual for other monthly cleaning instructions.



SPARE FILTERS

Helps keep dirt and lint out of the air and off the coil, thus increasing the unit's efficiency. Amana® brand filters are easy to remove, wash and replace.

FK10A	10-pack - A Series
FK10B	10-pack - B, C & D Series
FK10E	10-pack - E Series (requires 2 filters per change.)

REPLACEMENT CHARCOAL FILTER KIT

Absorbs airborne odors caused by cigarette, pipe or cigar smoke and odors caused by mold, mildew, etc. Filters are made of polyester fibers coated with activated charcoal and are individually wrapped. These filters are permanent and can be washed or cleaned. Call your Amana® brand PTAC sales person for details. 10 filters per pack.

CFK10A	10-PACK - A SERIES (R-22)
CFK10B	10-PACK - B, C & D SERIES (R-22)