



**LIGHTING NOTES**

A. EMERGENCY BATTERY LIGHTING UNITS AND EXIT SIGNS SHALL BE CONNECTED TO THE UN-SWITCHED HOT LEG OF THE BRANCH CIRCUIT.

B. FIXTURES SHOWN HATCHED ARE THE 'E' TYPE OF THE FIXTURE AND HAVE AN EMERGENCY BATTERY. CONNECT TO AN UN-SWITCHED HOT CONDUCTOR.

C. EMERGENCY LIGHTING: WALL FIXTURE: 12" BELOW FINISHED CEILING OR +10'-0" IN AREAS OF EXPOSED STRUCTURE UNLESS NOTED OTHERWISE. REMOTE HEAD FIXTURE: HEADS CENTERED ABOVE DOOR OPENING +9'-0" UNLESS NOTED OTHERWISE.

**KEYNOTES**

26.301	SPEAKERS BY OWNER.
26.302	SEE ARCHITECTURAL ELEVATIONS FOR MOUNTING HEIGHTS OF SIGNS.
26.306	POWER PACK FOR OCCUPANCY SENSOR, MOUNT ON WALL AT 96" AFF. CONNECT TO UN-SWITCHED HOT LEG OF LIGHTING CIRCUIT. PROGRAM FOR AUTO ON/OFF.
26.308	MOUNT POWER SUPPLY FOR TYPE 'SE' FIXTURES ABOVE CEILING. ROUTE LOW VOLTAGE WIRES THROUGH WALL TO CONNECT TO QUICK CONNECT FITTING ON POWER SUPPLY.
26.309	CONNECT UN-SWITCHED HOT LEG TO THE INVERTERS. SEE MANUFACTURER'S INSTALLATION DIAGRAMS.
26.310	PROVIDE CURRENT LIMITER FOR TRACK LIGHTING RATED FOR WATTAGE SHOWN ON DRAWING.
26.311	SPEAKERS BY OWNER, MOUNT SPEAKER TO STRUCTURE.

**HFA**  
 HARRISON FRENCH & ASSOCIATES, LTD.  
 t 479.273.7780  
 1705 S. Walton Blvd., Suite 3  
 Bentonville, Arkansas 72712  
 www.hfa-ac.com

**STIPULATION FOR REUSE**  
 THESE DRAWINGS ARE PREPARED FOR USE ON A SPECIFIC SITE AT A SPECIFIC TIME AND PLACE. THEY ARE NOT TO BE REPRODUCED, COPIED, REUSED, OR TRANSMITTED IN ANY MANNER WITHOUT THE WRITTEN CONSENT OF HFA. ANY REUSE OF THESE DRAWINGS FOR ANY OTHER PROJECT, SITE, OR TIME WITHOUT THE WRITTEN CONSENT OF HFA IS STRICTLY PROHIBITED. THE USER OF THESE DRAWINGS SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPROPRIATE AUTHORITIES. HFA AND ITS ENGINEERS, ARCHITECTS AND ENGINEERS, ARE NOT RESPONSIBLE FOR ANY REUSE OF THESE DRAWINGS FOR ANY OTHER PROJECT, SITE, OR TIME WITHOUT THE WRITTEN CONSENT OF HFA.

**Loves**  
 STORE NUMBER: 860  
 I-59, EXIT 1  
 NICHOLSON, MS 39466  
 JOB NUMBER: 03-23-30009  
 TIER 1 180

**ISSUE BLOCK**


CHECKED BY: CAR  
 DRAWN BY: SED  
 DOCUMENT DATE: 2/7/2023  
 PROTO: TIER 1 180  
 PROTO CYCLE: Q4 - 2022



**LIGHTING PLAN**

**1 LIGHTING PLAN**  
 3/16" = 1'-0"

SHEET: **E301**

07/2023 1:46:10 AM  
 C:\Users\jfrancis\appdata\local\temp\2023\02\07\14\22\47\06\00\1\4444\01\LIGHTING PLAN