



October 26, 2015

Ms. Lucy Hamilton
2053 E. Gause Blvd.
Slidell, LA 70461

RE: Home Foundation
54262 Apple Pie Ridge
Slidell, LA

Lucy Hamilton contacted Dammon Engineering to request an inspection of an existing foundation. The foundation previously supported a residential structure. The Hamiltons are planning to build an approximately 20' x 30' wood frame building on the foundation to accommodate a new commercial building.

The Architect that is designing the new building asked the Hamiltons to obtain an opinion on the structural integrity of the foundation and determine its capability for supporting the new structure.

The foundation was constructed with an 18" brick ledge to support a wood frame structure that no longer exists.

As long as the new structure is sitting on the edges of the foundation and on footings, the foundation will adequately support the new building.

This report does not cover any other aspects of the building such as plumbing, electrical, gas, mechanical egress, general arrangement, site drainage, etc.

Sincerely,

Brian Mistich

