



DAMMON

ENGINEERING, INC.

554 Old Spanish Trail
Slidell, LA 70458
Phone: 985-649-5832
Fax: 985-641-5950
dammonengineering.com
info@dammonengineering.com

August 18, 2023

Mr. Dallas Guidry
4501 Providence Pl
Apt 1B
New Orleans, La. 70126

Re:
1753 Marsha Dr
Slidell, LA. 70458

Dear Mr. Guidry,

You requested that we inspect the referenced residence for the removal of a load bearing wall.

A double 2x12 or Parallam 2.0E 3.5x9.5 beam that is not longer than 12 ft in length and constructed to meet the requirements of the 2021 IRC will be structurally sufficient to meet the loads applied to the load bearing wall. See attached plan.

This report does not cover any other aspects of the building such as plumbing, electrical, gas, mechanical egress, general arrangement, site drainage, etc., and assumes that ground conditions are substantially the same as is under the residence.

Sincerely,

Brian A Mistich, P.E.
La. License No. 0030187