

DAMMON ENGINEERING, INC.

dammonengineering.com

ARCHITECTS

ENGINEERS

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

1095 Florida Ave.
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

March 25, 2010

Mr. John Broyles
Codes Division
Lafayette Consolidated Government
220 W. Willow Street, Building B
P.O. Box 4017-C
Lafayette, Louisiana 70502

RE: 629 Camellia Drive
Lafayette, LA 70503

Dear Mr. Broyles,

This letter is to confirm that we have inspected photos of the bonding system taken during construction for the pool at this site and found the bonding system to be in compliance with the National Electrical Code.

The pool is 18 x 24 with a depth of 3½ to 6 feet. The rebar is 3/8 diameter and spaced 8 inches on center in the side walls and floor. The grounding conductors are placed 2 across the width and 3 across the length and is attached with ground clamps – 3 clamps in each conductor. The ground conductor wraps around and reinforces the conductor in the decking that goes to the ground rod of the pool equipment.

It is my professional opinion that the grounding system meets all requirements of the National Electrical Code. In issuing this letter, the undersigned understands that LCG is relying on this letter in connection with the issuance of any final inspection and/or Certificate of Occupancy, and that LCG would not have issued such final approvals without this letter.

Sincerely,

Emmett G. (Pete) Dammon, P.E.