


FOR MECHANICAL  
NOTES SEE M-1

EXHAUST FAN SCHEDULE

LOC	CFM	VOLTAGE	TYPE	MANF.
TOILETS	SEE DWG	120	VENT/LIGHT	-

A/C SPLIT UNIT SCHEDULE

NO.	TOTAL BTU	CFM	O.A.	HEAT (KW)	ELECTRICAL		COMMENTS
					VOLTAGE	MCA	
1	72,000	2,400	240	20	208V, 3ø	-	MDP2-2, 4, 6
2	60,000	2,000	200	20	208V, 3ø	-	MDP2-8, 10, 12
3	108,000	3,600	360	20	208V, 3ø	-	MDP2-1, 4, 6, 18
4	36,000	1,200	120	15	208V, 3ø	-	MDP2-20, 22
5	54,000	1,800	180	20	208V, 3ø	-	MDP2-26, 28, 30



MECHANICAL PLAN SUITE B  
SCALE: 1/8" = 1'-0"

- LEGEND**
- SUPPLY AIR
  - RETURN AIR
  - EXHAUST FAN
  - A/C UNIT
  - THERMOSTAT
  - AHU #1
  - AHU #2
  - AHU #3
  - AHU #4
  - AHU #5
  - OUTSIDE AIR
  - RETURN AIR



**DAMMON**  
ENGINEERING, INC.

**EMMETT DAMMON**

**ARCHITECT**  
**ROBERT SOLBERGER**

1095 FLORIDA AVENUE  
SLIDELL, LA, 70458  
985-649-5832

WEBSITE: WWW.DAMMONENGINEERING.COM  
EMAIL: DAMMONENG@BELLSOUTH.NET

ARCHITECTURE  
ENGINEERING  
STUDIES  
PLANNING  
INVESTIGATION  
EXPERT WITNESS

NEW OFFICE  
BUILDING

PLATFORM CRANE  
POWELL DRIVE  
SLIDELL, LA

MECHANICAL  
PLAN  
SUITE B

REV:

SCALE: AS NOTED

JOB#: 1898

DATE: 10-8-07

SHEET 16

**M-2**

OF 25