


FOR MECHANICAL
NOTES SEE M-1

EXHAUST FAN SCHEDULE			
LOG	CFM	VOLTAGE	TYPE
TOILETS	SEE DWG	120	VENF/LIGHT
			MANF.

A/C SPLIT UNIT SCHEDULE						
NO.	TOTAL BTU	CFM	O.A.	HEAT (KW)	ELECTRICAL MCA	COMMENTS
1	72,000	2,400	240	208V/3ø	MDP2-2,4,8	CARRIER
2	80,000	2,000	200	208V/3ø	MDP2-8,10,12	CARRIER
3	90,000	3,600	360	208V/3ø	MDP2-14,16,18	CARRIER
4	36,000	1,200	120	208V/3ø	MDP2-20,22	CARRIER
5	80,000	2,000	200	208V/3ø	MDP2-26,28,30	CARRIER



MECHANICAL PLAN SUITE B
SCALE: 1/8"=1'-0"

- LEGEND**
- SUPPLY AIR
 - RETURN AIR
 - EXHAUST FAN
 - A/C UNIT
 - THERMOSTAT
 - AHU #1
 - AHU #2
 - AHU #3
 - AHU #4
 - AHU #5
 - OUTSIDE AIR
 - RETURN AIR



DAMMON ENGINEERING, INC.

EMMETT DAMMON

ARCHITECT
ROBERT SOLBERGER

1095 FLORIDA AVENUE
SLIDELL, LA. 70458
985-649-5832

WEBSITE: WWW.DAMMONENGINEERING.COM
EMAIL: DAMMONENG@BELL.SOUTH.NET

ARCHITECTURE
ENGINEERING
STUDIES
PLANNING
INVESTIGATION
EXPERT WITNESS

NEW OFFICE BUILDING

PLATFORM CRANE
POWELL DRIVE
SLIDELL, LA

MECHANICAL PLAN SUITE B

REV:

SCALE: AS NOTED

JOB#: 1898

DATE: 10-8-07

SHEET 16

M-2

OF 25