



SHINGLES (SEE SPECS) OVER
15# FELT OVER 1/2" O.S.B WITH CLIPS
(R905.2.6 - 6 FASTENERS PER STRIP OF SHINGLES)

TRUSS SYSTEM
(DESIGNED BY OTHERS)

DECK (FOR AHU & PAN) SUSPENDED
FROM TRUSS SYSTEM WITH ALLTHREAD RODS
1/2" PLYWOOD DECKING)

A. H. U.

INSULATION (TYP)
R-13 (WALLS)
R-30 (CEILINGS)

SUSPENDED CEILING @ 10'-0"

BLOCKING FOR L CHANNEL

FIREBLOCKING
2 X 6 STUD WALLS

ANCHOR BOLTS (PLACE 28" O.C. MAX)

BRICK VENEER ATTACHED TO 1/2" SHEATHING
WITH 3/4" CORROGATED WALL TIES EVERY
4TH COURSE. VAPOR MEMBRANE TO BE RUN
OVER ALL SHEATHING PRIOR TO INSTALLATION
OF WALL TIES.

1X2 DRIP EDGE
SUB FACIA W/ ALUMINUM WRAP
2 2X12 BM W/ 1/2" PW BTWN
OVER 2 2X8S FOR FUR DOWN
WROUGHT IORN COLUMN
DESIGNED BY OTHERS

1:12 SLOPE
MAXIMUM