



Interior Lighting Compliance Certificate

Project Information

Energy Code: 90.1 (2007) Standard
 Project Title: Cantium Office Bldg
 Project Type: Alteration

Construction Site:
 111 Park Place
 Covington, LA 70433

Owner/Agent:
 Terry Hancocks
 Cantium
 111 Park Place
 Covington, LA 70433
 985-317-5101

Designer/Contractor:
 David Dammon
 Dammon Engineering, Inc
 554 Old Spanish Tr
 Slidell, LA 70458
 985-649-5832
 david@dammonengineering.com

Allowed Interior Lighting Power

A Area Category	B Floor Area (ft2)	C Allowed Watts / ft2	D Allowed Watts (B X C)
1-Renovation (Common Space Types:Office - Enclosed): Exempt			Total Allowed Watts = N/A

Area Category Exemption Qualifications

Activity Area	# Fixtures		Total # Watts	
	Pre-Alt.	Repl./Added	Pre-Alt.	Post-Alt.
Renovation (Common Space Types:Office - Enclosed 10000 sq.ft.) Exemption: Less than 50% fixture replacement.	315	150	25900.000	6700.000

Proposed Interior Lighting Power

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
Renovation (Common Space Types:Office - Enclosed 10000 sq.ft.): Exempt				Total Proposed Watts = N/A

Interior Lighting PASSES

Interior Lighting Compliance Statement

Compliance Statement: The proposed interior lighting alteration project represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed interior lighting systems have been designed to meet the 90.1 (2007) Standard requirements in COMcheck Version 4.1.1.0 and to comply with any applicable mandatory requirements listed in the Inspection Checklist.

Name - Title

Signature

Date