



**20 LIGHTING PLAN**  
SCALE: 1/4"=1'-0"

**LIGHTING LEGEND**

- 2x4 LED LIGHTING FIXTURE
- LED RECESSED LIGHT FIXTURE
- LED EXTERIOR WALL MOUNTED LIGHT FIXTURE
- LED VANITY LIGHT
- JUNCTION BOX
- EMERGENCY LIGHT FIXTURE
- EXIT LIGHT FIXTURE
- LIGHT SWITCH 120V COMMERCIAL GRADE
- 3-WAY LIGHT SWITCH 120V COMMERCIAL GRADE
- EXHAUST FAN SEE MECHANICAL PLAN
- CIRCUIT HOME RUN

**KEY NOTES**

1. PROVIDE CONNECTION TO UN-SWITCHED HOT OF LIGHTING CIRCUIT AND SHALL HAVE 90 MINUTE EMERGENCY BATTERY BACKUP.
- NOTE:  
REPLACE NECESSARY FIXTURES CAUSED BY REMODEL AND REUSE FIXTURES WHEN ABLE

**GENERAL LIGHTING NOTES**

1. ALL WORK SHALL COMPLY WITH APPLICABLE NATIONAL, STATE, AND LOCAL CODES, RULES, REGULATIONS, AND REQUIREMENTS OF THE SERVICE UTILITY COMPANY.
2. GENERAL CONTRACTOR SHALL NOTIFY THE ARCHITECT IMMEDIATELY IF ANY CONFLICTS OCCUR BETWEEN LIGHTING AND ANY OTHER TRADE. DO NOT PROCEED WITH INSTALLATION IN THAT AREA UNTIL CONFLICT HAS BEEN RESOLVED TO THE SATISFACTION OF THE ARCHITECT AND ENGINEER.
3. REFER TO ARCHITECTURAL DRAWINGS FOR EXACT LOCATION AND MOUNTING INSTRUCTIONS FOR ALL LIGHT FIXTURES. NOTIFY THE ARCHITECT AND ENGINEER OF ANY DISCREPANCIES BETWEEN THESE PLANS AND THE ARCHITECTURAL PLANS RELATING TO QUANTITY, TYPE AND LOCATION OF DEVICES AND/OR FIXTURES.
4. WHEN SPECIFIC LIGHT FIXTURE HAS BEEN SPECIFIED IN THE FIXTURE SCHEDULE, ELECTRICAL CONTRACTOR SHALL PROVIDE COMPLETE ASSEMBLY INCLUSIVE ALL PARTS AND HARDWARE TO INSURE PROPER FUNCTIONING FIXTURE.
5. ALL CONDUCTORS SHALL BE A MINIMUM OF #12 AWG UNLESS NOTED OTHERWISE.
6. ALL 120V RUNS LONGER THAN 60 FEET SHALL BE #10 AWG AND 277V RUNS LONGER THAN 150 FEET SHALL BE #10 AWG UNLESS NOTED OTHERWISE.
7. ALL CONDUCTORS SHALL BE COPPER.
8. WHERE CONDUCTOR SIZES ARE NOTED ON DRAWINGS, THAT WIRE SIZE SHALL BE THROUGH THE ENTIRE RUN UNLESS OTHERWISE NOTED.
9. MOUNTED LIGHT SWITCHES 48" AFF UNLESS NOTED OTHERWISE ON ARCHITECTURAL DRAWINGS.
10. WHERE MORE THAN ONE SWITCH OCCURS IN THE SAME LOCATION, THEY SHALL BE INSTALLED IN A GANG TYPE BOX UNDER ONE COVER PLATE. ALL GANGED SWITCHES SHALL HAVE A COMMON SEAMLESS FACEPLATE. EACH MULTI-GANGED BOX SHALL BE NO MORE THAN SIX (6) SWITCHES WIDE. WHERE MORE THAN SIX (6) SWITCHES ARE SHOWN AT ONE (1) LOCATION, ADDITIONAL MULTI-GANGED BOXES SHALL BE STACKED VERTICALLY AND THE WIDTH OF THE MULTI-GANGS SHALL BE AS EVEN AS POSSIBLE.
11. EACH DIMMER SWITCH SHALL HAVE A WATTAGE RATING 25% HIGHER THAN THE TOTAL WATTAGE OF ALL LIGHTS TO BE CONTROLLED BY THE DIMMER. DIMMER SIZES 600, 1000, 1500, AND 2000 WATTS, LUTRON NOVA T-STAR. WHERE SWITCHES ARE GANGED WITH DIMMERS, THE SWITCHES SHALL ALSO BE LUTRON NOVA T-STAR. FLUORESCENT AND LOW VOLTAGE DIMMERS SHALL BE LUTRON NOVA T-STAR.
12. WHERE FLUORESCENT FIXTURES ARE SHOWN TO BE DIMMED, THE FIXTURES SHALL HAVE DIMMING TYPE BALLASTS WHICH ARE COMPATIBLE WITH THE SPECIFIED DIMMERS.
13. WHERE LED FIXTURES/LAMPS ARE SHOWN TO BE DIMMED, THE DIMMER SHALL BE COMPATIBLE WITH THE FIXTURE/LAMP SPECIFIED OR PROVIDED.
14. ALL EMERGENCY EXIT LIGHT FIXTURES SHALL HAVE 90 MINUTE BATTERY BACKUP WITH INTEGRAL TEST BUTTON AND SHALL BURN CONTINUOUSLY.
15. ALL FLUORESCENT FIXTURES THAT UTILIZE DOUBLE-ENDED LAMPS AND CONTAIN BALLASTS SHALL BE PROVIDED WITH A DISCONNECTING MEANS IN ACCORDANCE WITH NEC 410.136.

**PANEL SCHEDULE**

PANEL:		PP1 WAITING ROOM		VOLTAGE:		208/120, 1Ø, 3Ø, 90A W/ 100A MAIN BREAKER					
LOCATION:		WAITING ROOM		ENCLOSURE:		FLUSH MOUNTED W/ EQUIPMENT GND BAR SQ D TYPE GO LOAD CENTER					
FEEDER SOURCE:		EXISTING PANEL									
CKT NO	THHN WIRE SIZE	LOAD DESCRIPTION LOCATION	BREAKER AMP POLE	LOAD (VA)	AD	BD	LOAD (VA)	BREAKER POLE AMP	LOAD DESCRIPTION LOCATION	THHN WIRE SIZE	CKT NO
1	#12	RECEPTACLES, OFFICE 1 & 2	20 1	1260	●	○	2400	2 30	AIR HANDLING UNIT	#10	2
3	#12	RECEPTACLES, EXAM ROOMS 3 & 4	20 1	1440	●	○	2400	2 30			4
5	#12	RECEPTACLES, EXAM ROOM 5 AND WAITING ROOM	20 1	1260	●	○	1000	2 30	CONDENSER UNIT	#10	6
7	#12	RECEPTACLES, EXAM ROOM 6 AND REST ROOMS	20 1	1080	●	○	1000	2 30			8
9	#12	RECEPTACLES, EXAM ROOM 7 AND RECEPTIONIST	20 1	1080	●	○	1500	1 30	ON DEMAND WATER HEATER	#10	10
11	#12	RECEPTACLES RECEPTIONIST COUNTER	20 1	180	●	○	1500	1 30	ON DEMAND WATER HEATER	#10	12
13	#12	RECEPTACLE RECEPTIONIST COUNTER	20 1	180	●	○	1500	1 30	ON DEMAND WATER HEATER	#10	14
15	#12	LIGHTS, WAITING ROOM AND HALL	20 1	600	●	○	1500	1 30			16
17	#12	LIGHTS, OFFICE 1 & 2 AND EXAM ROOMS 3, 4 & 5	20 1	300	●	○	800	1 20	WATER FOUNTAIN	#12	18
19	#12	LIGHTS, EXAM ROOMS 6 & 7 RESTROOMS AND RECEPTIONIST	20 1	300	●	○			SPACE		20
21		SPACE			●	○			SPACE		22
23		SPACE			●	○			SPACE		24
				TOTAL CONNECTED LOAD (VA) = 14,480				GROUND BUS			
				A φ = 7,480		B φ = 7,000		GROUND WIRE (G)			

**DAMMON ENGINEERING, INC.**  
LOUISIANA & MISSISSIPPI

www.dammonengineering.com  
info@dammonengineering.com  
554 Old Spanish Trail  
Strelitz, LA 70458  
PH: 985-649-5832

REVISIONS

#	DATE	DESCRIPTION

SEAL:

**LSA OULTONS ARCHITECTS**

56684 BOYDSTON ST.  
SLUPELL, LA 70458

JOB No: \_\_\_\_\_ DATE: 04-20-2022  
DRAWN BY: \_\_\_\_\_ CHECKED BY: CJD

SHEET TITLE:  
**LIGHTING PLAN AND PANEL SCHEDULE**

DRAWING NUMBER:  
**E102**

SHEET No: 12 of 12