



**DAMMON**  
ENGINEERING, INC.  
*Architects & Engineers*

554 Old Spanish Trail  
Slidell, LA 70458  
Phone: 985-649-5832  
Fax: 985-641-5950  
dammonengineering.com  
info@dammonengineering.com

May 13, 2015

Mr. David Jones  
Louisiana State Fire Marshal  
8181 Independence Blvd.  
Baton Rouge, LA 70806

RE: PO465406  
Bev, Inc.

Dear Mr. Jones,

I have spoken with the Owner of Bev, Inc. He is aware of the occupancy issue with the second floor of the referenced project as a result of the Occupancy being Construction Type III B.

In an effort to correct this problem, the Owner has issued the attached covenant stating that a sign will be posted prohibiting the total occupancy of the second floor from exceeding 299 persons above the level of exit discharge.

If you have any questions, or require any additional information, please feel free to call.

Sincerely,

Chuck Dammon, VP  
Dammon Engineering, Inc.