

ADDENDUM NO. 1

13 December 2011

Marco's Pizza
9212 West Judge Perez Dr.
Chalmette, LA

1. Coversheet; Changed Sheet A-3 title from "Finished and Ceiling Plan" to "Finish and Ceiling Plan".
2. Sheet A-1;
 - a. Added Note: "No exterior work expect for sign on Sheet E-2 and utilities"
 - b. Added 130 MPH wind requirement to window schedule.
 - c. Revised Door and Door Hardware schedules.
 - d. Labeled "Wall Schedule" legend"
3. Sheet A-2; Added 2 fire extinguishers, and differentiated Type "B" and type "K".
4. Sheet A-3; Revised Room Finish Specifications notes #2 and #3, and revised "Stone Veneer Section"
5. Sheet M-1; Added HVAC key notes #13 and #14 as needed.
6. Sheet E-1; Revised Ansul. System note to read "Install ansul. System (w/ pull station) tight to roof deck"
7. Sheet E-2; Added Electrical Load Summary
8. Sheet P-1;
 - a. Added grease trap detail
 - b. Revised Plumbing fixture schedule water heater description.
 - c. Added spec for toilet room grab bars to restroom elevations.
 - d. Added note to indicate deck and water heater above mop sink.