

DAMMON ENGINEERING, INC.

dammonengineering.com

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

554 Old Spanish Trail
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

January 3, 2012

To: Gwendolyn Shook, R.S., M. Ed
Sanitarian Parish Manager
State of Louisiana DHH
St. Bernard Parish Health Unit
3002 Jean Lafitte Pkwy.
Chalmette, LA 70043

REF: Marco's Pizza
9212 W. Judge Perez Dr.
Chalmette, LA 70043

Dear Ms. Shook,

Please see the below responses to your plan review question letter dated December 21, 2011:

1. Questionnaire number 3,4, and 7;
3: Mailing address will be the same as physical address.
4: Owner of business: please contact Bobby Curtis. Cell: 1-504-416-6689
7: Phone numbers of business owner: please contact Bobby Curtis.
2. A hand washing station is provided near the kitchen entrance from Dining area. Please see Sheet A-2 equipment label #12.
3. All food equipment, 3 compartment sinks, cooler drain, etc. are provided with a hub drain connection with air gap. Please see detail on bottom left of sheet P-2.
4. Shielding to protect against broken glass falling onto food shall be provided for all artificial lighting fixtures located over, by, or within food storage, preparation service, display facilities, and facilities where utensils and equipment are stored. (3707-A.) All artificial lighting fixtures have a protective cover to shield against falling broken glass. These light fixtures are marked with an 'A' on Sheet A-3.
5. The walls and ceilings in the food preparation areas, of walk in refrigeration units, equipment washing and utensil washing areas, toilet rooms and vestibules shall be light colored, smooth non-absorbent, and easily cleanable. Concrete or pumice blocks shall be Finished and sealed to provide an easily cleanable surface for the interior walls. (3703-A.) Please see Sheet A-3 for finish schedule.
6. Marco's Pizza will utilize the existing dumpster pad and service for the shopping center. The tenant has an agreement with the current service provider to include cleaning services for the dumpster.

Sincerely,
Brandon Nowakowski
Dammon Engineering