


**STATE of LOUISIANA  
OFFICE of PUBLIC HEALTH  
EAST BATON ROUGE PARISH  
HEALTH UNIT**



**Facsimile Transmission Cover Sheet**

Fax Number: 985 6415950 Date: 1.25.07

Attention: DAVID DAMMON Company: \_\_\_\_\_

From: LAKEISHA THERLOT

Phone Number: 225-242-4870 Fax Number: 225-342-5157

Number of Pages (including coversheet): 2

Message: QUIZNO'S # 11446 APPROVAL

**Environmental Health Services 353 North 12<sup>th</sup> Street Baton Rouge, LA 70802**

**PRIVACY AND CONFIDENTIALITY WARNING:**

This Facsimile may contain Protected Health Information, Individually Identifiable Health Information and other information which is protected by law. The information is intended only for the use of the intended recipient. If you are not the intended recipient, you are hereby notified that any review, disclosure/re-disclosure, copying, storing, distributing or the taking of action in reliance on the content of this facsimile and any attachment thereto, is strictly prohibited. If you have received this in error, please notify the sender immediately and destroy the contents of this facsimile.



Kathleen Babineaux Blanco  
GOVERNOR

STATE OF LOUISIANA  
DEPARTMENT OF HEALTH AND HOSPITALS



Frederick P. Corliss, M.D., M.P.H.  
SECRETARY

December 15, 2006

RE: #259538

Quizno's  
20377 Old Scenic Hwy.  
Zachary, LA. 70791


Dear Mr. Borskey,


Plans and Specifications for the above named project have been reviewed and found to be in substantial conformity with applicable provisions of the State Sanitary Code. This plan approval refers to sanitary features of the design of the floor plan only, and it is not to be taken as an approval of structural details, except insofar as they may affect sanitation.

**If a design error escapes our detection, that oversight shall not relieve you of the responsibility of complete compliance with the requirements of the State Sanitary Code.**

This plan approval is automatically cancelled if construction of the project has not been started within two (2) years after the date of this letter.

Please feel free to call me at 225-242-4918 to schedule a day and time for a pre-opening inspection and permitting for the above referenced project. The owner or a corporate member must be available to sign the permit application between 9:00AM-3:00PM on the date specified.

Sincerely,  
  
Heather L. Gray, R.S.  
Sanitarian 3

Approved by:   
LaKeisha D. Theriot, R.S.  
Assistant Sanitarian Manager 4 /Parish

LT/HLG/hg

cc: City Parish Commercial Plans Dept.

**STATE OF LOUISIANA**  
Department of Public Safety and Corrections  
Office of State Fire Marshal Code Enforcement and Building Safety  
8181 Independence Boulevard  
Baton Rouge, Louisiana 70806  
225-925-4920

HENRY H. FRY  
DEPUTY ASSISTANT SECRETARY

**NEW CONSTRUCTION**

EDWARD GREMILLION, P E, C E  
DAMMON ENGINEERING, INC  
1095 FLORIDA AVE  
SLIDELL, LA 70458-0000

RE: P0320387  
QUIZNOS 11446 STE 100  
20377 OLD SCENIC HWY  
ZACHARY, LA 70791

NFPA 101, 2003  
MERCANTILE CLASS C

Dear Applicant:

This is to advise that we have reviewed the drawings and specifications for the subject proposed construction and have determined that they appear to satisfactorily comply with the adopted laws, codes, rules and regulations of The State Fire Marshal subject to the following requirements:

1. **Contact the local building official of the applicable local political subdivision to coordinate compliance with State Uniform Construction Code requirements. LRS 40:1730.23 mandates the enforcement of building codes by municipalities and parishes in Louisiana, as described by LRS 40:1730.28. LRS 40:1730.27 mandates the adoption and enforcement of emergency wind and flood mitigation for the coastal region of Louisiana (effective February 28, 2006).**

NOTE: THE FOLLOWING COMMENTS IDENTIFY ISSUES FOR INFORMATIONAL AND CAUTIONARY PURPOSES OR ISSUES THAT COULD NOT BE VERIFIED IN THE SUBMITTED DOCUMENTS.

2. **LRS 40:1731-(Effective 8/15/95) Provide handicapped accessibility in accordance with ADA-AG (Accessibility Guidelines - September 1994). This does not include a review for compliance with the Federal Americans with Disabilities (Civil Rights) Act of 1990. Compliance with state regulations and requirements does not guarantee compliance with federal law. Particular deficiencies and paragraph references are noted as follows:**
  - a) 4.19 Lavatories shall comply with the following:
    1. 4.19.2 Lavatories shall be mounted with a clearance of at least 29" from the floor to the bottom of the apron. Knee and toe clearances shall comply with Fig. 31.
    3. 4.19.5 and 4.27.4 Faucets shall not require tight grasping, pinching, or twisting of the wrist to operate.

efir  
1 b6  
ripp  
e sign:  
occupie  
itions.  
Dec 29, 20  
387 - PAGE 1