

# Dammon Engineering, Inc.

dammonengineering.com

1095 Florida Ave.  
Slidell, LA 70458

P.O. Box 2830  
Slidell, LA 70459

985-649-5832  
FAX 985-641-5950

June 4, 2010


Mr. Tim Piere'  
Jefferson Parish  
Inspection & Code Enforcement  
1221 Elmwood Park Boulevard, Suite 101  
Jefferson, La 70123

RE: Paul Mitchell School  
3321 Hessmer Ave.  
Metairie, La.

Dear Mr. Piere'

The elevator room located on the 2<sup>nd</sup> floor of the building is an existing room that has been updated to fit the needs of the current occupant. All the existing elevator controls have been replaced with new. The hot water system is new also to provide the user with on demand needs. The walls are one hour rated surrounding the elevator room and water heater room with a fresh air supply being served from the elevator equipment room utilizing the existing fresh air vents on the exterior of the wall. Dammon Engineering approves of this method for this use.

Sincerely,

  
Chuck Dammon  
V/P Project Manager