

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

H "BUTCH" BROWNING
FIRE MARSHAL

BUILDING REHABILITATION

KEVIN KINCHEN
DAMMON ENGINEERING. INC.
554 OLD SPANISH TRAIL
SLIDELL, LA 70458-0000

RE: P0459448
TEXTRON MARINE NEW OFFICE
ADDITION
252 STONE RD
SLIDELL, LA 70458

NFPA 101, 2012
IBC, 2012 (CHAPTERS 9 & 10)

INDUSTRIAL
BUSINESS

Dear Applicant:

This is to advise that we have reviewed the drawings and specifications for the subject proposed construction and have determined that they appear to satisfactorily comply with the adopted laws, codes, rules and regulations of The State Fire Marshal subject to the following requirements:

1. **Scope of Work:** This review is for a new 6,117 sf office addition to an existing 161,309 sf industrial facility. There will be a two hour fire wall (double fire wall per NFPA 221) between existing and new construction. The scope of work is classified as Additions per IEBC Section 507.

Classification of Work: New Construction / Additions
Construction Type: II-B
Sprinkler system: Yes
Fire Alarm System: Yes

LSC:
BUSINESS

IBC:
BUSINESS Group B

IEBC 507.1 Scope. Provisions for additions shall apply where work is classified as an addition as defined in Chapter 2.

IEBC 507.2 Application. Additions to existing buildings shall comply with the provisions of Chapter 11.

IEBC 1101.1 Scope. An addition to a building or structure shall comply with the International Codes as adopted for new construction without requiring the existing building or structure to comply with any requirements of those codes or of these provisions, except as required by this chapter. Where an addition impacts the existing building or structure, that portion shall comply with this code.

Jan 22, 2015
P0459448 - PAGE 1

IEBC 1101.2 Creation or extension of nonconformity. An addition shall not create or extend any nonconformity in the existing building to which the addition is being made with regard to accessibility, structural strength, fire safety, means of egress, or the capacity of mechanical, plumbing, or electrical systems.

IEBC 1103.1 Compliance with the International Building Code. Additions to existing buildings or structures are new construction and shall comply with the International Building Code.

IEBC 1103.2 Additional gravity loads. Existing structural elements supporting any additional gravity loads as a result of additions shall comply with the International Building Code.

101:4.6.10.1 Buildings or portions of buildings shall be permitted to be occupied during construction, repair, alterations, or additions only if all means of egress and all fire protection features are in place and continuously maintained for the portion(s) occupied.

This review applies to new work indicated in the drawings and does not apply to existing non-conforming conditions.

2. **LRS 40:1730.45.A and LAC 55:V:2601** The documentation provided for the subject facility appears to comply with The Commercial Building Energy Conservation Code based on ANSI/ASHRAE/IESNA 90.1- 2007.

NOTE: THE FOLLOWING COMMENTS IDENTIFY ISSUES FOR INFORMATIONAL AND CAUTIONARY PURPOSES OR ISSUES THAT COULD NOT BE VERIFIED IN THE SUBMITTED DOCUMENTS.

3. **LRS 40:1731-(Effective 10/01/11)** Provide access for persons with disabilities in accordance with the ADA-ABA Accessibility Guidelines, July 23, 2004 (also known as the 2010 Standards). This does not include a review for compliance with the Federal Americans with Disabilities (Civil Rights) Act of 1990. NOTE: As per ADA-ABA 2004, Section F103, Office of State Fire Marshal appeal determinations are not valid for facilities that are designed, constructed, altered, or operated with federal funds, or leased by a federal agency. The authority having jurisdiction over such appeals is the administrator of the General Services Administration (GSA). Compliance with state regulations and requirements does not guarantee compliance with federal law.

"CAUTIONARY/INFORMATIONAL" items and paragraph references are noted as follows:

- a. **606.1 Lavatories in toilet rooms and breakroom/conference room sinks shall comply with the following:**
 1. **606.2 Provide a clear floor space complying with 305, positioned for a forward approach, and knee and toe clearance complying with 306 shall be provided.**
 2. **606.3 Lavatories and sinks shall be installed with the front of the higher of the rim or counter surface 34 inches maximum above the finish floor or ground.**
 3. **606.4 and 309 Controls for faucets shall not require tight grasping, pinching, or twisting of the wrist.**
 4. **606.5 Water supply and drain pipes shall be insulated or covered.**
- b. **604.1 Water closets and toilet compartments shall comply with 604.2 through 604.8 as follows:**

1. 604.2 The centerline of the water closet shall be 16 inches (405 mm) minimum to 18 inches (455 mm) maximum from the nearest adjacent wall (17 inches (405 mm) minimum to 19 inches (455 mm) maximum in an ambulatory accessible toilet compartment specified in 604.8.2).

2. 604.3.1 Provide a clearance around the water closet that complies with Figure 604.3.1. (NOTE: As per 604.3.2 No other fixtures or obstructions shall be located within the required water closet clearance.)

3. 604.4 The seat height above the finish floor shall be 17" minimum to 19" maximum to the top of the seat.

4. 604.5 Grab bars for water closets shall comply with 609. (Provide a 42" long grab bar adjacent to the toilet and a 36" long grab bar behind the toilet.)

5. 604.6 Flush controls shall be located on the open side of the water closet.

6. 604.7 Toilet paper dispensers shall comply with Figure 604.7.

7. 604.8 Wheelchair accessible toilet compartments shall meet the requirements of 604.8.1 through 604.8.3 as follows:

a. 604.8.1 Wheelchair Accessible Compartments

1) 604.8.1.1 Wheelchair compartments shall be sized in accordance with Figure 604.8.1.1.

2) 604.8.1.2 Toilet compartment doors, including hardware, shall comply with Section 404 and located in accordance with Figure 604.8.1.2.

3) 604.8.1.3 Compartments shall be arranged for a left-hand or right-hand approach to the water closet.

4) 604.8.1.4 Provide toe clearance in accordance with Figure 604.8.1.4.

5) 604.8.1.5 Grab bars shall comply with Section 609. (Provide a 42" long grab bar adjacent to the toilet and a 36" grab bar behind the toilet.)

b. 604.8.3 Coat hooks shall be located within one of the reach ranges specified in Section 308 and shelves shall be located 40" minimum and 48" maximum above the finish floor.

c. 216.2 Where signage identifies permanent rooms or spaces OR EXITS, the signage shall comply with Sections 703.1 - 703.5 (raised characters, Braille, visual characteristics, height).

d. 302 Floor and ground surfaces shall be stable, firm, and slip-resistant.

e. 303 Thresholds shall comply with requirements of this section regarding changes in level. (Not more than 1/2" height and beveled if over 1/4")

f. 308.1 Reach ranges shall comply with 308 as follows:

1. 308.2.1 Where a forward reach is unobstructed, the forward reach shall comply in accordance with Figure 308.2.1.

2. 308.2.2 Where a high forward reach is over an obstruction, the forward reach shall comply in accordance with Figure 308.2.2.

3. 308.3.1 Where a clear floor or ground space allows a parallel approach to an element and the side reach is unobstructed, the high reach shall comply in accordance with Figure 308.3.1.

4. 308.3.2 Where a clear floor or ground space allows a parallel approach to an element and the high side reach is over the obstruction, the height of the obstruction shall be 34" maximum and the depth of the obstruction shall be 24" maximum with a high side reach in accordance with Figure 308.3.2.

g. 404.2.7 Handles, pulls, latches, locks, and other operable parts on doors and gates shall comply with 309.4. Hardware shall not require tight grasping, tight pinching, or twisting of the wrist to operate.

4. LAC 55:305 Insulation and insulation assemblies shall meet the requirements of Section 720, International Building Code, 2012 Edition.

a) Concealed and exposed insulation shall have a flame spread of 0-25 and a smoke developed of 0-450 in accordance with IBC 720.

5. Modifications to the existing sprinkler system shall be in accordance with NFPA 13, 13R or 13D as applicable.
6. LRS 40:1574 Submit automatic sprinkler system shop drawings with plan review application, SPRINKLER SYSTEM REVIEW CHECKLIST & FEE SCHEDULE dated 01-20-13, and fee prior to installation of any work to this system.

Note: See Interpretive Memorandums 2013-02 and 2013-03 for submittal requirements.

Sprinkler shop drawing submittals are required to be reviewed by the professional of record/owner before being submitted to the Office of State Fire Marshal plan review section. Shop drawings reviewed by the professional of record shall bear his/her shop drawing review stamp indicating reviewed/no exceptions taken. See Interpretive Memorandum 2013-02. In order to expedite the review process, requests by the SFM reviewer for additional information will be sent both to the professional of record/owner and the sprinkler contractor. Contractor will be permitted to respond back to the SFM reviewer and copy the professional of record/owner with their response. Additional information will not require a shop drawing review stamp. Note: this does not include the response sent as a result of Request for Information letter.

Be advised that a sprinkler system that satisfies the requirements of NFPA 101 Life Safety Code, NFPA 13, NFPA 13R and/or NFPA 13D may not necessarily be considered by the building insurance underwriters as "full coverage" or "fully sprinklered", for insurance purposes.

NFPA 13:4.3, 23.1.4 (2013 edition) Complete and submit owner's information certificate to system designer in order to identify special occupancies and commodity classifications before start of design. Form can be found in the SFM website/Building Safety/Sprinklers (<http://sfm.dps.louisiana.gov/>).

NFPA 13:10 Underground piping shall be installed in accordance with chapter 10. See 10.6 for specific requirements for piping run under buildings.

Cities, Parishes and Water Purveyors (for example Baton Rouge Water Works Company) may have requirements for meters, single detector check valves, and double check and RPZ valves to be installed near the public water supply. These valves while not necessarily required by NFPA 13 are required to be listed for fire protection service when installed. The pressure loss across these valves is to be included in the sprinkler system calculations. Please verify that supporting documentation for these valves and meters are included with the sprinkler shop drawing submittal.

NFPA 25:4.1.2* Accessibility. The property owner or occupant shall provide ready accessibility to components of water-based fire protection systems that require inspection, testing, or maintenance.

7. 101:7.2.1.5 and IBC 1008.1.9 Locks on doors in means of egress shall not require the use of a key, special device or special knowledge to open in the direction of egress.
8. 101:7.2.1.5.10.2 and IBC 1008.1.9.4 through 1008.1.9.5 Doors shall be openable with ONLY one releasing operation. A two-step release, such as a knob and an independent slide bolt, is NOT acceptable, except under special conditions.

9. 101:7.5.2.1 and IBC 1014.2 Egress shall not be through a room subject to locking in the direction of egress.
10. 101:8.2.2.3 Fire compartments shall be formed with fire barriers that comply with Section 8.3 and are continuous in accordance with Section 8.3.1.2 from outside wall to outside wall or from one fire barrier to another, or a combination thereof, including continuity from the floor through all concealed spaces, such as those found above a ceiling, including interstitial spaces. Continuity is permitted to terminate at a ceiling, if the construction assembly of the ceiling has a fire resistance rating not less than that of the fire barrier.
11. 101:8.3.5 Penetrations through rated construction shall be sealed by approved firestop systems or devices tested in accordance with ASTM E-814 or ANSI/UL 1479.
 - a) Notify the District Office identified at the end of this letter for inspection of all completed fire and/or smoke barrier walls before any construction is installed that would conceal such construction and prevent a proper inspection. Access to randomly selected areas may be required by the inspector at time of final inspection if this notification is not given.
 - b) Provide detailed instructive cut sheets of the fire penetration sealing system used to the inspector at time of inspection. Random selective sampling by the contractor will be observed by the inspector.
12. 101:38.3.3 Interior walls and ceilings shall have a flame spread of 0-200 and a smoke development rating of 0-450.
13. Modifications to the existing fire alarm system shall be in accordance with NFPA 101, NFPA 72, ADA-ABA, and IBC.
14. LRS 40:1574 Submit fire alarm system shop drawings with plan review application and fee prior to installation of any work of this section. Such work shall not commence until shop drawings have been found to be in compliance with applicable codes by this office. The submittal shall include a copy of this letter and shall be in accordance with the submittal requirements outlined in the memorandum dated June 24, 1993 which was distributed from this office to all state licensed fire alarm contractors, architects and engineers. Specify the "Type of Signaling System" to be utilized, identify the monitoring station, describe the evacuation system ("zoned" or "general"), and include information concerning the means of protecting fire command centers, circuitry, and other essential equipment, such as may be required for high-rise buildings, as applicable.
15. 101:38.5.1 Utilities shall comply with the provisions of Section 9.1.
16. HVAC system shall be constructed in accordance with 101:9.2.
17. 101:9.2.1 Install smoke detectors to automatically stop the fan in HVAC duct systems over 2000 cfm in accordance with NFPA 90A:6.4.2.1(1). Where fire alarm system is required, duct detectors shall be connected to building alarm system.
18. LRS 40:1664.4 All work and inspections of LIFE SAFETY AND PROPERTY PROTECTION SYSTEMS and equipment shall be performed by a contractor licensed with the appropriate endorsement by the Office of the State Fire Marshal.
19. LRS 40:1664.4 All work and inspections of portable fire extinguishers shall be performed by a life safety and property protection contractor licensed with the appropriate endorsement by the Office of the State Fire Marshal. Portable fire extinguishers shall be certified annually.
 - a) For Inspection, see NFPA 10:7.2
 - b) For Maintenance, see NFPA 10:7.3

- c) For Recharging, see NFPA 10:7.4
20. Shop drawings for fire protection systems, such as Fire Alarm, Sprinklers, and Suppression Systems, that are required to be submitted to this office for review, shall be routed through the "Professional of Record's" (Architect / Engineer) office, and shall be stamped with his "Shop Drawing Review Stamp" or equivalent, indicating that shop drawings have been reviewed by him for conformance with plans, specifications, and appropriate codes.

NOTE: THE FOLLOWING IS A REVIEW FOR COMPLIANCE WITH THE REQUIREMENTS OF THE LOUISIANA STATE UNIFORM CONSTRUCTION CODE IN ACCORDANCE WITH ACT 12 OF THE 2005 FIRST EXTRAORDINARY SESSION OF THE LOUISIANA LEGISLATURE. THIS REVIEW IS PERFORMED AT THE REQUEST OF, AND ON BEHALF OF THE JURISDICTION IN WHICH THIS PROPOSED PROJECT IS LOCATED.

This office will not be responsible for inspections to certify compliance with applicable requirements. Contact the local Building Official or a Louisiana State Uniform Construction Code Council certified third-party provider to arrange for inspections.

Codes Referenced:

- 2012 International Building Code (IBC) not including Chapters 1, 11, 27, and 29;
- 2012 International Existing Building Code (IEBC) not including Chapter 1;
- 2012 International Mechanical Code (IMC);
- 2013 Louisiana State Plumbing Code (LSPC);
- 2012 International Fuel Gas Code (IFGC);
- 2011 National Electric Code (NEC)

21. **Building Planning:**

a) **Special Occupancy Areas:**

There are NO special detailed requirements.

b) **Accessory Use Areas:**

There is NO accessory occupancy per IBC Section 508.2.

c) **Incidental Use Areas:**

There is NO incidental use area per IBC Section 509.

d) **Construction Type/Building Limitations:**

The construction type is indicated to be Type II-B per IBC Section 602.

The proposed construction IS WITHIN the allowable height and area limitations of Table 503.

22. **Fire-Resistance-Rated Construction and Interior Finishes:**

a. Interior walls and ceiling finishes at interior exit stairways, interior exit ramps and exit passageways shall be Class B: Flame spread 0-75 smoke-developed 0-450.

b. Interior walls and ceiling finishes at corridors and enclosure for exit access stairways and exit access ramps shall be Class C: Flame spread 0-200; smoke-developed 0-450.

c. Interior walls and ceiling finishes at rooms and enclosed spaces shall be Class C: Flame spread 0-200; smoke-developed 0-450.

d. Wood used in Type I or Type II construction shall be limited to the conditions specified in IBC Section 603.1 and shall be fire-retardant-treated.

e. Fire wall(s) shall be constructed in accordance with Section 706. The fire-resistance rating shall be not less than 2 hours per Section 706.4. **DOUBLE FIRE WALLS SHALL BE CONSTRUCTED IN ACCORDANCE WITH NFPA 221.**

23. **Fire Protection Systems:**

Refer to Life Safety Code review above for fire protection system requirements.

24. **Means of Egress:**

a) Refer to Life Safety Code review above for means of egress requirements.

25. **Structural:**

The following design loads and other information pertinent to the structural design required by IBC Sections 1603.1.1 through 1603.1.8 shall be indicated on the construction documents, per IBC 1603.1:

a) **Gravity Load Data:**

Minimum live loads shall be in accordance with IBC Table 1607.1 or ASCE 7-10 Table 4-1

Minimum Snow loads shall be in accordance with IBC Fig. 1608.2 or ASCE 7-10 Fig. 7.1.

- First Floor live loads are indicated as 50 psf.

- Roof live loads are indicated as 20 psf.

- Ground Snow loads are indicated as 5 psf.

b) **Wind Design Data:**

Wind loads on every building or structure shall be determined in accordance with Chapters 26 to 30 of ASCE 7-10, per IBC 1609.1.1.

- Ultimate Design Wind Speed, Vult (3-second gust) is indicated as 141 MPH; [IBC 1609.3.1 and/or ASCE 7-10 Figure 6-1]

- Nominal Design Wind Speed, V_{sd} is NOT indicated, SEE ATTACHED LETTER FROM POR; [IBC 1609.3.1 and/or ASCE 7-10 Figure 6-1]

- Risk category is indicated as II; [IBC Table 1604.5 and/or ASCE 7-10 Table 1-1]

- Wind exposure category is indicated as B; [IBC Section 1609.4.3]

- The internal pressure coefficient is indicated as +/- 0.18; [ASCE 7-10 Figure 6-5]

- Design wind pressures used for the design of exterior components and cladding are 33.6 psf.

Protection of openings for wind-borne debris is required.

c) **Flood Design Data:**

The flood hazard area established for the site is identified as Zone AE; [IBC 1603.1.6]

For buildings located in whole or in part in flood hazard areas as determined by the local flood plain administrator, the following information referenced to the datum on the Flood Insurance Rate Map (FIRM) shall be shown on the construction documents, regardless of whether flood loads govern the design of the building:

- The elevation of the proposed lowest floor is indicated as 13.67 NAVD.

- The base flood elevation, BFE, is indicated as 9.0 NGVD.

26. **Mechanical Systems:**

a) Attics containing appliances requiring access shall be provided with an opening and unobstructed passageway large enough to allow removal of the largest appliance in accordance with this section. The clear access opening dimensions shall be a minimum of 20 inches by 30 inches, where such dimensions are large enough to allow removal of the largest appliance, per IMC Section 306.3.

b) Provide a lighting fixture in the Mechanical room, controlled by a switch located at the access opening. A receptacle outlet shall be provided at or near the appliance/equipment location, per IMC Section 306.3.1.

c) The minimum ventilation rate of outdoor air shall be determined in accordance with Section 403.3.

d) The ventilation air distribution system shall be provided with means to adjust the system to achieve at least the minimum ventilation airflow rate required. Ventilation systems shall be balanced by an approved method. Such balancing shall verify that the ventilation system is capable of supplying the airflow rates required by Section 403, per IMC 403.7.

27. Plumbing Systems:

Review for compliance with the requirements of the Louisiana State Plumbing Code [Part XIV (Plumbing) of the State Sanitary Code] is performed at the request of the jurisdiction in which this proposed project is located AND on behalf of the State Health Officer. In accordance with R.S. 40:4.A(7), R.S. 40:5, and R.S. 40:1730.28.A(5), the State Health Officer and the Office of Public Health of the Department of Health and Hospitals holds the exclusive jurisdiction, control, and authority over Part XIV (Plumbing) of the State Sanitary Code. Interpretations and/or adjustments to the requirements contained in this code should be directed to that department for ruling.

NO APPARENT DEFICIENCIES DETECTED

28. Fuel Gas: NO NEW WORK INDICATED, NOT REVIEWED

29. Electrical Systems:

a) A 125-volt, single-phase, 15- or 20-ampere-rated receptacle outlet shall be installed at an accessible location for the servicing of heating, air-conditioning, and refrigeration equipment. The receptacle shall be located on the same level and within 25 ft of the heating, air-conditioning, and refrigeration equipment. The receptacle outlet shall not be connected to the load side of the equipment disconnecting means.

b) Attics containing equipment requiring servicing, such as heating, air-conditioning, and refrigeration equipment, at least one lighting outlet containing a switch or controlled by a wall switch shall be installed in such spaces. At least one point of control shall be at the usual point of entry to these spaces. The lighting outlet shall be provided at or near the equipment requiring servicing.

c) Provide a disconnecting means for air-conditioning and refrigerating equipment, in accordance with NEC 440.12.

30. NOTE: Please IDENTIFY THIS PROJECT NUMBER WITH FUTURE SUBMITTALS OR OTHER CORRESPONDENCE pertaining to this project.

Changes to construction in the field which are not consistent with the reviewed documents are not authorized unless reviewed by this office for compliance with Code. Modifications to reviewed plans must be submitted to this office by the Architect/Civil Engineer for review prior to final inspection. If an Architect or Civil Engineer is not required by RS 37:155, revisions shall be submitted by the Owner. Submittals shall include plans, completed application, a minimum \$55.00 review fee, and a copy of the most current plan review letter.

Compliance with code requirements for fire protection systems, such as Fire Alarm, Sprinkler and Suppression Systems, is determined by separate shop drawing submittal and is not included in this review.

This review applies to work indicated in the drawings or specifications. Existing portions of the facility or building unaffected by the new work shall comply with LAC 55:103B.

This review shall in no way permit and/or authorize any omissions or deviations from the specific requirements of the adopted codes, rules and regulations in accordance with R.S. 40:1574.1(B).

This review is valid for 180 days from the date of this letter. Construction permits must be issued and/or construction must commence within this time period.

This office requires certification of the completed project in accordance with the approved documents (certificate enclosed).

Occupancy of the project will not be permitted until we receive the completed certificate and a satisfactory inspection of the completed construction has been made by this office.

To arrange for inspection of the project, please contact the District Office at the phone number below two (2) to three (3) weeks in advance. The plans stamped reviewed by this office must be available on job site at time of inspection. Certificate of completion must be provided to the inspecting Deputy for final inspection.

REVIEWED BY:
DAVID JONES
ARCHITECT

NOTE: Please call the REVIEWER identified above if you have any questions regarding this review.
Do not call the Inspection Office until you are ready for inspection.

CC:
Textron Marine & Land
St Tammany Fire Protection District No 1*
City Of Slidell*
New Orleans District Ofc* 5045688506

David Jones (DPS)

From: Kevin Kinchen <kevinkinchen2013@gmail.com> on behalf of Kevin J. Kinchen, NCARB <kevin@dammonengineering.com>
Sent: Thursday, January 22, 2015 9:14 AM
To: David Jones (DPS)
Subject: RE: Plan Review Letter PO459448
Attachments: Scan 01_2015012209093800.pdf; HOLD LETTER.DOC

David,

Please find attached our response letter and your letter dated December 4.

Kevin J. Kinchen, NCARB

Chief Architect
Dammon Engineering, Inc.
Architects & Engineers
554 Old Spanish Trail
Slidell, La. 70458
985.649.5832

LA. S.F.M. PLAN REVIEW
PO# 459448 REVIEWER 459
READING FILE DATE MO 01 YR 15
ORIG TO: _____
SENDER APPL. _____ OWNER _____
CC'S _____
COPY WHAT PGS. Copy to file
B.R. _____ N.O. _____ ALEX _____ LAF. _____
SHREVE _____ HO FILE _____ HO DEPT. _____
DET FILE _____ HR FILE _____ NON-REQ. SYST. _____
OTHER _____

From: David.Jones@dps.la.gov [mailto:David.Jones@dps.la.gov]
Sent: Wednesday, January 21, 2015 8:39 AM
To: kevin@dammonengineering.com; DAMMONENG@BELLSOUTH.COM
Subject: Plan Review Letter

RECEIVED

JAN 21 2015

STATE OF LOUISIANA
ARCHITECTURAL SECTION

January 22, 2015

David Jones
Architect
Office of State Fire Marshal
8181 Independence Blvd.
Baton Rouge, LA 70806

RE: **TEXTRON New Office Addition PO459448**
DE Project No. 2203

Dear Mr. Jones,

Pursuant to your hold letter dated December 4, 2014 we are providing the following responses:

Items 1 A & B:

We will utilize option B by separating the new office addition from the existing F-1 area with a fire wall in compliance with Section 706 by upgrading the existing 6" thick tilt-up exterior concrete wall to an 1-hour equivalent fire rating by replacing the existing caulking material with fire-stop and fire-caulk and the addition of a 1-hour fire barrier (UL # V497) on the new office addition. There will be no connections or penetrations between the two rated walls per NFPA 221.

The two fire barriers will terminate at the interior surface of noncombustible exterior sheathing per IBC 2012 Section 706.5, Exception 3 as both buildings will be protected by an automatic sprinkler system installed in accordance with Section 903.1.1 or 903.1.2.

**CONSTRUCTION SHALL ALSO MEET
NFPA 221 REQUIREMENTS**

Item 1 C:

See sheet G2 under the Wind Speed Design Requirements. All design loads are addressed.

Item 1 D:

- 1. See sheet G2 under the Wind Speed Design Requirements. Basic Wind Speed (3 Second Gust) = 141 MPH (Fig 1609) is the Vult wind speed for this project. A revision of this page will replace the word Basic with the word Vult.*

459448
**REVIEWED FOR
STATE FIRE MARSHAL
AS PER REVIEW LETTER
BY: WILLIAM D. JONES, ARCHITECT, CBO**
William D. Jones
1/22/15

DAMMON

ENGINEERING, INC.
Architects & Engineers

554 Old Spanish Trail
Slidell, LA 70458
P 985.649.5832
F 985.641.5950
www.dammonengineering.com
info@dammonengineering.com

2. IBC 2012 Section 1609.1.1 states: "The wind speeds in Figures 1609A, 1609B and 1609C are ultimate design wind speeds, V_{ult} , and shall be converted in accordance with Section 1609.3.1 to nominal design wind speeds, V_{asd} when the provisions of the standards referenced in Exceptions 1 through 5 are used." This project is not utilizing any of the Exceptions 1 through 5, therefore V_{asd} is not required.

Please let me know if this answers all your questions.

Sincerely,



Kevin J. Kinchen, NCARB
Chief Architect
Dammon Engineering, Inc.

Enclosures: SFM Hold Letter, December 4, 2014
CC: file

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

H "BUTCH" BROWNING
FIRE MARSHAL

**INFORMATION REQUEST
NOT - FOR - PERMITTING**

KEVIN KINCHEN
DAMMON ENGINEERING, INC.
554 OLD SPANISH TRAIL
SLIDELL, LA 70458-0000

RE: P0459448
TEXTRON MARINE NEW OFFICE
ADDITION
252 STONE RD
SLIDELL, LA 70458

NFPA 101, 2012
IBC, 2012 (CHAPTERS 9 & 10)

INDUSTRIAL
BUSINESS

Dear Applicant:

Additional information is required to perform a proper review. The project referenced above is being held pending submission of the following information:

NOTE: THE COMMENTS LISTED BELOW IDENTIFY APPARENT DEFICIENCIES DETECTED IN OUR REVIEW OF THE DOCUMENTS SUBMITTED.

1. **RS 40:1574 and/or RS 40:1730.39.A Additional drawings and/or specifications are required:**
 - A. **Per sheet G2, the construction type is indicated to be Type II-B. The area is indicated to be unlimited per Section 507. Section 507.3 permits unlimited construction when the building is surrounded by yards of not less than 60 feet. At the southwest corner and south elevation of the existing building, approximately 545 lf of exterior wall falls within the 60 ft "restricted " area, therefore this structure does not comply with Section 507.3.**

Section 507.5 permits a reduction of the 60 ft yards to 40 ft if the requirements of 507.5(1) thru 507.5(3) are met. **CANNOT BE DETERMINED WITHOUT ADDITIONAL INFORMATION. PROVIDE DOCUMENTATION THAT THESE REQUIREMENTS ARE BEING MET.**
 - B. **AN OPTION TO MEETING THE ABOVE REQUIREMENTS MAY BE TO SEPARATE THE NEW OFFICE AREA FROM THE EXISTING F-1 AREA WITH A FIRE WALL IN COMPLIANCE WITH SECTION 706.**

Structural Design Data: (May also be indicated on the structural drawings)

C. Design loads must be included within the construction documents in a manner such that the design loads are clear for all parts of the structure [IBC Section 1603]. This information is required on ALL projects regardless of the involvement of a registered design professional.

Wind Design Data:

D. Indicate the following:

1. Ultimate design wind speed, Vult (3-second gust) miles per hour for the site location [IBC Section 1609.3.1]

2. Nominal design wind speed, Vasd (3-second gust) miles per hour for the site location [IBC Section 1609.3.1]

2. NOTE: Please IDENTIFY THIS PROJECT NUMBER WITH FUTURE SUBMITTALS OR OTHER CORRESPONDENCE pertaining to this project.

Due to the lack of information, the referenced project has NOT been reviewed. Please direct the requested information to my attention. Processing will continue upon receipt of the information requested above. Enclose a copy of this letter with future submittals and/or other correspondence pertaining to this project.

This project will be returned as "NOT IN COMPLIANCE" if the requested information is not received by this office within 21 days of the date of this letter, thereby requiring a RESUBMITTAL of the entire project along with a new completed application and appropriate review fee.

CONSTRUCTION IS NOT AUTHORIZED until a satisfactory review has been performed and a formal review letter has been issued by this office.

REVIEWED BY:
DAVID JONES
ARCHITECT

NOTE: Please call the REVIEWER identified above if you have any questions regarding this review.
Do not call the Inspection Office until you are ready for inspection.

CC:
Textron Marine & Land
St Tammany Fire Protection District No 1*
City Of Slidell*