



**ELECTRICAL CONDUIT PLAN**  
SCALE: 1/4" = 1'-0"

- NOTE:**
- FURNISH & INSTALL ONE 90A, 2-P BREAKER IN EXISTING MCC, TO POWER NEW QUIET ROOM PANEL LPA. DO NOT CONNECT TO "STINGER" LEG.

These plans and specifications have been prepared by me or under my close personal supervision, and to the best of my knowledge and belief, they meet all applicable codes and ordinances. I will not supervise the work.

*Bruce D. Barton*  
Date: \_\_\_\_\_  
BRUCE D. BARTON, P. 18295



**AS ALL SOUTH ENGINEERS, L.L.C.**  
652 PAPERWORTH AVENUE  
METAIRIE, LA 70005  
504 922-2785

DESIGNED BY:	RAC
DRAWN BY:	EAO
CHECKED BY:	RAC

**PLAQUEMINES PARISH QUIET ROOMS  
PACKAGE NO. 2**  
DIAMOND PUMP STATION, HAYES PUMP STATION,  
GRAND DELIARD PUMP STATION, AND DUVIC PUMP STATION,  
HAYES PUMP STATION  
ELECTRICAL CONDUIT PLAN

SHEET NO.  
**HY-E2**

35 OF 67

CADD FILE NAME:

REVISIONS	REMARKS	DATE
APPD		