

GENERAL NOTES THIS SHEET:

- ALL SEWER AND STORM DRAIN PIPING SHALL BE RUN BELOW SLAB UNLESS NOTED OTHERWISE. HANG FROM SLAB.
- VENT PIPING SHALL BE RUN ABOVE CEILING OR TIGHT TO STRUCTURE.
- PROVIDE TRAP PRIMERS ON ALL FLOOR DRAINS.
- INSULATE HORIZONTAL RUN OF WASTE PIPING RECEIVING A/C CONDENSATE.
- INSULATE ROOF DRAINS AND HORIZONTAL STORM DRAIN PIPING RUNS ABOVE GRADE.
- ALL COLD WATER, HOT WATER AND HOT WATER RE-CIRCULATING PIPING SHALL BE RUN ABOVE CEILING OR TIGHT TO STRUCTURE. STORM DRAIN PIPING ABOVE GRADE SHALL BE RUN ABOVE CEILING OR TIGHT TO STRUCTURE.
- ALL WATER PIPING SHALL BE 3/4" UNLESS NOTED OTHERWISE.
- PROVIDE AIR CHAMBERS ON ALL DOMESTIC WATER BRANCH PIPING SERVING FIXTURES.
- PROVIDE ISOLATION VALVES IN THE HOT AND COLD WATER PIPING TO ALL FIXTURE GROUPS.
- MINIMUM VENT THRU ROOF SHALL BE 2".
- ALL FIXTURES SHALL BE INSTALLED LEVEL AND TRUE. CENTER FIXTURES WHERE APPLICABLE. FOR INSTANCE WATER CLOSETS IN NON-ADA STALLS.
- ALL ADA FIXTURES SHALL BE INSTALLED PER ADA GUIDELINES.
- FLOOR DRAINS IN TOILET ROOMS SHALL BE COORDINATED AND LOCATED PER ARCHITECTURAL FLOOR PLANS.
- FLOOR DRAINS USED FOR AIR UNITS SHALL BE LOCATED AS CLOSE TO EDGE OF UNIT AS POSSIBLE. COORDINATE LOCATION WITH SUBMITTED UNIT DIMENSIONAL DATA.
- PLUMBING SHALL CONFORM TO THE LOUISIANA STATE PLUMBING CODE.

SPECIFIC NOTES THIS SHEET:

- CONNECT TO EXISTING SS. VERIFY EXACT LOCATION ON SITE.
- SEE ARCHITECTURAL PLANS FOR LIMITS OF TRENCHING.
- EXCAVATE UNDER GRADE BEAM UNDER BUILDING SLAB.
- CONNECT TO EXISTING CW. VERIFY EXACT LOCATION ON SITE.
- ELECTRIC WATER HEATER ABOVE CEILING. SEE DETAIL ON M-5.
- PROVIDE SUMP PUMP BELOW SINK AND PUMP TO ABOVE CEILING.
- INCLUDES SDS1 SINK PACKAGE OR EQUAL CAPABLE OF PASSING 3/4" SOLIDS, 55 GPM @ 24' HEAD, 10 GALLON FOAM BASIN.
- TRAP PRIMER ABOVE CEILING. SEE DETAIL ON M-5.
- TRAP PRIMER LINE DOWN WALL TO FLOOR DRAIN.
- PROVIDE NEW CLEAN OUT IN EXISTING SEWER.

