




HVAC PLAN UNIT 1A
SCALE: 1/4" = 1'-0"



HVAC PLAN UNIT 1B
SCALE: 1/4" = 1'-0"



HVAC PLAN UNIT 2A
SCALE: 1/4" = 1'-0"



HVAC PLAN UNIT 2B
SCALE: 1/4" = 1'-0"

LEGEND

- SUPPLY AIR VENT
- ▾ FIRE DAMPER
- BATHROOM EXHAUST
- ⊕ THERMOSTAT

MECHANICAL SPECIFICATIONS
2 TON HEAT PUMP

EQUIPMENT SELECTIONS

INDOOR HEAT PUMP	ADP_BU24210
AIR FLOW	800 CFM
ELECTRICAL SPECIFICATIONS	240V-1ϕ
UNIT M.C.A. (INCLUDING HEAT)	55.0 AMPS
REV. CYCLE HEAT CAPACITY	34120 BTUH
AUX. HEAT CAPACITY	10.0 KW (41.6A)
OUTDOOR HEAT PUMP	DUCANE_HP10B24
ELECTRICAL SPECIFICATIONS	240V-1ϕ
UNIT M.C.A.	16.3 MCA
COOLING CAPACITY	24,000 BTUH S.E.E.R. 10.0

MECHANICAL SPECIFICATIONS
2.5 TON HEAT PUMP

EQUIPMENT SELECTIONS

INDOOR HEAT PUMP	ADP_BU30210
AIR FLOW	1000 CFM
ELECTRICAL SPECIFICATIONS	240V-1ϕ
UNIT M.C.A. (INCLUDING HEAT)	56.0 AMPS
REV. CYCLE HEAT CAPACITY	34120 BTUH
AUX. HEAT CAPACITY	10.0 KW (41.6A)
OUTDOOR HEAT PUMP	DUCANE_HP10B30
ELECTRICAL SPECIFICATIONS	240V-1ϕ
UNIT M.C.A.	21.4 MCA
COOLING CAPACITY	30,000 BTUH S.E.E.R. 10.0

THE BRYAN COMPANY
ISLAND PARK
APARTMENT COMMUNITY
SHREVEPORT, LA.

ISLAND PARK
DAMMON ENGINEERING, INC.
ARCHITECTS - ENGINEERS
SLIDELL, LA. 70458
819 ROBERT ROAD

SCALE: AS NOTED

FILE: -

JOB No.: -

DATE: 03-29-04

SHEET

M-3

OF -